

FUEL INVENTORY CONTROL REPORT

FACILITY NAME:

Kool Corner

MONTH/YEAR:

AUGUST

2024

FACILITY ID #:

67397

TANK SIZE:

8000

FUEL TYPE:

REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
29-Jul		3460	0	946	2514		2497	-17	-17
30-Jul		2497	0	904	1593		1598	5	-12
31-Jul		1598	0	855	743		745	2	-10
1-Aug		745	6900	638	7007		7036	29	19
2-Aug		7036	0	1044	5992		5983	-9	10
3-Aug		5983	0	1075	4908		4893	-15	-5
4-Aug		4893	0	804	4089		4086	-3	-8
5-Aug		4086	0	0	4086		4086	0	-8
6-Aug		4086	0	0	4086		4086	0	-8
7-Aug		4086	0	0	4086		4086	0	-8
8-Aug		4086	0	3551	535		509	-26	-34
9-Aug		509	6500	689	6320		6335	15	-19
10-Aug		6335	0	1110	5225		5236	11	-8
11-Aug		5236	0	835	4401		4385	-16	-24
12-Aug		4385	0	1065	3320		3315	-5	-29
13-Aug		3315	0	1042	2273		2271	-2	-31
14-Aug		2271	0	766	1505		1512	7	-24
15-Aug		1512	6000	1022	6490		6513	23	-1
16-Aug		6513	0	1004	5509		5496	-13	-14
17-Aug		5496	0	1012	4484		4477	-7	-21
18-Aug		4477	0	955	3522		3515	-7	-28
19-Aug		3515	0	953	2562		2558	-4	-32
20-Aug		2558	0	797	1761		1763	2	-30
21-Aug		1763	0	913	850		855	5	-25
22-Aug		855	0	526	329		333	4	-21
23-Aug		333	6810	538	6605		6615	10	-11
24-Aug		6615	0	960	5655		5642	-13	-24
25-Aug		5642	0	938	4704		4697	-7	-31
26-Aug		4697	0	835	3862		3857	-5	-36
27-Aug		3857	0	947	2910		2908	-2	-38

TOTAL SALES:

26724

TOTAL OVER/SHORT:

-38

LEAK TEST:

397.24

WATER CHECK (INCHES):

0

PASS / FAIL:

PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: AUGUST 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
29-Jul		1698	0	66	1632		1631	-1	-1
30-Jul		1631	0	92	1539		1522	-17	-18
31-Jul		1522	0	99	1423		1442	19	1
1-Aug		1442	500	183	1759		1758	-1	0
2-Aug		1758	0	116	1642		1643	1	1
3-Aug		1643	0	148	1495		1497	2	3
4-Aug		1497	0	108	1389		1399	10	13
5-Aug		1399	0	0	1399		1399	0	13
6-Aug		1399	0	0	1399		1399	0	13
7-Aug		1399	0	0	1399		1399	0	13
8-Aug		1399	0	492	907		909	2	15
9-Aug		909	500	77	1332		1347	15	30
10-Aug		1347	0	67	1280		1275	-5	25
11-Aug		1275	0	173	1102		1103	1	26
12-Aug		1103	0	117	986		986	0	26
13-Aug		986	0	110	876		877	1	27
14-Aug		877	0	81	796		796	0	27
15-Aug		796	1500	191	2105		2106	1	28
16-Aug		2106	0	87	2019		2016	-3	25
17-Aug		2016	0	117	1899		1899	0	25
18-Aug		1899	0	172	1727		1727	0	25
19-Aug		1727	0	139	1588		1590	2	27
20-Aug		1590	0	99	1491		1491	0	27
21-Aug		1491	0	163	1328		1329	1	28
22-Aug		1329	0	52	1277		1277	0	28
23-Aug		1277	1206	97	2386		2382	-4	24
24-Aug		2382	0	155	2227		2227	0	24
25-Aug		2227	0	123	2104		2104	0	24
26-Aug		2104	0	65	2039		2038	-1	23
27-Aug		2038	0	137	1901		1902	1	24

TOTAL SALES: 3526 TOTAL OVER/SHORT: 24

LEAK TEST: 165.26 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.