



## LINE AND LEAK DETECTOR TEST DATA FORM

**Facility Name:** Mickeys 14 **Date:** 11/8/2023  
**Facility Address:** 4826 Stagecoach Rd  
Killeen, TX 76542  
**Facility Phone:** \_\_\_\_\_  
**Test Contractor:** PETRO-TANK SOLUTIONS, LLC  
**Address:** 6115 FM 762 Rd Suite 500 **Tester:** Anil Momin  
Richmond, TX 77469  
**Contractor Phone:** (281) 242-2687 **License #** 4865.LTN

Product	REGULAR	SUPER	DIESEL	
Pump Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Isolation Mechanism	Ball Valve	Ball Valve	Ball Valve	
Test Pressure (1 1/2 times working pressure)	50 PSI	50 PSI	50 PSI	
Initial Cylinder Level (ICL)	0.040	0.040	0.090	
Final Cylinder Level (FCL)	0.040	0.040	0.090	
Leak Volume = ICL - FCL	0.000	0.000	0.000	
Time Started	10:30	10:30	11:15	
Time Completed	11:00	11:00	11:45	
Total Test Time (30 min. minimum)	30 MIN	30 MIN	30 MIN	
Conclusion (Pass or Fail)	Pass	Pass	Pass	
Leak Detector Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Line PSI	29 PSI	28 PSI	26 PSI	
Leak Detector Result (Pass or Fail)	Pass	Pass	Pass	

**Comments:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_