

**APPENDIX C-5****UST OVERFILL EQUIPMENT INSPECTION  
AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE**

Facility Name: <b>Foodies Corner 5</b>			Owner: <b>Whitestone Business, INC</b>			
Address: <b>1405 W Whitestone Blvd</b>			Address: <b>1405 W Whitestone Blvd</b>			
City, State, Zip Code: <b>Cedar Park, TX 78613</b>			City, State, Zip Code: <b>Cedar Park, TX 78613</b>			
Facility I.D. #: <b>55347</b>			Phone #:			
Testing Company: <b>Petro-Tank Solutions</b>			Phone #:		Date: <b>6/17/2024</b>	
This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.						
Product Grade	<b>Diesel</b>	<b>Regular</b>	<b>Super</b>			
Tank Number	<b>1A</b>	<b>2A</b>	<b>3A</b>			
Tank Volume, gallons	<b>8000</b>	<b>8000</b>	<b>8000</b>			
Tank Diameter, inches	<b>92"</b>	<b>92"</b>	<b>92"</b>			
Overfill Prevention Device Brand	<b>OPW</b>	<b>OPW</b>	<b>OPW</b>			
Type	<input type="checkbox"/> Automatic Shutoff Device <input checked="" type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input checked="" type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input checked="" type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve
<b>AUTOMATIC SHUTOFF DEVICE INSPECTION</b>						
1. Drop tube removed from tank?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Drop tube and float mechanisms free of debris?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Float moves freely without binding and poppet moves into flow path?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Bypass valve in the drop tube open and free of blockage (if present)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present
5. Flapper adjusted to shut off flow at 95% capacity?*	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
A "No" to any item in Lines 1-5 indicates a test failure.						
<b>BALL FLOAT VALVE INSPECTION**</b>						
1. Tank top fittings vapor-tight and leak-free?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Ball float cage free of debris?	<b>Yes</b>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Ball free of holes and cracks and moves freely in cage?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Vent hole in pipe open and near top of tank?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. Ball float pipe proper length to restrict flow at 90% capacity?***	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
A "No" to any item in Lines 1-5 indicates a test failure.						
<b>Test Results</b>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
<b>Comments:</b>						

\* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

\*\* If a ball float is found to fail the inspection, another method of overfill must be used.

\*\*\* Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Tester's Name (print) Jadell BurnsTester's Signature Jadell Burns