

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: DECEMBER | 2023FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
2-Nov		1378	6000	1066	6312		6336	24	24
3-Nov		6336	0	952	5384		5389	5	29
4-Nov		5389	0	968	4421		4417	-4	25
5-Nov		4417	0	903	3514		3505	-9	16
6-Nov		3505	0	781	2724		2717	-7	9
7-Nov		2717	0	1017	1700		1696	-4	5
8-Nov		1696	0	830	866		865	-1	4
9-Nov		865	6700	798	6767		6780	13	17
10-Nov		6780	0	877	5903		5893	-10	7
11-Nov		5893	0	875	5018		5018	0	7
12-Nov		5018	0	801	4217		4208	-9	-2
13-Nov		4208	0	831	3377		3366	-11	-13
14-Nov		3366	0	774	2592		2574	-18	-31
15-Nov		2574	0	925	1649		1641	-8	-39
16-Nov		1641	0	985	656		652	-4	-43
17-Nov		652	0	321	331		331	0	-43
18-Nov		331	6802	1026	6107		6117	10	-33
19-Nov		6117	0	781	5336		5334	-2	-35
20-Nov		5334	0	902	4432		4428	-4	-39
21-Nov		4428	0	1045	3383		3371	-12	-51
22-Nov		3371	0	919	2452		2441	-11	-62
23-Nov		2441	0	748	1693		1684	-9	-71
24-Nov		1684	0	621	1063		1057	-6	-77
25-Nov		1057	6501	590	6968		7007	39	-38
26-Nov		7007	0	554	6453		6443	-10	-48
27-Nov		6443	0	868	5575		5563	-12	-60
28-Nov		5563	0	805	4758		4748	-10	-70
29-Nov		4748	0	800	3948		3939	-9	-79
30-Nov		3939	0	973	2966		2954	-12	-91
1-Dec		2954	0	1194	1760		1752	-8	-99

TOTAL SALES: 25530TOTAL OVER/SHORT: -99LEAK TEST: 385.3WATER CHECK (INCHES): 0PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: DECEMBER | 2023FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
2-Nov		1056	500	148	1408		1410	2	2
3-Nov		1410	0	185	1225		1225	0	2
4-Nov		1225	0	105	1120		1119	-1	1
5-Nov		1119	0	89	1030		1030	0	1
6-Nov		1030	0	99	931		930	-1	0
7-Nov		930	0	131	799		799	0	0
8-Nov		799	0	112	687		686	-1	-1
9-Nov		686	1000	101	1585		1588	3	2
10-Nov		1588	0	160	1428		1427	-1	1
11-Nov		1427	0	131	1296		1300	4	5
12-Nov		1300	0	165	1135		1134	-1	4
13-Nov		1134	0	120	1014		1013	-1	3
14-Nov		1013	0	132	881		881	0	3
15-Nov		881	0	132	749		747	-2	1
16-Nov		747	0	92	655		654	-1	0
17-Nov		654	0	21	633		633	0	0
18-Nov		633	1000	105	1528		1535	7	7
19-Nov		1535	0	130	1405		1406	1	8
20-Nov		1406	0	94	1312		1312	0	8
21-Nov		1312	0	126	1186		1185	-1	7
22-Nov		1185	0	50	1135		1134	-1	6
23-Nov		1134	0	93	1041		1040	-1	5
24-Nov		1040	0	140	900		899	-1	4
25-Nov		899	600	45	1454		1455	1	5
26-Nov		1455	0	131	1324		1325	1	6
27-Nov		1325	0	110	1215		1213	-2	4
28-Nov		1213	0	106	1107		1106	-1	3
29-Nov		1106	0	73	1033		1032	-1	2
30-Nov		1032	0	154	878		877	-1	1
1-Dec		877	0	117	760		759	-1	0

TOTAL SALES: 3397TOTAL OVER/SHORT: 0LEAK TEST: 163.97WATER CHECK (INCHES): 0PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.