

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 02/05/2023

Effective Dates : 01/06/23 to 02/04/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/6/2023	5,864.00	0.00	1,074.00	0.00	4,790.00	4,786.00	0.00	-4.00	-4.00	
1/7/2023	4,786.00	0.00	844.00	0.00	3,942.00	3,940.00	0.00	-2.00	-6.00	
1/8/2023	3,940.00	0.00	924.00	0.00	3,016.00	3,009.00	0.00	-7.00	-13.00	
1/9/2023	3,009.00	0.00	880.00	0.00	2,129.00	2,123.00	0.00	-6.00	-19.00	
1/10/2023	2,123.00	0.00	927.00	0.00	1,196.00	1,205.00	0.00	9.00	-10.00	
1/11/2023	1,205.00	0.00	878.00	0.00	327.00	330.00	0.00	3.00	-7.00	
1/12/2023	330.00	7,000.00	587.00	0.00	6,743.00	6,760.00	0.00	17.00	10.00	
1/13/2023	6,760.00	0.00	985.00	0.00	5,775.00	5,769.00	0.00	-6.00	4.00	
1/14/2023	5,769.00	0.00	1,016.00	0.00	4,753.00	4,745.00	0.00	-8.00	-4.00	
1/15/2023	4,745.00	0.00	957.00	0.00	3,788.00	3,789.00	0.00	1.00	-3.00	
1/16/2023	3,789.00	0.00	765.00	0.00	3,024.00	3,018.00	0.00	-6.00	-9.00	
1/17/2023	3,018.00	0.00	819.00	0.00	2,199.00	2,180.00	0.00	-19.00	-28.00	
1/18/2023	2,180.00	0.00	767.00	0.00	1,413.00	1,414.00	0.00	1.00	-27.00	
1/19/2023	1,414.00	6,500.00	939.00	0.00	6,975.00	6,986.00	0.00	11.00	-16.00	
1/20/2023	6,986.00	0.00	1,027.00	0.00	5,959.00	5,947.00	0.00	-12.00	-28.00	
1/21/2023	5,947.00	0.00	750.00	0.00	5,197.00	5,192.00	0.00	-5.00	-33.00	
1/22/2023	5,192.00	0.00	825.00	0.00	4,367.00	4,363.00	0.00	-4.00	-37.00	
1/23/2023	4,363.00	0.00	930.00	0.00	3,433.00	3,427.00	0.00	-6.00	-43.00	
1/24/2023	3,427.00	0.00	840.00	0.00	2,587.00	2,581.00	0.00	-6.00	-49.00	
1/25/2023	2,581.00	0.00	820.00	0.00	1,761.00	1,761.00	0.00	0.00	-49.00	Verif.Sales
1/26/2023	1,761.00	5,911.00	1,065.00	0.00	6,607.00	6,591.00	0.00	-16.00	-65.00	
1/27/2023	6,591.00	0.00	1,056.00	0.00	5,535.00	5,532.00	0.00	-3.00	-68.00	
1/28/2023	5,532.00	0.00	819.00	0.00	4,713.00	4,712.00	0.00	-1.00	-69.00	
1/29/2023	4,712.00	0.00	691.00	0.00	4,021.00	4,019.00	0.00	-2.00	-71.00	
1/30/2023	4,019.00	0.00	1,095.00	0.00	2,924.00	2,916.00	0.00	-8.00	-79.00	
1/31/2023	2,916.00	0.00	499.00	0.00	2,417.00	2,413.00	0.00	-4.00	-83.00	
2/1/2023	2,413.00	0.00	0.00	0.00	2,413.00	2,413.00	0.00	0.00	-83.00	
2/2/2023	2,413.00	0.00	0.00	0.00	2,413.00	2,413.00	0.00	0.00	-83.00	
2/3/2023	2,413.00	0.00	0.00	0.00	2,413.00	2,413.00	0.00	0.00	-83.00	
2/4/2023	2,413.00	0.00	721.00	0.00	1,692.00	1,687.00	0.00	-5.00	-88.00	
TOTALS		19,411.00	23,500.00	0.00			0.00	-88.00	-88.00	

Leak Check = (23,500.00 * 0.01 + 130) = 365.0 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	365.0 gall	0.0 inches	-0.0218 gph	0.0353 gph	PASS	PASS	ND
Min. Daily Sales :		0.0	Max. Daily Sales :		1095.0	Avg. Daily Sales : 783.3	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 02/05/2023

Effective Dates : 01/06/23 to 02/04/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/6/2023	1,628.00	0.00	125.00	0.00	1,503.00	1,503.00	0.00	0.00	0.00	Verif.Sales
1/7/2023	1,503.00	0.00	86.00	0.00	1,417.00	1,417.00	0.00	0.00	0.00	Verif.Sales
1/8/2023	1,417.00	0.00	144.00	0.00	1,273.00	1,273.00	0.00	0.00	0.00	Verif.Sales
1/9/2023	1,273.00	0.00	152.00	0.00	1,121.00	1,120.00	0.00	-1.00	-1.00	
1/10/2023	1,120.00	0.00	157.00	0.00	963.00	963.00	0.00	0.00	-1.00	Verif.Sales
1/11/2023	963.00	0.00	184.00	0.00	779.00	778.00	0.00	-1.00	-2.00	
1/12/2023	778.00	1,000.00	85.00	0.00	1,693.00	1,687.00	0.00	-6.00	-8.00	
1/13/2023	1,687.00	0.00	156.00	0.00	1,531.00	1,539.00	0.00	8.00	0.00	
1/14/2023	1,539.00	0.00	101.00	0.00	1,438.00	1,438.00	0.00	0.00	0.00	Verif.Sales
1/15/2023	1,438.00	0.00	175.00	0.00	1,263.00	1,262.00	0.00	-1.00	-1.00	
1/16/2023	1,262.00	0.00	128.00	0.00	1,134.00	1,134.00	0.00	0.00	-1.00	Verif.Sales
1/17/2023	1,134.00	0.00	80.00	0.00	1,054.00	1,053.00	0.00	-1.00	-2.00	
1/18/2023	1,053.00	0.00	90.00	0.00	963.00	963.00	0.00	0.00	-2.00	Verif.Sales
1/19/2023	963.00	1,500.00	60.00	0.00	2,403.00	2,406.00	0.00	3.00	1.00	
1/20/2023	2,406.00	0.00	202.00	0.00	2,204.00	2,205.00	0.00	1.00	2.00	
1/21/2023	2,205.00	0.00	138.00	0.00	2,067.00	2,067.00	0.00	0.00	2.00	Verif.Sales
1/22/2023	2,067.00	0.00	114.00	0.00	1,953.00	1,953.00	0.00	0.00	2.00	Verif.Sales
1/23/2023	1,953.00	0.00	140.00	0.00	1,813.00	1,812.00	0.00	-1.00	1.00	
1/24/2023	1,812.00	0.00	79.00	0.00	1,733.00	1,732.00	0.00	-1.00	0.00	
1/25/2023	1,732.00	0.00	100.00	0.00	1,632.00	1,632.00	0.00	0.00	0.00	Verif.Sales
1/26/2023	1,632.00	0.00	139.00	0.00	1,493.00	1,492.00	0.00	-1.00	-1.00	
1/27/2023	1,492.00	0.00	180.00	0.00	1,312.00	1,311.00	0.00	-1.00	-2.00	
1/28/2023	1,311.00	0.00	154.00	0.00	1,157.00	1,156.00	0.00	-1.00	-3.00	
1/29/2023	1,156.00	0.00	161.00	0.00	995.00	994.00	0.00	-1.00	-4.00	
1/30/2023	994.00	0.00	105.00	0.00	889.00	888.00	0.00	-1.00	-5.00	
1/31/2023	888.00	0.00	34.00	0.00	854.00	853.00	0.00	-1.00	-6.00	
2/1/2023	853.00	0.00	0.00	0.00	853.00	853.00	0.00	0.00	-6.00	
2/2/2023	853.00	0.00	0.00	0.00	853.00	853.00	0.00	0.00	-6.00	
2/3/2023	853.00	0.00	0.00	0.00	853.00	853.00	0.00	0.00	-6.00	
2/4/2023	853.00	0.00	95.00	0.00	758.00	756.00	0.00	-2.00	-8.00	
TOTALS		2,500.00	3,364.00	0.00			0.00	-8.00	-8.00	

Leak Check = (3,364.00 * 0.01 + 130) = 163.6 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago	
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result	
0.1000	163.6 gall	0.0 inches	-0.0066 gph	0.0058 gph	PASS	PASS	ND	
Min. Daily Sales :		0.0	Max. Daily Sales :		202.0	Avg. Daily Sales :		112.1

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496