

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 01/04/2024

Effective Dates : 12/02/23 to 12/31/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
12/2/2023	1,752.00	0.00	848.00	0.00	904.00	901.00	0.00	-3.00	-3.00	
12/3/2023	901.00	6,600.00	845.00	0.00	6,656.00	6,677.00	0.00	21.00	18.00	
12/4/2023	6,677.00	0.00	984.00	0.00	5,693.00	5,679.00	0.00	-14.00	4.00	
12/5/2023	5,679.00	0.00	972.00	0.00	4,707.00	4,695.00	0.00	-12.00	-8.00	
12/6/2023	4,695.00	0.00	993.00	0.00	3,702.00	3,691.00	0.00	-11.00	-19.00	
12/7/2023	3,691.00	0.00	854.00	0.00	2,837.00	2,827.00	0.00	-10.00	-29.00	
12/8/2023	2,827.00	0.00	981.00	0.00	1,846.00	1,840.00	0.00	-6.00	-35.00	
12/9/2023	1,840.00	0.00	1,086.00	0.00	754.00	753.00	0.00	-1.00	-36.00	
12/10/2023	753.00	6,001.00	873.00	0.00	5,881.00	5,880.00	0.00	-1.00	-37.00	
12/11/2023	5,880.00	0.00	1,057.00	0.00	4,823.00	4,820.00	0.00	-3.00	-40.00	
12/12/2023	4,820.00	0.00	1,103.00	0.00	3,717.00	3,709.00	0.00	-8.00	-48.00	
12/13/2023	3,709.00	0.00	751.00	0.00	2,958.00	2,948.00	0.00	-10.00	-58.00	
12/14/2023	2,948.00	0.00	1,039.00	0.00	1,909.00	1,903.00	0.00	-6.00	-64.00	
12/15/2023	1,903.00	0.00	903.00	0.00	1,000.00	999.00	0.00	-1.00	-65.00	
12/16/2023	999.00	6,501.00	959.00	0.00	6,541.00	6,554.00	0.00	13.00	-52.00	
12/17/2023	6,554.00	0.00	1,013.00	0.00	5,541.00	5,531.00	0.00	-10.00	-62.00	
12/18/2023	5,531.00	0.00	716.00	0.00	4,815.00	4,807.00	0.00	-8.00	-70.00	
12/19/2023	4,807.00	0.00	899.00	0.00	3,908.00	3,897.00	0.00	-11.00	-81.00	
12/20/2023	3,897.00	0.00	934.00	0.00	2,963.00	2,950.00	0.00	-13.00	-94.00	
12/21/2023	2,950.00	0.00	870.00	0.00	2,080.00	2,071.00	0.00	-9.00	-103.00	
12/22/2023	2,071.00	0.00	979.00	0.00	1,092.00	1,090.00	0.00	-2.00	-105.00	
12/23/2023	1,090.00	6,002.00	926.00	0.00	6,166.00	6,210.00	0.00	44.00	-61.00	
12/24/2023	6,210.00	0.00	870.00	0.00	5,340.00	5,339.00	0.00	-1.00	-62.00	
12/25/2023	5,339.00	0.00	614.00	0.00	4,725.00	4,705.00	0.00	-20.00	-82.00	
12/26/2023	4,705.00	0.00	683.00	0.00	4,022.00	4,015.00	0.00	-7.00	-89.00	
12/27/2023	4,015.00	0.00	844.00	0.00	3,171.00	3,159.00	0.00	-12.00	-101.00	
12/28/2023	3,159.00	0.00	783.00	0.00	2,376.00	2,367.00	0.00	-9.00	-110.00	
12/29/2023	2,367.00	0.00	877.00	0.00	1,490.00	1,486.00	0.00	-4.00	-114.00	
12/30/2023	1,486.00	0.00	819.00	0.00	667.00	665.00	0.00	-2.00	-116.00	
12/31/2023	665.00	6,801.00	496.00	0.00	6,970.00	6,983.00	0.00	13.00	-103.00	
TOTALS		31,905.00	26,571.00	0.00			0.00	-103.00	-103.00	

Leak Check = (26,571.00 * 0.01 + 130) = 395.7 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	395.7 gall	0.0 inches	-0.0551 gph	0.0494 gph	PASS	PASS	PASS
Min. Daily Sales :		496.0	Max. Daily Sales :		1103.0	Avg. Daily Sales : 885.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 01/04/2024

Effective Dates : 12/02/23 to 12/31/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
12/2/2023	759.00	0.00	96.00	0.00	663.00	662.00	0.00	-1.00	-1.00	
12/3/2023	662.00	1,000.00	120.00	0.00	1,542.00	1,545.00	0.00	3.00	2.00	
12/4/2023	1,545.00	0.00	101.00	0.00	1,444.00	1,445.00	0.00	1.00	3.00	
12/5/2023	1,445.00	0.00	137.00	0.00	1,308.00	1,307.00	0.00	-1.00	2.00	
12/6/2023	1,307.00	0.00	99.00	0.00	1,208.00	1,208.00	0.00	0.00	2.00	Verif.Sales
12/7/2023	1,208.00	0.00	168.00	0.00	1,040.00	1,039.00	0.00	-1.00	1.00	
12/8/2023	1,039.00	0.00	90.00	0.00	949.00	949.00	0.00	0.00	1.00	Verif.Sales
12/9/2023	949.00	0.00	111.00	0.00	838.00	837.00	0.00	-1.00	0.00	
12/10/2023	837.00	1,000.00	126.00	0.00	1,711.00	1,716.00	0.00	5.00	5.00	
12/11/2023	1,716.00	0.00	190.00	0.00	1,526.00	1,528.00	0.00	2.00	7.00	
12/12/2023	1,528.00	0.00	167.00	0.00	1,361.00	1,360.00	0.00	-1.00	6.00	
12/13/2023	1,360.00	0.00	73.00	0.00	1,287.00	1,287.00	0.00	0.00	6.00	Verif.Sales
12/14/2023	1,287.00	0.00	136.00	0.00	1,151.00	1,150.00	0.00	-1.00	5.00	
12/15/2023	1,150.00	0.00	197.00	0.00	953.00	951.00	0.00	-2.00	3.00	
12/16/2023	951.00	700.00	163.00	0.00	1,488.00	1,490.00	0.00	2.00	5.00	
12/17/2023	1,490.00	0.00	160.00	0.00	1,330.00	1,330.00	0.00	0.00	5.00	Verif.Sales
12/18/2023	1,330.00	0.00	135.00	0.00	1,195.00	1,195.00	0.00	0.00	5.00	Verif.Sales
12/19/2023	1,195.00	0.00	135.00	0.00	1,060.00	1,059.00	0.00	-1.00	4.00	
12/20/2023	1,059.00	0.00	93.00	0.00	966.00	964.00	0.00	-2.00	2.00	
12/21/2023	964.00	0.00	122.00	0.00	842.00	835.00	0.00	-7.00	-5.00	
12/22/2023	835.00	0.00	91.00	0.00	744.00	744.00	0.00	0.00	-5.00	Verif.Sales
12/23/2023	744.00	1,000.00	104.00	0.00	1,640.00	1,603.00	0.00	-37.00	-42.00	
12/24/2023	1,603.00	0.00	142.00	0.00	1,461.00	1,462.00	0.00	1.00	-41.00	
12/25/2023	1,462.00	0.00	118.00	0.00	1,344.00	1,344.00	0.00	0.00	-41.00	Verif.Sales
12/26/2023	1,344.00	0.00	67.00	0.00	1,277.00	1,276.00	0.00	-1.00	-42.00	
12/27/2023	1,276.00	0.00	105.00	0.00	1,171.00	1,171.00	0.00	0.00	-42.00	Verif.Sales
12/28/2023	1,171.00	0.00	114.00	0.00	1,057.00	1,056.00	0.00	-1.00	-43.00	
12/29/2023	1,056.00	0.00	153.00	0.00	903.00	902.00	0.00	-1.00	-44.00	
12/30/2023	902.00	0.00	164.00	0.00	738.00	736.00	0.00	-2.00	-46.00	
12/31/2023	736.00	1,000.00	65.00	0.00	1,671.00	1,674.00	0.00	3.00	-43.00	
TOTALS		4,700.00	3,742.00	0.00			0.00	-43.00	-43.00	

Leak Check = (3,742.00 * 0.01 + 130) = 167.4 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	167.4 gall	0.0 inches	0.0148 gph	0.0122 gph	PASS	PASS	PASS
Min. Daily Sales :		65.0	Max. Daily Sales :		197.0	Avg. Daily Sales : 124.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496