

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner

MONTH/YEAR: MARCH 2024

FACILITY ID #: 67397

TANK SIZE: 8000

FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
31-Jan		4999	0	0	4999		4999	0	0
1-Feb		4999	0	0	4999		4999	0	0
2-Feb		4999	0	0	4999		5000	1	1
3-Feb		5000	0	0	5000		5000	0	1
4-Feb		5000	0	0	5000		5001	1	2
5-Feb		5001	0	0	5001		5002	1	3
6-Feb		5002	0	0	5002		5003	1	4
7-Feb		5003	0	0	5003		5003	0	4
8-Feb		5003	0	0	5003		5004	1	5
9-Feb		5004	0	0	5004		5005	1	6
10-Feb		5005	0	0	5005		5005	0	6
11-Feb		5005	0	0	5005		5006	1	7
12-Feb		5006	0	0	5006		5007	1	8
13-Feb		5007	0	0	5007		5007	0	8
14-Feb		5007	0	0	5007		5008	1	9
15-Feb		5008	0	0	5008		5008	0	9
16-Feb		5008	0	0	5008		5008	0	9
17-Feb		5008	0	0	5008		5009	1	10
18-Feb		5009	0	0	5009		5009	0	10
19-Feb		5009	0	0	5009		5009	0	10
20-Feb		5009	0	0	5009		5010	1	11
21-Feb		5010	0	0	5010		5010	0	11
22-Feb		5010	0	0	5010		5010	0	11
23-Feb		5010	0	0	5010		5010	0	11
24-Feb		5010	0	0	5010		5010	0	11
25-Feb		5010	0	0	5010		5011	1	12
26-Feb		5011	0	0	5011		5011	0	12
27-Feb		5011	0	0	5011		5012	1	13
28-Feb		5012	0	102	4910		4905	-5	8
29-Feb		4905	0	580	4325		4322	-3	5

TOTAL SALES: 682

TOTAL OVER/SHORT: 5

LEAK TEST: 136.82

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: MARCH | 2024FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
31-Jan		1411	0	0	1411		1411	0	0
1-Feb		1411	0	0	1411		1410	-1	-1
2-Feb		1410	0	0	1410		1410	0	-1
3-Feb		1410	0	0	1410		1410	0	-1
4-Feb		1410	0	0	1410		1411	1	0
5-Feb		1411	0	0	1411		1411	0	0
6-Feb		1411	0	0	1411		1411	0	0
7-Feb		1411	0	0	1411		1411	0	0
8-Feb		1411	0	0	1411		1411	0	0
9-Feb		1411	0	0	1411		1411	0	0
10-Feb		1411	0	0	1411		1411	0	0
11-Feb		1411	0	0	1411		1411	0	0
12-Feb		1411	0	0	1411		1411	0	0
13-Feb		1411	0	0	1411		1411	0	0
14-Feb		1411	0	0	1411		1411	0	0
15-Feb		1411	0	0	1411		1411	0	0
16-Feb		1411	0	0	1411		1411	0	0
17-Feb		1411	0	0	1411		1411	0	0
18-Feb		1411	0	0	1411		1411	0	0
19-Feb		1411	0	0	1411		1410	-1	-1
20-Feb		1410	0	0	1410		1410	0	-1
21-Feb		1410	0	0	1410		1410	0	-1
22-Feb		1410	0	0	1410		1410	0	-1
23-Feb		1410	0	0	1410		1410	0	-1
24-Feb		1410	0	0	1410		1410	0	-1
25-Feb		1410	0	0	1410		1410	0	-1
26-Feb		1410	0	0	1410		1410	0	-1
27-Feb		1410	0	0	1410		1410	0	-1
28-Feb		1410	0	6	1404		1374	-30	-31
29-Feb		1374	0	66	1308		1307	-1	-32

TOTAL SALES: 72TOTAL OVER/SHORT: -32LEAK TEST: 130.72WATER CHECK (INCHES): 0PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**