

CONTAINMENT SUMP INTEGRITY TESTING						
HYDROSTATIC TESTING METHOD						
Facility Name:		Owner:		-		
Address:		-		Address:		-
City, State, Zip Code:		-		City, State, Zip Code:		-
Facility I.D. #:		-		Phone #:		-
Testing Company:		-		Phone #:		Date:
This procedure is to test the leak integrity of containment sumps. See PEI/RP1200, Section 6.5 for the test method.						
Containment Sump ID		Regular	Super	Diesel		
Pass/Fail criteria: Must pass visual inspection. Water level drop of less than 1/8 inch.						
Test Results		-	-	-		
Comments:						

* All liquids and debris must be disposed of properly.

Tester's Name _____ Tester's Signature _____