

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 01/11/2023

Effective Dates : 12/07/22 to 01/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
12/7/2022	4,942.00	0.00	742.00	0.00	4,200.00	4,204.00	0.00	4.00	4.00	
12/8/2022	4,204.00	0.00	815.00	0.00	3,389.00	3,384.00	0.00	-5.00	-1.00	
12/9/2022	3,384.00	0.00	931.00	0.00	2,453.00	2,450.00	0.00	-3.00	-4.00	
12/10/2022	2,450.00	0.00	932.00	0.00	1,518.00	1,521.00	0.00	3.00	-1.00	
12/11/2022	1,521.00	6,501.00	650.00	0.00	7,372.00	7,376.00	0.00	4.00	3.00	
12/12/2022	7,376.00	0.00	887.00	0.00	6,489.00	6,501.00	0.00	12.00	15.00	
12/13/2022	6,501.00	0.00	863.00	0.00	5,638.00	5,633.00	0.00	-5.00	10.00	
12/14/2022	5,633.00	0.00	1,073.00	0.00	4,560.00	4,555.00	0.00	-5.00	5.00	
12/15/2022	4,555.00	0.00	966.00	0.00	3,589.00	3,583.00	0.00	-6.00	-1.00	
12/16/2022	3,583.00	0.00	1,099.00	0.00	2,484.00	2,477.00	0.00	-7.00	-8.00	
12/17/2022	2,477.00	0.00	831.00	0.00	1,646.00	1,644.00	0.00	-2.00	-10.00	
12/18/2022	1,644.00	6,499.00	915.00	0.00	7,228.00	7,212.00	0.00	-16.00	-26.00	
12/19/2022	7,212.00	0.00	904.00	0.00	6,308.00	6,317.00	0.00	9.00	-17.00	
12/20/2022	6,317.00	0.00	1,021.00	0.00	5,296.00	5,292.00	0.00	-4.00	-21.00	
12/21/2022	5,292.00	0.00	855.00	0.00	4,437.00	4,433.00	0.00	-4.00	-25.00	
12/22/2022	4,433.00	0.00	788.00	0.00	3,645.00	3,624.00	0.00	-21.00	-46.00	
12/23/2022	3,624.00	0.00	961.00	0.00	2,663.00	2,667.00	0.00	4.00	-42.00	
12/24/2022	2,667.00	0.00	783.00	0.00	1,884.00	1,877.00	0.00	-7.00	-49.00	
12/25/2022	1,877.00	0.00	540.00	0.00	1,337.00	1,337.00	0.00	0.00	-49.00	Verif.Sales
12/26/2022	1,337.00	6,519.00	672.00	0.00	7,184.00	7,192.00	0.00	8.00	-41.00	
12/27/2022	7,192.00	0.00	764.00	0.00	6,428.00	6,441.00	0.00	13.00	-28.00	
12/28/2022	6,441.00	0.00	631.00	0.00	5,810.00	5,811.00	0.00	1.00	-27.00	
12/29/2022	5,811.00	0.00	633.00	0.00	5,178.00	5,176.00	0.00	-2.00	-29.00	
12/30/2022	5,176.00	0.00	870.00	0.00	4,306.00	4,304.00	0.00	-2.00	-31.00	
12/31/2022	4,304.00	0.00	992.00	0.00	3,312.00	3,306.00	0.00	-6.00	-37.00	
1/1/2023	3,306.00	0.00	653.00	0.00	2,653.00	2,650.00	0.00	-3.00	-40.00	
1/2/2023	2,650.00	0.00	721.00	0.00	1,929.00	1,929.00	0.00	0.00	-40.00	Verif.Sales
1/3/2023	1,929.00	6,501.00	782.00	0.00	7,648.00	7,684.00	0.00	36.00	-4.00	
1/4/2023	7,684.00	0.00	866.00	0.00	6,818.00	6,831.00	0.00	13.00	9.00	
1/5/2023	6,831.00	0.00	960.00	0.00	5,871.00	5,864.00	0.00	-7.00	2.00	
TOTALS		26,020.00	25,100.00	0.00			0.00	2.00	2.00	

Leak Check = (25,100.00 * 0.01 + 130) = 381.0 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	381.0 gall	0.0 inches	-0.0009 gph	0.0411 gph	PASS	ND	ND
Min. Daily Sales :		540.0	Max. Daily Sales :		1099.0	Avg. Daily Sales : 836.7	

General comments :

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 01/11/2023

Effective Dates : 12/07/22 to 01/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
12/7/2022	884.00	0.00	151.00	0.00	733.00	732.00	0.00	-1.00	-1.00	
12/8/2022	732.00	0.00	106.00	0.00	626.00	626.00	0.00	0.00	-1.00	Verif.Sales
12/9/2022	626.00	0.00	134.00	0.00	492.00	492.00	0.00	0.00	-1.00	Verif.Sales
12/10/2022	492.00	0.00	115.00	0.00	377.00	377.00	0.00	0.00	-1.00	Verif.Sales
12/11/2022	377.00	2,000.00	24.00	0.00	2,353.00	2,351.00	0.00	-2.00	-3.00	
12/12/2022	2,351.00	0.00	80.00	0.00	2,271.00	2,277.00	0.00	6.00	3.00	
12/13/2022	2,277.00	0.00	140.00	0.00	2,137.00	2,138.00	0.00	1.00	4.00	
12/14/2022	2,138.00	0.00	102.00	0.00	2,036.00	2,036.00	0.00	0.00	4.00	Verif.Sales
12/15/2022	2,036.00	0.00	133.00	0.00	1,903.00	1,903.00	0.00	0.00	4.00	Verif.Sales
12/16/2022	1,903.00	0.00	236.00	0.00	1,667.00	1,667.00	0.00	0.00	4.00	Verif.Sales
12/17/2022	1,667.00	0.00	173.00	0.00	1,494.00	1,494.00	0.00	0.00	4.00	Verif.Sales
12/18/2022	1,494.00	1,001.00	123.00	0.00	2,372.00	2,370.00	0.00	-2.00	2.00	
12/19/2022	2,370.00	0.00	153.00	0.00	2,217.00	2,221.00	0.00	4.00	6.00	
12/20/2022	2,221.00	0.00	74.00	0.00	2,147.00	2,147.00	0.00	0.00	6.00	Verif.Sales
12/21/2022	2,147.00	0.00	90.00	0.00	2,057.00	2,055.00	0.00	-2.00	4.00	
12/22/2022	2,055.00	0.00	68.00	0.00	1,987.00	1,986.00	0.00	-1.00	3.00	
12/23/2022	1,986.00	0.00	110.00	0.00	1,876.00	1,875.00	0.00	-1.00	2.00	
12/24/2022	1,875.00	0.00	54.00	0.00	1,821.00	1,819.00	0.00	-2.00	0.00	
12/25/2022	1,819.00	0.00	81.00	0.00	1,738.00	1,737.00	0.00	-1.00	-1.00	
12/26/2022	1,737.00	0.00	75.00	0.00	1,662.00	1,661.00	0.00	-1.00	-2.00	
12/27/2022	1,661.00	0.00	118.00	0.00	1,543.00	1,541.00	0.00	-2.00	-4.00	
12/28/2022	1,541.00	0.00	81.00	0.00	1,460.00	1,459.00	0.00	-1.00	-5.00	
12/29/2022	1,459.00	0.00	145.00	0.00	1,314.00	1,314.00	0.00	0.00	-5.00	Verif.Sales
12/30/2022	1,314.00	0.00	122.00	0.00	1,192.00	1,192.00	0.00	0.00	-5.00	Verif.Sales
12/31/2022	1,192.00	0.00	100.00	0.00	1,092.00	1,091.00	0.00	-1.00	-6.00	
1/1/2023	1,091.00	0.00	154.00	0.00	937.00	938.00	0.00	1.00	-5.00	
1/2/2023	938.00	0.00	41.00	0.00	897.00	897.00	0.00	0.00	-5.00	Verif.Sales
1/3/2023	897.00	1,000.00	93.00	0.00	1,804.00	1,803.00	0.00	-1.00	-6.00	
1/4/2023	1,803.00	0.00	82.00	0.00	1,721.00	1,725.00	0.00	4.00	-2.00	
1/5/2023	1,725.00	0.00	98.00	0.00	1,627.00	1,628.00	0.00	1.00	-1.00	
TOTALS		4,001.00	3,256.00	0.00			0.00	-1.00	-1.00	

Leak Check = (3,256.00 * 0.01 + 130) = 162.6 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	162.6 gall	0.0 inches	-0.0014 gph	0.0088 gph	PASS	ND	ND
Min. Daily Sales :		24.0	Max. Daily Sales :		236.0	Avg. Daily Sales : 108.5	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496