

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: APRIL | 2023FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
7-Mar		3942	0	931	3011		3008	-3	-3
8-Mar		3008	0	970	2038		2039	1	-2
9-Mar		2039	0	916	1123		1128	5	3
10-Mar		1128	0	802	326		331	5	8
11-Mar		331	6000	1323	5008		5008	0	8
12-Mar		5008	0	1166	3842		3842	0	8
13-Mar		3842	0	877	2965		2962	-3	5
14-Mar		2962	0	878	2084		2084	0	5
15-Mar		2084	6467	942	7609		7669	60	65
16-Mar		7669	0	977	6692		6680	-12	53
17-Mar		6680	0	0	6680		6680	0	53
18-Mar		6680	0	2470	4210		4190	-20	33
19-Mar		4190	0	1094	3096		3087	-9	24
20-Mar		3087	0	1085	2002		2013	11	35
21-Mar		2013	0	900	1113		1102	-11	24
22-Mar		1102	0	775	327		331	4	28
23-Mar		331	6500	1052	5779		5780	1	29
24-Mar		5780	0	1188	4592		4587	-5	24
25-Mar		4587	0	1252	3335		3330	-5	19
26-Mar		3330	0	1194	2136		2134	-2	17
27-Mar		2134	0	1156	978		966	-12	5
28-Mar		966	2583	1103	2446		2507	61	66
29-Mar		2507	0	818	1689		1693	4	70
30-Mar		1693	0	1048	645		648	3	73
31-Mar		648	6501	989	6160		6177	17	90
1-Apr		6177	0	888	5289		5285	-4	86
2-Apr		5285	0	937	4348		4337	-11	75
3-Apr		4337	0	1057	3280		3276	-4	71
4-Apr		3276	0	1055	2221		2229	8	79
5-Apr		2229	0	797	1432		1436	4	83

TOTAL SALES: 30640TOTAL OVER/SHORT: 83LEAK TEST: 436.4WATER CHECK (INCHES): 0PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: APRIL | 2023

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
7-Mar		1132	0	176	956		956	0	0
8-Mar		956	0	107	849		850	1	1
9-Mar		850	0	122	728		728	0	1
10-Mar		728	0	94	634		634	0	1
11-Mar		634	1000	175	1459		1459	0	1
12-Mar		1459	0	114	1345		1346	1	2
13-Mar		1346	0	154	1192		1193	1	3
14-Mar		1193	0	50	1143		1143	0	3
15-Mar		1143	700	107	1736		1733	-3	0
16-Mar		1733	0	135	1598		1600	2	2
17-Mar		1600	0	0	1600		1600	0	2
18-Mar		1600	0	295	1305		1305	0	2
19-Mar		1305	0	123	1182		1182	0	2
20-Mar		1182	0	100	1082		1082	0	2
21-Mar		1082	0	132	950		949	-1	1
22-Mar		949	0	132	817		817	0	1
23-Mar		817	700	101	1416		1420	4	5
24-Mar		1420	0	129	1291		1292	1	6
25-Mar		1292	0	112	1180		1180	0	6
26-Mar		1180	0	197	983		983	0	6
27-Mar		983	0	80	903		903	0	6
28-Mar		903	0	161	742		741	-1	5
29-Mar		741	0	139	602		603	1	6
30-Mar		603	0	186	417		417	0	6
31-Mar		417	2000	130	2287		2299	12	18
1-Apr		2299	0	167	2132		2134	2	20
2-Apr		2134	0	127	2007		2007	0	20
3-Apr		2007	0	143	1864		1866	2	22
4-Apr		1866	0	134	1732		1733	1	23
5-Apr		1733	0	182	1551		1553	2	25

TOTAL SALES: 4004

TOTAL OVER/SHORT: 25

LEAK TEST: 170.04

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.