

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner

MONTH/YEAR: NOVEMBER 2024

FACILITY ID #: 67397

TANK SIZE: 8000

FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
27-Oct		3141	0	1089	2052		2047	-5	-5
28-Oct		2047	0	862	1185		1188	3	-2
29-Oct		1188	6501	898	6791		6817	26	24
30-Oct		6817	0	981	5836		5826	-10	14
31-Oct		5826	0	1043	4783		4776	-7	7
1-Nov		4776	0	882	3894		3885	-9	-2
2-Nov		3885	0	692	3193		3185	-8	-10
3-Nov		3185	0	777	2408		2400	-8	-18
4-Nov		2400	0	0	2400		2400	0	-18
5-Nov		2400	0	1770	630		633	3	-15
6-Nov		633	7000	953	6680		6704	24	9
7-Nov		6704	0	884	5820		5850	30	39
8-Nov		5850	0	998	4852		4823	-29	10
9-Nov		4823	0	962	3861		3849	-12	-2
10-Nov		3849	0	930	2919		2910	-9	-11
11-Nov		2910	0	820	2090		2086	-4	-15
12-Nov		2086	0	901	1185		1188	3	-12
13-Nov		1188	0	858	330		332	2	-10
14-Nov		332	6950	545	6737		6757	20	10
15-Nov		6757	0	854	5903		5899	-4	6
16-Nov		5899	0	908	4991		4984	-7	-1
17-Nov		4984	0	833	4151		4143	-8	-9
18-Nov		4143	0	770	3373		3364	-9	-18
19-Nov		3364	0	790	2574		2567	-7	-25
20-Nov		2567	0	828	1739		1736	-3	-28
21-Nov		1736	0	784	952		953	1	-27
22-Nov		953	6700	959	6694		6723	29	2
23-Nov		6723	0	925	5798		5794	-4	-2
24-Nov		5794	0	876	4918		4912	-6	-8
25-Nov		4912	0	945	3967		3962	-5	-13

TOTAL SALES: 26317

TOTAL OVER/SHORT: -13

LEAK TEST: 393.17

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**

**FUEL INVENTORY CONTROL REPORT**

FACILITY NAME: Kool Corner MONTH/YEAR: NOVEMBER 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
27-Oct		1118	0	204	914		915	1	1
28-Oct		915	0	145	770		769	-1	0
29-Oct		769	1000	176	1593		1591	-2	-2
30-Oct		1591	0	112	1479		1478	-1	-3
31-Oct		1478	0	122	1356		1355	-1	-4
1-Nov		1355	0	159	1196		1196	0	-4
2-Nov		1196	0	159	1037		1037	0	-4
3-Nov		1037	0	123	914		913	-1	-5
4-Nov		913	0	0	913		913	0	-5
5-Nov		913	0	316	597		612	15	10
6-Nov		612	950	126	1436		1439	3	13
7-Nov		1439	0	127	1312		1312	0	13
8-Nov		1312	0	139	1173		1177	4	17
9-Nov		1177	0	152	1025		1025	0	17
10-Nov		1025	0	111	914		917	3	20
11-Nov		917	0	123	794		793	-1	19
12-Nov		793	0	147	646		646	0	19
13-Nov		646	0	98	548		547	-1	18
14-Nov		547	1500	121	1926		1927	1	19
15-Nov		1927	0	91	1836		1837	1	20
16-Nov		1837	0	106	1731		1730	-1	19
17-Nov		1730	0	111	1619		1619	0	19
18-Nov		1619	0	132	1487		1492	5	24
19-Nov		1492	0	141	1351		1352	1	25
20-Nov		1352	0	174	1178		1177	-1	24
21-Nov		1177	0	162	1015		1014	-1	23
22-Nov		1014	700	113	1601		1603	2	25
23-Nov		1603	0	203	1400		1400	0	25
24-Nov		1400	0	148	1252		1251	-1	24
25-Nov		1251	0	109	1142		1142	0	24

TOTAL SALES: 4150 TOTAL OVER/SHORT: 24

LEAK TEST: 171.5 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.