



## LINE AND LEAK DETECTOR TEST DATA FORM

**Facility Name:** All Star Grocery 3
**Date:** 2/12/2025

**Facility Address:** 4600 Teri Rd  
Austin, TX 78744

**Facility Phone:** \_\_\_\_\_

**Test Contractor:** PETRO-TANK SOLUTIONS, LLC

**Address:** 803 Summer Park Dr, Ste #150  
Stafford, TX 77477

**Contractor Phone:** (281) 242-2687

**Tester:** Anil momin

**Method:** Hasstech ACURITE Pipeline Tester

**License #** 5373.LTN

Product	REGULAR	SUPER	DIESEL	
Pump Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Isolation Mechanism	Ball Valve	Ball Valve	Ball Valve	
Test Pressure (1 1/2 times working pressure)	50 PSI	50 PSI	50 PSI	
Initial Cylinder Level (ICL)	0.040	0.040	0.085	
Final Cylinder Level (FCL)	0.040	0.040	0.085	
Leak Volume = ICL - FCL	0.000	0.000	0.000	
Time Started	3:00	3:00	3:45	
Time Completed	3:30	3:30	4:15	
Total Test Time (30 min. minimum)	30 MINS	30 MINS	30 MINS	
Conclusion (Pass or Fail)	PASS	PASS	PASS	
Leak Detector Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Line PSI	30 PSI	28 PSI	27 PSI	
Leak Detector Result (Pass or Fail)	PASS	PASS	PASS	

**Comments:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_