

## **APPENDIX C-3**

	SPILL BU	CKET INTEGRITY GLE- AND DOUBL	TESTING HYDR E-WALLED VACU	OSTATIC TEST N	METHOD OD	
Facility Name: Big Bucket			Owner: Gogo Lakeline, Incorporated			
Address: 2219 S Lakeline Blvd			Address: 608 Baldovino Skwy			
City, State, Zip Code: Cedar Park, TX 78613			City, State, Zip Code: Lakeway, TX 78738			
Facility I.D. #: 87986			Phone #:			
Testing Company: Petro-Tank Solutions			Phone #: Date: 9/11/2024			
This procedure is to method, Section 6.3	test the leak integ 3 for single-walled v	rity of single- and do acuum test method	ouble-walled spill b d and Section 6.4 fo	uckets. See PEI/RP or double-walled va	1200 Section 6.2 to cuum test method.	for hydrostatic test
Tank Number	1A	1B	1C			
Product Stored	Regular	Super	Diesel			
Spill Bucket Capacity	3.5 gallons	3.5 gallons	3.5 gallons			
Manufacturer	EMCO	EMCO	EMCO			
Construction	☑ Single-walled ☐ Double-walled	☑ Single-walled ☐ Double-walled	☑ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled	☐ Single-walled ☐ Double-walled
Test Type		☑ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☑ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled	☐ Hydrostatic ☐ Vacuum ☐ Single-walled ☐ Double-walled
Spill Bucket Type	☑ Product □ Vapor	☑ Product □ Vapor	☑ Product □ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor	☐ Product ☐ Vapor
Liquid and debris removed from spill bucket?*	☑ Yes □ No	☑ Yes □ No	☑ Yes ☐ No	□ Yes □ No	□ Yes □ No	□ Yes □ No
Visual Inspection (No cracks, loose parts or separa- tion of the bucket from the fill pipe.)	☑ Pass ☐ Fail	☑ Pass ☐ Fail	☑ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail
Tank riser cap included in test?	☑ Yes ☐ No ☐ NA	☑ Yes ☐ No ☐ NA	☑ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No
Drain valve included in test?	☐ Yes ☑ No ☐ NA	☐ Yes ☑ No ☐ NA	☐ Yes ☑ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA	☐ Yes ☐ No ☐ NA
Starting Level	13 inch	13 inch	13 inch			
Test Start Time	2:00 PM	2:00 PM	2:00 PM			a comment of the
Ending Level	13 inch	13 inch	13 inch			and the state of t
Test End Time	3:00 PM	3:00 PM	3:00 PM			
Test Period	1 hr		1 hr	at year		
Level Change	0	1 hr 0	0			
		spection. Hydrostati		of less than 1/8 in	ch; Vacuum single-	walled only:
Maintain at least 2	26 inches water col	umn; Vacuum doub	le-walled: maintain	at least 12 inches	water column.	
Test Results	☑ Pass ☐ Fail	☑ Pass ☐ Fail	☑ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Comments:						
*All liquids and deb Tester's Name (p			Teste	er's Signature	D. Cul	