

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner

MONTH/YEAR: MARCH 2024

FACILITY ID #: 67397

TANK SIZE: 8000

FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
1-Mar		4322	0	844	3478		3471	-7	-7
2-Mar		3471	0	896	2575		2570	-5	-12
3-Mar		2570	0	958	1612		1613	1	-11
4-Mar		1613	0	696	917		920	3	-8
5-Mar		920	6000	855	6065		6082	17	9
6-Mar		6082	0	664	5418		5410	-8	1
7-Mar		5410	0	622	4788		4786	-2	-1
8-Mar		4786	0	1009	3777		3772	-5	-6
9-Mar		3772	0	838	2934		2928	-6	-12
10-Mar		2928	0	852	2076		2073	-3	-15
11-Mar		2073	0	711	1362		1365	3	-12
12-Mar		1365	6501	851	7015		7041	26	14
13-Mar		7041	0	748	6293		6282	-11	3
14-Mar		6282	0	674	5608		5602	-6	-3
15-Mar		5602	0	664	4938		4933	-5	-8
16-Mar		4933	0	703	4230		4228	-2	-10
17-Mar		4228	0	815	3413		3407	-6	-16
18-Mar		3407	0	767	2640		2635	-5	-21
19-Mar		2635	0	1001	1634		1636	2	-19
20-Mar		1636	0	1057	579		583	4	-15
21-Mar		583	6501	819	6265		6267	2	-13
22-Mar		6267	0	1030	5237		5232	-5	-18
23-Mar		5232	0	850	4382		4380	-2	-20
24-Mar		4380	0	875	3505		3500	-5	-25
25-Mar		3500	0	907	2593		2588	-5	-30
26-Mar		2588	0	894	1694		1695	1	-29
27-Mar		1695	0	1041	654		656	2	-27
28-Mar		656	6501	1180	5977		5984	7	-20
29-Mar		5984	0	900	5084		5087	3	-17
30-Mar		5087	0	885	4202		4198	-4	-21

TOTAL SALES: 25606

TOTAL OVER/SHORT: -21

LEAK TEST: 386.06

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: MARCH 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
1-Mar		1307	0	106	1201		1201	0	0
2-Mar		1201	0	140	1061		1061	0	0
3-Mar		1061	0	141	920		919	-1	-1
4-Mar		919	0	77	842		842	0	-1
5-Mar		842	1000	105	1737		1734	-3	-4
6-Mar		1734	0	59	1675		1673	-2	-6
7-Mar		1673	0	68	1605		1605	0	-6
8-Mar		1605	0	135	1470		1471	1	-5
9-Mar		1471	0	114	1357		1357	0	-5
10-Mar		1357	0	109	1248		1248	0	-5
11-Mar		1248	0	120	1128		1128	0	-5
12-Mar		1128	520	120	1528		1528	0	-5
13-Mar		1528	0	146	1382		1383	1	-4
14-Mar		1383	0	97	1286		1287	1	-3
15-Mar		1287	0	125	1162		1162	0	-3
16-Mar		1162	0	123	1039		1039	0	-3
17-Mar		1039	0	212	827		827	0	-3
18-Mar		827	0	97	730		729	-1	-4
19-Mar		729	0	98	631		630	-1	-5
20-Mar		630	0	92	538		537	-1	-6
21-Mar		537	1500	97	1940		1943	3	-3
22-Mar		1943	0	172	1771		1773	2	-1
23-Mar		1773	0	111	1662		1663	1	0
24-Mar		1663	0	189	1474		1475	1	1
25-Mar		1475	0	128	1347		1347	0	1
26-Mar		1347	0	152	1195		1195	0	1
27-Mar		1195	0	119	1076		1075	-1	0
28-Mar		1075	1000	171	1904		1907	3	3
29-Mar		1907	0	118	1789		1793	4	7
30-Mar		1793	0	96	1697		1695	-2	5

TOTAL SALES: 3637 TOTAL OVER/SHORT: 5

LEAK TEST: 166.37 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.