

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX 78723

Owner ID:
Facility ID: 67397
Tank : 01
Product : REGULAR

Date generated 06/03/2024

Effective Dates : 04/30/24 to 05/29/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
4/30/2024	6,562.00	0.00	1,090.00	0.00	5,472.00	5,463.00	0.00	-9.00	-9.00	
5/1/2024	5,463.00	0.00	997.00	0.00	4,466.00	4,463.00	0.00	-3.00	-12.00	
5/2/2024	4,463.00	0.00	924.00	0.00	3,539.00	3,535.00	0.00	-4.00	-16.00	
5/3/2024	3,535.00	0.00	1,147.00	0.00	2,388.00	2,383.00	0.00	-5.00	-21.00	
5/4/2024	2,383.00	0.00	1,106.00	0.00	1,277.00	1,291.00	0.00	14.00	-7.00	
5/5/2024	1,291.00	0.00	954.00	0.00	337.00	332.00	0.00	-5.00	-12.00	
5/6/2024	332.00	6,503.00	918.00	0.00	5,917.00	5,922.00	0.00	5.00	-7.00	
5/7/2024	5,922.00	0.00	937.00	0.00	4,985.00	4,981.00	0.00	-4.00	-11.00	
5/8/2024	4,981.00	0.00	1,176.00	0.00	3,805.00	3,802.00	0.00	-3.00	-14.00	
5/9/2024	3,802.00	0.00	1,134.00	0.00	2,668.00	2,663.00	0.00	-5.00	-19.00	
5/10/2024	2,663.00	0.00	1,117.00	0.00	1,546.00	1,537.00	0.00	-9.00	-28.00	
5/11/2024	1,537.00	0.00	924.00	0.00	613.00	631.00	0.00	18.00	-10.00	
5/12/2024	631.00	6,202.00	315.00	0.00	6,518.00	6,530.00	0.00	12.00	2.00	
5/13/2024	6,530.00	0.00	908.00	0.00	5,622.00	5,620.00	0.00	-2.00	0.00	
5/14/2024	5,620.00	0.00	908.00	0.00	4,712.00	4,711.00	0.00	-1.00	-1.00	
5/15/2024	4,711.00	0.00	968.00	0.00	3,743.00	3,741.00	0.00	-2.00	-3.00	
5/16/2024	3,741.00	0.00	995.00	0.00	2,746.00	2,742.00	0.00	-4.00	-7.00	
5/17/2024	2,742.00	0.00	1,285.00	0.00	1,457.00	1,462.00	0.00	5.00	-2.00	
5/18/2024	1,462.00	0.00	1,012.00	0.00	450.00	454.00	0.00	4.00	2.00	
5/19/2024	454.00	6,300.00	1,060.00	0.00	5,694.00	5,699.00	0.00	5.00	7.00	
5/20/2024	5,699.00	0.00	968.00	0.00	4,731.00	4,734.00	0.00	3.00	10.00	
5/21/2024	4,734.00	0.00	886.00	0.00	3,848.00	3,841.00	0.00	-7.00	3.00	
5/22/2024	3,841.00	0.00	1,015.00	0.00	2,826.00	2,822.00	0.00	-4.00	-1.00	
5/23/2024	2,822.00	0.00	933.00	0.00	1,889.00	1,891.00	0.00	2.00	1.00	
5/24/2024	1,891.00	0.00	1,095.00	0.00	796.00	805.00	0.00	9.00	10.00	
5/25/2024	805.00	6,504.00	845.00	0.00	6,464.00	6,477.00	0.00	13.00	23.00	
5/26/2024	6,477.00	0.00	827.00	0.00	5,650.00	5,645.00	0.00	-5.00	18.00	
5/27/2024	5,645.00	0.00	820.00	0.00	4,825.00	4,820.00	0.00	-5.00	13.00	
5/28/2024	4,820.00	0.00	762.00	0.00	4,058.00	4,045.00	0.00	-13.00	0.00	
5/29/2024	4,045.00	0.00	885.00	0.00	3,160.00	3,154.00	0.00	-6.00	-6.00	
TOTALS		25,509.00	28,911.00	0.00			0.00	-6.00	-6.00	

Leak Check = (28,911.00 * 0.01 + 130) = 419.1 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	419.1 gall	0.0 inches	0.0039 gph	0.0272 gph	PASS	PASS	PASS
Min. Daily Sales :		315.0	Max. Daily Sales :		1285.0	Avg. Daily Sales : 963.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX 78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 06/03/2024

Effective Dates : 04/30/24 to 05/29/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
4/30/2024	2,041.00	0.00	114.00	0.00	1,927.00	1,928.00	0.00	1.00	1.00	
5/1/2024	1,928.00	0.00	125.00	0.00	1,803.00	1,803.00	0.00	0.00	1.00	Verif.Sales
5/2/2024	1,803.00	0.00	149.00	0.00	1,654.00	1,655.00	0.00	1.00	2.00	
5/3/2024	1,655.00	0.00	150.00	0.00	1,505.00	1,506.00	0.00	1.00	3.00	
5/4/2024	1,506.00	0.00	126.00	0.00	1,380.00	1,380.00	0.00	0.00	3.00	Verif.Sales
5/5/2024	1,380.00	0.00	100.00	0.00	1,280.00	1,281.00	0.00	1.00	4.00	
5/6/2024	1,281.00	500.00	135.00	0.00	1,646.00	1,645.00	0.00	-1.00	3.00	
5/7/2024	1,645.00	0.00	102.00	0.00	1,543.00	1,545.00	0.00	2.00	5.00	
5/8/2024	1,545.00	0.00	150.00	0.00	1,395.00	1,395.00	0.00	0.00	5.00	Verif.Sales
5/9/2024	1,395.00	0.00	79.00	0.00	1,316.00	1,318.00	0.00	2.00	7.00	
5/10/2024	1,318.00	0.00	157.00	0.00	1,161.00	1,161.00	0.00	0.00	7.00	Verif.Sales
5/11/2024	1,161.00	0.00	192.00	0.00	969.00	969.00	0.00	0.00	7.00	Verif.Sales
5/12/2024	969.00	500.00	41.00	0.00	1,428.00	1,426.00	0.00	-2.00	5.00	
5/13/2024	1,426.00	0.00	152.00	0.00	1,274.00	1,276.00	0.00	2.00	7.00	
5/14/2024	1,276.00	0.00	151.00	0.00	1,125.00	1,126.00	0.00	1.00	8.00	
5/15/2024	1,126.00	0.00	113.00	0.00	1,013.00	1,014.00	0.00	1.00	9.00	
5/16/2024	1,014.00	0.00	168.00	0.00	846.00	853.00	0.00	7.00	16.00	
5/17/2024	853.00	0.00	130.00	0.00	723.00	716.00	0.00	-7.00	9.00	
5/18/2024	716.00	0.00	146.00	0.00	570.00	571.00	0.00	1.00	10.00	
5/19/2024	571.00	1,000.00	130.00	0.00	1,441.00	1,443.00	0.00	2.00	12.00	
5/20/2024	1,443.00	0.00	111.00	0.00	1,332.00	1,333.00	0.00	1.00	13.00	
5/21/2024	1,333.00	0.00	137.00	0.00	1,196.00	1,198.00	0.00	2.00	15.00	
5/22/2024	1,198.00	0.00	109.00	0.00	1,089.00	1,090.00	0.00	1.00	16.00	
5/23/2024	1,090.00	0.00	131.00	0.00	959.00	959.00	0.00	0.00	16.00	Verif.Sales
5/24/2024	959.00	0.00	136.00	0.00	823.00	828.00	0.00	5.00	21.00	
5/25/2024	828.00	1,006.00	83.00	0.00	1,751.00	1,745.00	0.00	-6.00	15.00	
5/26/2024	1,745.00	0.00	184.00	0.00	1,561.00	1,562.00	0.00	1.00	16.00	
5/27/2024	1,562.00	0.00	68.00	0.00	1,494.00	1,494.00	0.00	0.00	16.00	Verif.Sales
5/28/2024	1,494.00	0.00	114.00	0.00	1,380.00	1,381.00	0.00	1.00	17.00	
5/29/2024	1,381.00	0.00	85.00	0.00	1,296.00	1,305.00	0.00	9.00	26.00	
TOTALS		3,006.00	3,768.00	0.00			0.00	26.00	26.00	

Leak Check = (3,768.00 * 0.01 + 130) = 167.7 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago	
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result	
0.1000	167.7 gall	0.0 inches	0.0070 gph	0.0080 gph	PASS	PASS	PASS	
Min. Daily Sales :		41.0	Max. Daily Sales :		192.0	Avg. Daily Sales :		125.6

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496