APPENDIX C-7

AUTOMATIC TANK GAUGE
OPERATION INSPECTION

Facility Name: Big Bucket	Owner: Gogo Lakeline, Incorporated		
Address: 2219 S Lakeline Blvd	Address: 608 Baldovino Skwy		
City, State, Zip Code: Cedar Park, TX 78613	City, State, Zip Code: Lakeway, TX 78738		
Facility I.D. #: 87986	Phone #:		
Testing Company: Petro-Tank Solutions	Phone #:		Date: 9/11/2024

This procedure is to determine whether the automatic tank guage (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number	1A	1B	1C	
Product Stored	Regular	Super	Diesel	
ATG Brand and Model	TLS-450 Plus	TLS-450 Plus	TLS-450 Plus	
1. Tank Volume, gallons	20000	6000	6000	
2. Tank Diameter, inches	126"	126"	126"	
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No
4. Float moves freely on the stem without binding?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No
5. Fuel float level agrees with the value programmed into the console?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No
6. Water float level agrees with the value programmed into the console?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No
7. Inch level from bottom of stem when 90% alarm is triggered.	104 7/8	104 7/8	104 7/8	
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No
9. Inch level from the bottom when the water float first triggers an alarm.	.25	.25	.25	
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	☑ Yes ☐ No	☑ Yes ☐ No	☑ Yes ☐ No	☐ Yes ☐ No

If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.

Test Results	☑ Pass ☐ Fail	☑ Pass ☐ Fail	☑ Pass ☐ Fail	☐ Pass ☐ Fail

Comments:

Tester's Name (print) __Dustin Cuevas__   Tester's Signature __D. Cuev__