

MONTHLY INSPECTION REPORT

AMTS

803 SUMMER PARK DR, STE #150

STAFFORD, TX 77477

O: 281-242-2687

E: OFFICE.PETROTANKSOLUTIONS@GMAIL.COM



Facility Name: TEXAS TRUCK PLAZA

Facility Address: 5303 N Mccarty St, Houston, TX 77013

TCEQ Facility ID: 71725

Technician: Ali Momin

Time: 07:42 AM

Date Inspected: 05/08/2025

NOT APPLICABLE

REQUIRES IMMEDIATE ATTENTION

CHECKED AND OKAY

COMMENTS

1. Hanging hardware leaking?

✓

2. Hanging hardware free of cracks and holes?

✓

3. Octane stickers on?



×

4. Ethanol sticker on?



×

5. No Smoking/Stop Engine stickers on?



×

6. TDLR Weights & Measurements stickers on?

✓

7. Any sign of leaks under the dispensers?

✓

8. Any liquid or debris under dispenser sumps?

✓

9. Are Spill buckets free of liquid or debris?

✓

10. Spill buckets interior & exterior damaged or cracked?

✓

11. Grey Fill Cap in working condition?

✓

12. Fill Adapter threaded tight and not loose?

✓

13. Orange Vapor cap in working condition?			✓	
14. Vapor adapter in working condition?			✓	
15. STP Sumps free of liquid and debris?			✓	
16. STP Sumps free of holes and cracks?			✓	
17. Are all the lids properly painted?			✓	
18. Are the vent caps in good condition?			✓	

GENERAL COMMENTS: No stickers except TDLR informed him