

ANNUAL
Stage I Vapor Recovery Test
July 13, 2024

Foodies Corner 5
1405 W Whitestone Blvd
Cedar Park, TX 78613
0

Performed By:



803 Summer Park Dr, Ste # 150
Stafford, TX 77477
Ph: 281.242.2687
Fx: 281.494.4336
Email: Office.AMTS@gmail.com

Vapor Recovery Test Result Cover Sheet

(NOTICE: Submit Test Results to the appropriate TCEQ regional office, and local program with jurisdiction, within 10 working days of test completion. See reverse side for addresses.)

Tests of the Vapor Recovery System are to be conducted at the following location:

Facility Name: Foodies Corner 5 Facility ID Number: 55347
 Facility Address: 1405 W Whitestone Blvd
 Facility City: Cedar Park State: TX Zip Code: 78613
 Facility Phone: _____
 Owner Name: Amirali Maknojia Phone Number: _____

Vapor Recovery System Installed:

System	UST or AST	Type of System ¹	Executive Order or Certification Number	Test Purpose ²
Stage I	UST	Two-point	N/A	C/A

¹ Coaxial or Two-point for Stage I, Balance or Assist for Stage II.

² Test Purposes are: CI = Initial Compliance, CA = Annual Compliance, CM = After Major Modification, or 3Y = Three Year

The Following Tests were Conducted at the Facility:

Number	Test Procedure Name	Date Tested	Name of Person(s) Conducting Test	Pass or Fail
TP-201.3	Pressure/Vacuum Vent Test	7/13/2024	Anil Momin	Pass
TP-201.1E	Pressure Decay	7/13/2024	Anil Momin	Pass

The tester arrived on-site at 2:00 PM and departed at 4:30 PM

There are a total of 3 pages containing test results attached to this cover sheet.

I certify that the above tests, the results of which are attached to this cover sheet, were conducted in accordance with the test procedures as outlined in the Vapor Recovery Test Procedures Handbook, and that the results submitted here are true and correct to the best of my knowledge.

Signature of Test Contractor Responsible Party: AM Date: 7/13/2024

Test Company Name: Petro Tank Solution Phone Number: 281-242-2687

Form 201.3
Pressure/Vacuum (P/V) Vent Valve Data Sheet

Test Date: 7/13/2024
Page 1 of 2

Facility Name: Foodies Corner 5

Facility ID Number: 55347

P/V Valve Manufacturer: OPW		Model Number: 623 V		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH): 0.05		Manufacturers Specified Negative Leak Rate (CFH): 0.21			
Measured Positive Leak Rate (CFH): 0.03		Measured Negative Leak Rate (CFH): 0.18			
Positive Cracking Pressure (in. H2O) 2.94		Negative Cracking Pressure (in. H2O) 7.56			

P/V Valve Manufacturer: OPW		Model Number: 623 V		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH): 0.05		Manufacturers Specified Positive Leak Rate (CFH): 0.21			
Measured Positive Leak Rate (CFH): 0.04		Measured Negative Leak Rate (CFH): 0.19			
Positive Cracking Pressure (in. H2O) 3.02		Negative Cracking Pressure (in. H2O) 8.31			

P/V Valve Manufacturer:		Model Number:		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH):		Manufacturers Specified Positive Leak Rate (CFH):			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O) _____			

SITE INFORMATION		FACILITY PARAMETERS			
GDF NAME AND ADDRESS NAME Foodies Corner 5	GDF REPRESENTATIVE Amirali Maknojia	PHASE II SYSTEM TYPE (CIRCLE ONE) BALANCE HIRT RED JACKET HASSTECH HEALY OTHER MANIFOLDED? Y OR (N)			
ADDRESS 1405 W Whitestone Blvd Cedar Park, TX 78613	GDF PHONE NO. 0				
PERMIT CONDITIONS:	GDF FACILITY ID: 55347				
OPERATING PARAMETERS					
Numbers of Nozzles Served by Tank #1	8	Numbers of Nozzles Served by Tank #3			
Numbers of Nozzles Served by Tank #2	8	Numbers of Nozzles Served by Tank #4			
APPLICATION REGULATIONS:		VN RECOMMENDED:			
TANK #:	1	2	3	4	TOTAL
1 Product Grade	Regular	Super			
2 Actual Tank Size	8000	8000			
3 Gasoline Volume	4928	2052			
4 Ullage, Gallons (#2-#3)	3072	5948			
5 Initial Pressure, inches H2O	2.00	2.00			
6 Pressure after 1 minute, inches H2O	1.99	1.99			
7 Pressure after 2 minute, inches H2O	1.98	1.98			
8 Pressure after 3 minute, inches H2O	1.97	1.97			
9 Pressure after 4 minute, inches H2O	1.96	1.96			
10 Final Pressure after 5 minute, inches H2O	1.95	1.95			
11 Allowable Final Pressure	1.68	1.83			
Test Conducted by: Anil Momin	Test Company: Petro Tank Solution		Date of Test: 7/13/2024		
COMMENTS:					