

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: MAY | 2023FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
6-Apr		1436	0	998	438		442	4	4
7-Apr		442	6501	961	5982		5992	10	14
8-Apr		5992	0	895	5097		5097	0	14
9-Apr		5097	0	841	4256		4262	6	20
10-Apr		4262	0	725	3537		3532	-5	15
11-Apr		3532	0	989	2543		2538	-5	10
12-Apr		2538	0	1052	1486		1488	2	12
13-Apr		1488	3502	1014	3976		3974	-2	10
14-Apr		3974	0	1079	2895		2889	-6	4
15-Apr		2889	0	1096	1793		1795	2	6
16-Apr		1795	0	1017	778		783	5	11
17-Apr		783	6000	958	5825		5840	15	26
18-Apr		5840	0	1092	4748		4746	-2	24
19-Apr		4746	0	1194	3552		3543	-9	15
20-Apr		3543	0	1278	2265		2269	4	19
21-Apr		2269	0	1051	1218		1223	5	24
22-Apr		1223	0	896	327		332	5	29
23-Apr		332	6901	886	6347		6358	11	40
24-Apr		6358	0	908	5450		5447	-3	37
25-Apr		5447	0	986	4461		4460	-1	36
26-Apr		4460	0	822	3638		3635	-3	33
27-Apr		3635	0	1077	2558		2554	-4	29
28-Apr		2554	0	1016	1538		1543	5	34
29-Apr		1543	6000	893	6650		6675	25	59
30-Apr		6675	0	828	5847		5841	-6	53
1-May		5841	0	1058	4783		4779	-4	49
2-May		4779	0	1074	3705		3702	-3	46
3-May		3702	0	831	2871		2862	-9	37
4-May		2862	0	1000	1862		1870	8	45
5-May		1870	0	1123	747		756	9	54

TOTAL SALES: 29638TOTAL OVER/SHORT: 54LEAK TEST: 426.38WATER CHECK (INCHES): 0PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: MAY | 2023

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
6-Apr		1553	0	128	1425		1425	0	0
7-Apr		1425	0	167	1258		1257	-1	-1
8-Apr		1257	0	112	1145		1145	0	-1
9-Apr		1145	0	125	1020		1020	0	-1
10-Apr		1020	0	101	919		918	-1	-2
11-Apr		918	0	184	734		733	-1	-3
12-Apr		733	0	131	602		602	0	-3
13-Apr		602	2000	116	2486		2494	8	5
14-Apr		2494	0	131	2363		2361	-2	3
15-Apr		2361	0	151	2210		2211	1	4
16-Apr		2211	0	155	2056		2056	0	4
17-Apr		2056	0	120	1936		1936	0	4
18-Apr		1936	0	104	1832		1832	0	4
19-Apr		1832	0	126	1706		1707	1	5
20-Apr		1707	0	167	1540		1541	1	6
21-Apr		1541	0	173	1368		1369	1	7
22-Apr		1369	0	164	1205		1204	-1	6
23-Apr		1204	0	117	1087		1087	0	6
24-Apr		1087	0	178	909		908	-1	5
25-Apr		908	0	98	810		809	-1	4
26-Apr		809	0	125	684		685	1	5
27-Apr		685	0	89	596		596	0	5
28-Apr		596	0	172	424		424	0	5
29-Apr		424	1500	108	1816		1816	0	5
30-Apr		1816	0	119	1697		1699	2	7
1-May		1699	0	140	1559		1561	2	9
2-May		1561	0	65	1496		1496	0	9
3-May		1496	0	137	1359		1361	2	11
4-May		1361	0	124	1237		1237	0	11
5-May		1237	0	148	1089		1091	2	13

TOTAL SALES: 3975

TOTAL OVER/SHORT: 13

LEAK TEST: 169.75

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**