

TEST REPORT OF AUXILIARY CABLE

(Core Phase Out & Insulation Test - DLP)

Cable Type	Pilot cable		
Route	Route C		
Applied Voltage	1 kV		
Date of Test	08/02/2017		
Span No.	Fgh	Cable No.	Ggg
Cable Length (km)	893.00	Date of Test	08/02/2017

Test Result

1) Each conductor against the rest and earth - 1kV for 1 min

Pair No.	Core No.	Color Code	Color Code	Remarks	Insul. Resis. (Mohm)	Pair No.	Core No.	Color Code	Color Code	Remarks	Insul. Resis. (Mohm)
1	1	Pink	GreenO	OK	1500.00	6	11	Green	Green	Not OK	1000.00
	2	M246	T138	Not OK	1000.00		12	Brown	Brown	OK	1000.00
2	3	W66	Cc09	OK	2000.00	7	13	Red	Red	OK	2000.00
	4	Blue	Blue	Not OK	1500.00		14	Yellow	Yellow	Not OK	500.00
3	5	Violet	Violet	Not OK	1500.00	8	15	Green	Green	OK	2000.00
	6	Black	Black	OK	1000.00		16	Brown	Brown	Not OK	3.00
4	7	Green	Green	Not OK	0.00	9	17	Red	Red	Not OK	1500.00
	8	Brown	Brown	U	1500.00		18	Yellow	Yellow	Not OK	1500.00
5	9	Red	Red	Gj	1000.00	10	19	Blue	Blue	Not OK	1500.00
	10	Yellow	Yellow	OK	1000.00		20	White	White	U	1500.00

Remarks	Foo
---------	-----

Test Instrument

Fluke 115 (s/n: 17971512)

Calibration Date

02/03/2017

Tested By Professional Engineer	Witnessed & Reported By IEPL	Witnessed By LS Cable & System
Vincent Ting (PE)	Nora	James
08/02/2017	08/02/2017	08/02/2017
		