

US Patent & Trademark Office

Patent Public Search | Text View

United States Patent	12410938
Kind Code	B2
Date of Patent	September 09, 2025
Inventor(s)	Atchison; Shaun B. et al.

Damper control systems and methods for a zoning system

Abstract

The present disclosure relates to a heating, ventilation, and/or air conditioning (HVAC) system that includes a controller configured to receive a call for conditioning from each zone of a plurality of zones, where each zone of the plurality of zones includes a damper. The controller is also configured to determine a priority level of each zone of the plurality of zones and to control operation of the HVAC system to sequentially open the dampers of the plurality of zones based on the priority levels of the plurality of zones.

Inventors: Atchison; Shaun B. (Wichita, KS), Grajeda-Trevizo; Noel A. (Newton, KS)

Applicant: Johnson Controls Technology Company (Auburn Hills, MI)

Family ID: 72336195

Assignee: TYCO FIRE & SECURITY GMBH (Neuhausen am Rheinfall, CH)

Appl. No.: 16/359827

Filed: March 20, 2019

Prior Publication Data

Document Identifier	Publication Date
US 20200284463 A1	Sep. 10, 2020

Related U.S. Application Data

us-provisional-application US 62815913 20190308

Publication Classification

Int. Cl.: F24F11/79 (20180101); F24F110/10 (20180101)

U.S. Cl.:

CPC **F24F11/79** (20180101); F24F2110/10 (20180101)

Field of Classification Search

CPC: F24F (11/74); F24F (11/755)

References Cited

U.S. PATENT DOCUMENTS

Patent No.	Issued Date	Patentee Name	U.S. Cl.	CPC
7156316	12/2006	Kates	N/A	N/A
7320362	12/2007	Nichols	165/205	G05D 23/1934
7558648	12/2008	Hoglund et al.	N/A	N/A
2003/0171901	12/2002	Salsbury	703/2	G06F 17/12
2007/0045431	12/2006	Chapman	236/46C	F24F 11/30
2017/0023269	12/2016	Gevelber	N/A	F24F 11/62
2017/0299218	12/2016	Kojima	N/A	F24F 11/76

Primary Examiner: Atkisson; Jianying C

Assistant Examiner: Shaikh; Meraj A

Attorney, Agent or Firm: Fletcher Yoder, PC

Background/Summary

CROSS-REFERENCE TO RELATED APPLICATIONS (1) This application claims priority from and the benefit of U.S. Provisional Application Ser. No. 62/815,913, entitled “DAMPER CONTROL SYSTEMS AND METHODS FOR A ZONING SYSTEM,” filed Mar. 8, 2019, which is herein incorporated by reference in its entirety for all purposes.

BACKGROUND

(1) This section is intended to introduce the reader to various aspects of art that may be related to various aspects of the present techniques, which are described and/or claimed below. This discussion is believed to be helpful in providing the reader with background information to facilitate a better understanding of the various aspects of the present disclosure. Accordingly, it should be understood that these statements are to be read in this light and not as an admission of any kind.

(2) A heating, ventilation, and/or air conditioning (HVAC) system may be used to control certain environmental conditions, such as temperature, within a building, home, or other structure. A zoned HVAC system generally includes dampers disposed within ductwork of an air distribution system of a building. The dampers cooperate to regulate air flow within the ductwork and redirect air to specific areas or zones of the building based on a cooling demand of the zones. Accordingly, the dampers facilitate the designation of customized temperature zones throughout the building. That is, the zoned HVAC system may deliver suitably conditioned air to particular zones of the building in order to adequately meet and/or approach a demand for conditioned air in these zones. In many cases, a zone controller or other control unit is used to control and operate the dampers of the

HVAC system. Unfortunately, conventional zone controllers are typically inadequate to operate zoned HVAC systems having a relatively large quantity of dampers.

SUMMARY

(3) The present disclosure relates to a heating, ventilation, and/or air conditioning (HVAC) system that includes a controller configured to receive a call for conditioning from each zone of a plurality of zones, where each zone of the plurality of zones includes a damper. The controller is configured to determine a priority level of each zone of the plurality of zones and to control operation of the HVAC system to sequentially open the dampers of the plurality of zones based on the priority levels of the plurality of zones.

(4) The present disclosure also relates to a zoning system for a heating, ventilation, and/or air conditioning (HVAC) system having a plurality of zones, where the zoning system includes a controller configured to receive a first call for conditioning from a first zone that includes a first damper and to receive a second call for conditioning from a second zone that includes a second damper. The controller is also configured to determine a priority level of the first zone and a priority level of the second zone and to control operation of the HVAC system to sequentially actuate the first damper and the second damper based on the priority levels of the first zone and the second zone.

(5) The present disclosure also relates to a control system for a zoned heating, ventilation, and/or air conditioning (HVAC) system including a plurality of zones. The control system includes a controller configured to receive a call for conditioning from two zones of the plurality of zones, where each zone of the two zones includes a damper set. The controller is also configured to determine a priority level of each zone of the two zones and to control operation of the zoned HVAC system to sequentially open the damper sets of the two zones based on the priority levels of the two zones.

Description

BRIEF DESCRIPTION OF THE DRAWINGS

(1) Various aspects of this disclosure may be better understood upon reading the following detailed description and upon reference to the drawings in which:

(2) FIG. 1 is a perspective view of an embodiment of a building that may utilize a heating, ventilation, and/or air conditioning (HVAC) system in a commercial setting, in accordance with an aspect of the present disclosure;

(3) FIG. 2 is a perspective view of an embodiment of a packaged HVAC unit of the HVAC system of FIG. 1, in accordance with an aspect of the present disclosure;

(4) FIG. 3 is a perspective view of an embodiment of a split, residential HVAC system, in accordance with an aspect of the present disclosure;

(5) FIG. 4 is a schematic diagram of an embodiment of a vapor compression system that may be used in an HVAC system, in accordance with an aspect of the present disclosure;

(6) FIG. 5 is a block diagram of an embodiment of a control system that may be used to control a zoned HVAC system, in accordance with an aspect of the present disclosure;

(7) FIG. 6 is a schematic diagram of an embodiment of a building having HVAC equipment that may be controlled by a control system, in accordance with an aspect of the present disclosure;

(8) FIG. 7 is a flow diagram of an embodiment of a process for generating a zoning database for a control system, in accordance with an aspect of the present disclosure;

(9) FIG. 8 is a flow diagram of an embodiment of a process for operating a zoned HVAC system using a control system, in accordance with an aspect of the present disclosure;

(10) FIG. 9 is a flow diagram of an embodiment of additional steps that may be included in the process of FIG. 8, in accordance with an aspect of the present disclosure;

(11) FIG. 10 is an illustration of an embodiment of a first screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure;

(12) FIG. 11 is an illustration of an embodiment of a second screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure;

(13) FIG. 12 is an illustration of an embodiment of a third screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure;

(14) FIG. 13 is an illustration of an embodiment of a fourth screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure;

(15) FIG. 14 is an illustration of an embodiment of a fifth screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure;

(16) FIG. 15 is an illustration of an embodiment of a sixth screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system, in accordance with an aspect of the present disclosure; and

(17) FIG. 16 is an illustration of an embodiment of a seventh screen of a graphical user interface that may be used to facilitate generation of a zoning database for a control system of an HVAC system, in accordance with an aspect of the present disclosure.

DETAILED DESCRIPTION

(18) One or more specific embodiments of the present disclosure will be described below. These described embodiments are only examples of the presently disclosed techniques. Additionally, in an effort to provide a concise description of these embodiments, all features of an actual implementation may not be described in the specification. It should be appreciated that in the development of any such actual implementation, as in any engineering or design project, numerous implementation-specific decisions must be made to achieve the developers' specific goals, such as compliance with system-related and business-related constraints, which may vary from one implementation to another. Moreover, it should be appreciated that such a development effort might be complex and time consuming, but would nevertheless be a routine undertaking of design, fabrication, and manufacture for those of ordinary skill having the benefit of this disclosure.

(19) When introducing elements of various embodiments of the present disclosure, the articles “a,” “an,” and “the” are intended to mean that there are one or more of the elements. The terms “comprising,” “including,” and “having” are intended to be inclusive and mean that there may be additional elements other than the listed elements. Additionally, it should be understood that references to “one embodiment” or “an embodiment” of the present disclosure are not intended to be interpreted as excluding the existence of additional embodiments that also incorporate the recited features.

(20) As noted above, certain HVAC systems may include zoned HVAC systems configured to concurrently regulate separate climate conditions within a plurality of separate spaces or rooms of a building or other structure. These previously-designated spaces or rooms may form zones of the zoned HVAC system. Zoned HVAC systems often utilize a control system to control the operation of various air conditioning devices and/or equipment that enables the independent adjustment of climate parameters within each of the zones. For example, the control system may include a zone controller that is configured to adjust devices of the HVAC system to regulate and/or maintain an air temperature within each zone at a desired setting or within a desired range. Accordingly, the zone controller enables the individual management of climate parameters within the zones.

(21) Zoned HVAC systems generally include a plurality of ducts forming an air distribution system throughout the building. The ducts may include return air ducts and supply air ducts that extend

between and fluidly couple air conditioning components of the HVAC system, such as an evaporator and/or a furnace, to the zones of the building. For example, each of the zones may be associated with one or more return air ducts and one or more supply air ducts that enable the HVAC system to receive air from and supply air to a particular zone. Respective dampers may be positioned within each of the return air and/or supply air ducts of the zones and may be configured to regulate a flow rate of return air being drawn from and a flow rate of supply air being directed into the zones. In particular, the dampers may be electrically and/or communicatively coupled to the zone controller, such that the zone controller may operate the dampers to adjust respective positions of the dampers. Accordingly, the zone controller may facilitate distribution of conditioned air amongst zones of the building that may be calling for heating or cooling.

(22) Typical zone controllers generally include a damper support limit that is indicative of a maximum quantity of dampers the zone controller may operate at a particular instance in time. Indeed, hardware and/or software limitations of conventional zone controllers may render the zone controllers inadequate to control an HVAC system having a quantity of dampers that exceeds the damper support limit of the zone controller. Therefore, conventional zone controllers are typically limited for use in HVAC systems that include a total quantity of dampers that is equal to, or less than, the damper support limit of the zone controller. Accordingly, in many cases, multiple zone controllers are implemented to control HVAC systems that include more dampers than permitted by the damper support limit of an individual zone controller. Unfortunately, implementing multiple zone controllers in an HVAC system may complicate assembly and installation of the HVAC system, as well as increase operational and/or maintenance costs associated with the HVAC system.

(23) It is now recognized that enabling an individual zone controller to effectively operate an HVAC system that includes a quantity of dampers that exceeds a quantity of dampers allotted by the traditional damper support limit of the zone controller may reduce manufacturing, assembly, and/or maintenance costs associated with the HVAC system. Accordingly, embodiments of the present disclosure are directed to a control system that, via implementation of a zoning algorithm, may control an HVAC system that includes more dampers than allotted by the damper support limit of the zone controller.

(24) For example, in accordance with present embodiments, the zone controller may be communicatively coupled and/or electrically coupled to a plurality of damper sets of the HVAC system, where each damper set is associated with a particular room or zone of a building. Each of the damper sets may include a total quantity of individual dampers that is equal to, or less than, the damper support limit of the zone controller. The zoning algorithm enables the zone controller to sequentially control the dampers sets based on certain zone parameters when multiple zones send a call for heating or cooling at once. For example, in embodiments where a first zone, a second zone, and a third zone simultaneously send a call for heating or cooling to the zone controller, the zone controller may sequentially control a damper set of the first zone, a damper set of the second zone, and a damper set of the third zone, where each of the dampers sets includes a quantity of individual dampers that is equal to, or less than, the damper support limit of the zone controller. Indeed, by enabling the zone controller to sequentially control the individual damper sets, the zoning algorithm may ensure that the zone controller does not, at a particular instance in time, operate a total quantity of dampers that exceeds the damper support limit of the zone controller. That is, the zoning algorithm may ensure that the zone controller does not operate two or more damper sets simultaneously if a cumulative quantity of individual dampers included in the two or more damper sets exceeds the damper support limit of the zone controller. In this manner, the control system of the present disclosure may enable an individual zone controller to operate an HVAC system that may include more dampers than allotted by the damper support limit of the zone controller. These and other features will be described below with reference to the drawings.

(25) Turning now to the drawings, FIG. 1 illustrates an embodiment of a heating, ventilation, and/or air conditioning (HVAC) system for environmental management that may employ one or

more HVAC units. As used herein, an HVAC system includes any number of components configured to enable regulation of parameters related to climate characteristics, such as temperature, humidity, air flow, pressure, air quality, and so forth. For example, an “HVAC system” as used herein is defined as conventionally understood and as further described herein. Components or parts of an “HVAC system” may include, but are not limited to, all, some of, or individual parts such as a heat exchanger, a heater, an air flow control device, such as a fan, a sensor configured to detect a climate characteristic or operating parameter, a filter, a control device configured to regulate operation of an HVAC system component, a component configured to enable regulation of climate characteristics, or a combination thereof. An “HVAC system” is a system configured to provide such functions as heating, cooling, ventilation, dehumidification, pressurization, refrigeration, filtration, or any combination thereof. The embodiments described herein may be utilized in a variety of applications to control climate characteristics, such as residential, commercial, industrial, transportation, or other applications where climate control is desired.

(26) In the illustrated embodiment, a building **10** is air conditioned by a system that includes an HVAC unit **12**. The building **10** may be a commercial structure or a residential structure. As shown, the HVAC unit **12** is disposed on the roof of the building **10**; however, the HVAC unit **12** may be located in other equipment rooms or areas adjacent the building **10**. The HVAC unit **12** may be a single package unit containing other equipment, such as a blower, integrated air handler, and/or auxiliary heating unit. In other embodiments, the HVAC unit **12** may be part of a split HVAC system, such as the system shown in FIG. 3, which includes an outdoor HVAC unit **58** and an indoor HVAC unit **56**.

(27) The HVAC unit **12** is an air cooled device that implements a refrigeration cycle to provide conditioned air to the building **10**. Specifically, the HVAC unit **12** may include one or more heat exchangers across which an air flow is passed to condition the air flow before the air flow is supplied to the building. In the illustrated embodiment, the HVAC unit **12** is a rooftop unit (RTU) that conditions a supply air stream, such as environmental air and/or a return air flow from the building **10**. After the HVAC unit **12** conditions the air, the air is supplied to the building **10** via ductwork **14** extending throughout the building **10** from the HVAC unit **12**. For example, the ductwork **14** may extend to various individual floors or other sections of the building **10**. In certain embodiments, the HVAC unit **12** may be a heat pump that provides both heating and cooling to the building with one refrigeration circuit configured to operate in different modes. In other embodiments, the HVAC unit **12** may include one or more refrigeration circuits for cooling an air stream and a furnace for heating the air stream.

(28) A control device **16**, one type of which may be a thermostat, may be used to designate the temperature of the conditioned air. The control device **16** also may be used to control the flow of air through the ductwork **14**. For example, the control device **16** may be used to regulate operation of one or more components of the HVAC unit **12** or other components, such as dampers and fans, within the building **10** that may control flow of air through and/or from the ductwork **14**. In some embodiments, other devices may be included in the system, such as pressure and/or temperature transducers or switches that sense the temperatures and pressures of the supply air, return air, and so forth. Moreover, the control device **16** may include computer systems that are integrated with or separate from other building control or monitoring systems, and even systems that are remote from the building **10**.

(29) FIG. 2 is a perspective view of an embodiment of the HVAC unit **12**. In the illustrated embodiment, the HVAC unit **12** is a single package unit that may include one or more independent refrigeration circuits and components that are tested, charged, wired, piped, and ready for installation. The HVAC unit **12** may provide a variety of heating and/or cooling functions, such as cooling only, heating only, cooling with electric heat, cooling with dehumidification, cooling with gas heat, or cooling with a heat pump. As described above, the HVAC unit **12** may directly cool and/or heat an air stream provided to the building **10** to condition a space in the building **10**.

(30) As shown in the illustrated embodiment of FIG. 2, a cabinet **24** encloses the HVAC unit **12** and provides structural support and protection to the internal components from environmental and other contaminants. In some embodiments, the cabinet **24** may be constructed of galvanized steel and insulated with aluminum foil faced insulation. Rails **26** may be joined to the bottom perimeter of the cabinet **24** and provide a foundation for the HVAC unit **12**. In certain embodiments, the rails **26** may provide access for a forklift and/or overhead rigging to facilitate installation and/or removal of the HVAC unit **12**. In some embodiments, the rails **26** may fit into “curbs” on the roof to enable the HVAC unit **12** to provide air to the ductwork **14** from the bottom of the HVAC unit **12** while blocking elements such as rain from leaking into the building **10**.

(31) The HVAC unit **12** includes heat exchangers **28** and **30** in fluid communication with one or more refrigeration circuits. Tubes within the heat exchangers **28** and **30** may circulate refrigerant, such as R-**410A**, through the heat exchangers **28** and **30**. The tubes may be of various types, such as multichannel tubes, conventional copper or aluminum tubing, and so forth. Together, the heat exchangers **28** and **30** may implement a thermal cycle in which the refrigerant undergoes phase changes and/or temperature changes as it flows through the heat exchangers **28** and **30** to produce heated and/or cooled air. For example, the heat exchanger **28** may function as a condenser where heat is released from the refrigerant to ambient air, and the heat exchanger **30** may function as an evaporator where the refrigerant absorbs heat to cool an air stream. In other embodiments, the HVAC unit **12** may operate in a heat pump mode where the roles of the heat exchangers **28** and **30** may be reversed. That is, the heat exchanger **28** may function as an evaporator and the heat exchanger **30** may function as a condenser. In further embodiments, the HVAC unit **12** may include a furnace for heating the air stream that is supplied to the building **10**. While the illustrated embodiment of FIG. 2 shows the HVAC unit **12** having two of the heat exchangers **28** and **30**, in other embodiments, the HVAC unit **12** may include one heat exchanger or more than two heat exchangers.

(32) The heat exchanger **30** is located within a compartment **31** that separates the heat exchanger **30** from the heat exchanger **28**. Fans **32** draw air from the environment through the heat exchanger **28**. Air may be heated and/or cooled as the air flows through the heat exchanger **28** before being released back to the environment surrounding the rooftop unit **12**. A blower assembly **34**, powered by a motor **36**, draws air through the heat exchanger **30** to heat or cool the air. The heated or cooled air may be directed to the building **10** by the ductwork **14**, which may be connected to the HVAC unit **12**. Before flowing through the heat exchanger **30**, the conditioned air flows through one or more filters **38** that may remove particulates and contaminants from the air. In certain embodiments, the filters **38** may be disposed on the air intake side of the heat exchanger **30** to prevent contaminants from contacting the heat exchanger **30**.

(33) The HVAC unit **12** also may include other equipment for implementing the thermal cycle. Compressors **42** increase the pressure and temperature of the refrigerant before the refrigerant enters the heat exchanger **28**. The compressors **42** may be any suitable type of compressors, such as scroll compressors, rotary compressors, screw compressors, or reciprocating compressors. In some embodiments, the compressors **42** may include a pair of hermetic direct drive compressors arranged in a dual stage configuration **44**. However, in other embodiments, any number of the compressors **42** may be provided to achieve various stages of heating and/or cooling. As may be appreciated, additional equipment and devices may be included in the HVAC unit **12**, such as a solid-core filter drier, a drain pan, a disconnect switch, an economizer, pressure switches, phase monitors, and humidity sensors, among other things.

(34) The HVAC unit **12** may receive power through a terminal block **46**. For example, a high voltage power source may be connected to the terminal block **46** to power the equipment. The operation of the HVAC unit **12** may be governed or regulated by a control board **48**. The control board **48** may include control circuitry connected to a thermostat, sensors, and alarms. One or more of these components may be referred to herein separately or collectively as the control device **16**.

The control circuitry may be configured to control operation of the equipment, provide alarms, and monitor safety switches. Wiring **49** may connect the control board **48** and the terminal block **46** to the equipment of the HVAC unit **12**.

(35) FIG. **3** illustrates a residential heating and cooling system **50**, also in accordance with present techniques. The residential heating and cooling system **50** may provide heated and cooled air to a residential structure, as well as provide outside air for ventilation and provide improved indoor air quality (IAQ) through devices such as ultraviolet lights and air filters. In the illustrated embodiment, the residential heating and cooling system **50** is a split HVAC system. In general, a residence **52** conditioned by a split HVAC system may include refrigerant conduits **54** that operatively couple the indoor unit **56** to the outdoor unit **58**. The indoor unit **56** may be positioned in a utility room, an attic, a basement, and so forth. The outdoor unit **58** is typically situated adjacent to a side of residence **52** and is covered by a shroud to protect the system components and to prevent leaves and other debris or contaminants from entering the unit. The refrigerant conduits **54** transfer refrigerant between the indoor unit **56** and the outdoor unit **58**, typically transferring primarily liquid refrigerant in one direction and primarily vaporized refrigerant in an opposite direction.

(36) When the system shown in FIG. **3** is operating as an air conditioner, a heat exchanger **60** in the outdoor unit **58** serves as a condenser for re-condensing vaporized refrigerant flowing from the indoor unit **56** to the outdoor unit **58** via one of the refrigerant conduits **54**. In these applications, a heat exchanger **62** of the indoor unit functions as an evaporator. Specifically, the heat exchanger **62** receives liquid refrigerant, which may be expanded by an expansion device, and evaporates the refrigerant before returning it to the outdoor unit **58**.

(37) The outdoor unit **58** draws environmental air through the heat exchanger **60** using a fan **64** and expels the air above the outdoor unit **58**. When operating as an air conditioner, the air is heated by the heat exchanger **60** within the outdoor unit **58** and exits the unit at a temperature higher than it entered. The indoor unit **56** includes a blower or fan **66** that directs air through or across the indoor heat exchanger **62**, where the air is cooled when the system is operating in air conditioning mode. Thereafter, the air is passed through ductwork **68** that directs the air to the residence **52**. The overall system operates to maintain a desired temperature as set by a system controller. When the temperature sensed inside the residence **52** is higher than the set point on the thermostat, or a set point plus a small amount, the residential heating and cooling system **50** may become operative to refrigerate additional air for circulation through the residence **52**. When the temperature reaches the set point, or a set point minus a small amount, the residential heating and cooling system **50** may stop the refrigeration cycle temporarily.

(38) The residential heating and cooling system **50** may also operate as a heat pump. When operating as a heat pump, the roles of heat exchangers **60** and **62** are reversed. That is, the heat exchanger **60** of the outdoor unit **58** will serve as an evaporator to evaporate refrigerant and thereby cool air entering the outdoor unit **58** as the air passes over outdoor the heat exchanger **60**. The indoor heat exchanger **62** will receive a stream of air blown over it and will heat the air by condensing the refrigerant.

(39) In some embodiments, the indoor unit **56** may include a furnace system **70**. For example, the indoor unit **56** may include the furnace system **70** when the residential heating and cooling system **50** is not configured to operate as a heat pump. The furnace system **70** may include a burner assembly and heat exchanger, among other components, inside the indoor unit **56**. Fuel is provided to the burner assembly of the furnace **70** where it is mixed with air and combusted to form combustion products. The combustion products may pass through tubes or piping in a heat exchanger, separate from heat exchanger **62**, such that air directed by the blower **66** passes over the tubes or pipes and extracts heat from the combustion products. The heated air may then be routed from the furnace system **70** to the ductwork **68** for heating the residence **52**.

(40) FIG. **4** is an embodiment of a vapor compression system **72** that can be used in any of the

systems described above. The vapor compression system **72** may circulate a refrigerant through a circuit starting with a compressor **74**. The circuit may also include a condenser **76**, an expansion valve(s) or device(s) **78**, and an evaporator **80**. The vapor compression system **72** may further include a control panel **82** that has an analog to digital (A/D) converter **84**, a microprocessor **86**, a non-volatile memory **88**, and/or an interface board **90**. The control panel **82** and its components may function to regulate operation of the vapor compression system **72** based on feedback from an operator, from sensors of the vapor compression system **72** that detect operating conditions, and so forth.

(41) In some embodiments, the vapor compression system **72** may use one or more of a variable speed drive (VSDs) **92**, a motor **94**, the compressor **74**, the condenser **76**, the expansion valve or device **78**, and/or the evaporator **80**. The motor **94** may drive the compressor **74** and may be powered by the variable speed drive (VSD) **92**. The VSD **92** receives alternating current (AC) power having a particular fixed line voltage and fixed line frequency from an AC power source, and provides power having a variable voltage and frequency to the motor **94**. In other embodiments, the motor **94** may be powered directly from an AC or direct current (DC) power source. The motor **94** may include any type of electric motor that can be powered by a VSD or directly from an AC or DC power source, such as a switched reluctance motor, an induction motor, an electronically commutated permanent magnet motor, or another suitable motor.

(42) The compressor **74** compresses a refrigerant vapor and delivers the vapor to the condenser **76** through a discharge passage. In some embodiments, the compressor **74** may be a centrifugal compressor. The refrigerant vapor delivered by the compressor **74** to the condenser **76** may transfer heat to a fluid passing across the condenser **76**, such as ambient or environmental air **96**. The refrigerant vapor may condense to a refrigerant liquid in the condenser **76** as a result of thermal heat transfer with the environmental air **96**. The liquid refrigerant from the condenser **76** may flow through the expansion device **78** to the evaporator **80**.

(43) The liquid refrigerant delivered to the evaporator **80** may absorb heat from another air stream, such as a supply air stream **98** provided to the building **10** or the residence **52**. For example, the supply air stream **98** may include ambient or environmental air, return air from a building, or a combination of the two. The liquid refrigerant in the evaporator **80** may undergo a phase change from the liquid refrigerant to a refrigerant vapor. In this manner, the evaporator **80** may reduce the temperature of the supply air stream **98** via thermal heat transfer with the refrigerant. Thereafter, the vapor refrigerant exits the evaporator **80** and returns to the compressor **74** by a suction line to complete the cycle.

(44) In some embodiments, the vapor compression system **72** may further include a reheat coil in addition to the evaporator **80**. For example, the reheat coil may be positioned downstream of the evaporator relative to the supply air stream **98** and may reheat the supply air stream **98** when the supply air stream **98** is overcooled to remove humidity from the supply air stream **98** before the supply air stream **98** is directed to the building **10** or the residence **52**.

(45) It should be appreciated that any of the features described herein may be incorporated with the HVAC unit **12**, the residential heating and cooling system **50**, or other HVAC systems.

Additionally, while the features disclosed herein are described in the context of embodiments that directly heat and cool a supply air stream provided to a building or other load, embodiments of the present disclosure may be applicable to other HVAC systems as well. For example, the features described herein may be applied to mechanical cooling systems, free cooling systems, chiller systems, or other heat pump or refrigeration applications.

(46) The description above with reference to FIGS. **1-4** is intended to be illustrative of the context of the present disclosure. Accordingly, it should be noted that the embodiments of the present disclosure may include features of the description above. As will be discussed in more detail below, embodiments of the present disclosure include a zoned HVAC system having a control system, such as the control device **16**, which may be configured to sequentially operate respective damper

sets that are associated with particular zones serviced by the zoned HVAC system. More specifically, the control system is configured to sequentially operate the damper sets based on respective priority levels of the zones and/or based on predetermined upper airflow limits associated with the zones.

(47) With the foregoing in mind, FIG. 5 is a block diagram of an embodiment of a control system **102** that may be configured to operate any of the HVAC systems of FIGS. 1-4 or any other suitable zoned HVAC system associated with the building **10** or another structure. In the illustrated embodiment, the control system **102** includes a zone controller **104**, a display device **106**, which may be an input device, and one or more control devices **108**, such as one or more thermostats, which may be configured to cooperatively control HVAC equipment **110** of an HVAC system. As discussed in detail below, in some embodiments, the HVAC equipment **110** may include one or more dampers, louvers, or other suitable flow regulation devices that are configured to control airflow into or out of particular zones of the HVAC system.

(48) The zone controller **104** includes a processor **112** and a memory device **114**. The processor **112** may be used to execute software, such as software for providing commands and/or data to the control system **102**, and so forth. Moreover, the processor **112** may include multiple microprocessors, one or more “general-purpose” microprocessors, one or more special-purpose microprocessors, and/or one or more application specific integrated circuits (ASICs), or some combination thereof. For example, upon installation of the software or other executable instructions on the processor **112**, the processor **112** may become a special purpose processor configured to improve operation of the processor **112**, operation of an HVAC system, and/or operation of the control system **102** using the techniques described herein. In some embodiments, the processor **112** may include one or more reduced instruction set (RISC) processors. The memory device **114** may include a volatile memory, such as RAM, and/or a nonvolatile memory, such as ROM. The memory device **114** may store a variety of information and may be used for various purposes. For example, the memory device **114** may store processor-executable instructions for the processor **112** to execute, such as instructions for providing commands and/or data to the control system **102** and/or to components of an HVAC system associated with the control system **102**.

(49) As described in greater detail herein, in certain embodiments, the processor **112** may generate and display a graphical user interface (GUI) on the display device **106**. The GUI enables an occupant, an installer or service technician, or another user to input commands into the control system **102** and to control operation of the control system **102**. In some embodiments, the display device **106** may be a component of the zone controller **104**, a component of one of the control devices **108**, or a control panel screen of an HVAC unit. In other embodiments, the display device **106** may be an external device communicatively coupled to the control system **102**. For example, the display device **106** may be a tablet, a mobile device, a laptop computer, a personal computer, a wearable device, and/or the like. The display device **106** may be communicatively coupled to the components of the control system **102** via various wired and/or wireless communication devices or techniques.

(50) For example, the zone controller **104**, the display device **106**, the control devices **108**, and/or certain of the HVAC equipment **110** may each have a communication component that facilitates wired or wireless communication between the zone controller **104**, the display device **106**, the control devices **108**, and/or the HVAC equipment **110** via a network. Accordingly, individual components of the control system **102** may communicate with one another via the network. The communication components may include a network interface that enables the zone controller **104**, the display device **106**, the control devices **108**, and/or the HVAC equipment **110** to communicate via various protocols such as EtherNet/IP, ControlNet, DeviceNet, or any other communication network protocol. Alternatively, the communication components may enable the zone controller **104**, the display device **106**, the control devices **108**, and/or the HVAC equipment **110** to communicate via various wireless communication protocols such as Wi-Fi, mobile

telecommunications technology, Bluetooth®, near-field communications technology, and the like. As such, the zone controller **104**, the display device **106**, the control devices **108**, and/or the HVAC equipment **110** may wirelessly communicate data between each other.

(51) FIG. **6** is a schematic of an embodiment of the building **10** serviced by the control system **102**. As shown in the illustrated embodiment, the building **10** includes a first zone **120**, a second zone **122**, a third zone **124**, and a fourth zone **126**, which are collectively referred to herein as zones **128**. In some embodiments, each of the zones **128** may be associated with a respective room or space within the building **10**. However, it should be understood that, in other embodiments, each of the zones **128** may include 1, 2, 3, 4, 5, 6, or more than 6 rooms. The control devices **108** may include a first control device **130**, a second control device **132**, a third control device **134**, and a fourth control device **136**, which are respectively positioned within and/or associated with the first zone **120**, the second zone **122**, the third zone **124**, and the fourth zone **124**. Accordingly, the control devices **108** may individually monitor climate parameters, such as temperature, within each of the zones **128**.

(52) The zones **128** are supplied with conditioned air generated by an HVAC system **138**. It should be appreciated that the HVAC system **138** may include any of the HVAC systems of FIGS. **1-4** or any other suitable HVAC system. The HVAC system **138** includes the HVAC equipment **110**, which enables the HVAC system **138** to supply conditioned air to one or more of the zones **128**. More specifically, the HVAC equipment **110** enables the HVAC system **138** to concurrently regulate climate parameters within each of the zones **128** of the building **10** via supply or other regulation of air flow to, within, and/or from the zones **128**.

(53) For example, in some embodiments, the HVAC equipment **110** may include a first damper set **140**, a second damper set **142**, a third damper set **144**, and a fourth damper set **146**, which are respectively associated with the first zone **120**, the second zone **122**, the third zone **124**, and the fourth zone **126**. The first, second, third, and fourth damper sets **140**, **142**, **144**, and **146** may be fluidly coupled to the HVAC system **138** via an air distribution system, such as a system of ductwork, which enables the damper sets **140**, **142**, **144**, **146** to control a flow rate of conditioned air supplied to the zones **128** and a flow rate of return air drawn from the zones **128** via the HVAC system **138**. Indeed, it should be understood that the first damper set **140**, the second damper set **142**, the third damper set **144**, and the fourth damper set **146** may each include one or more supply air dampers and/or one or more return air dampers. For conciseness, the first damper set **140**, the second damper set **142**, the third damper set **144**, and the fourth damper set **146** may be collectively or individually referred to herein as damper sets **150**.

(54) As noted above, the zone controller **104** may be communicatively coupled to the control devices **108** to enable the zone controller **104** to monitor and/or regulate a temperature, humidity, and/or other climate parameter within each of the zones **128** based on feedback received from the control devices **108**. For example, the zone controller **104** may be configured to adjust a flow rate of conditioned air that is supplied to the zones **128** via the HVAC system **138** based on temperature measurements acquired by the control devices **108**. In some embodiments, an occupant or resident of the building **10** may input a desired target temperature setpoint of the first zone **120** using, for example, the first control device **130**. The first control device **130** may determine whether a current or measured temperature within the first zone **120** is within a threshold range of the target temperature setpoint of the first zone **120**. If the current temperature within the first zone **120** deviates from the target temperature setpoint of the first zone **120** by a threshold amount, the first control device **130** may send a call for heating or cooling to the zone controller **104**. In response, that the zone controller **104** may adjust a position the first damper set **140** to increase or decrease a flow rate of conditioned air supplied to the first zone **120** via the HVAC system **138**.

(55) For example, in embodiments where the HVAC system **138** is operating in a cooling mode and the current temperature within the first zone **120** exceeds the target temperature setpoint of the first zone **120** by the threshold amount, the first control device **130** may send a call for cooling to the

zone controller **104**. In response, the zone controller **104** may instruct the first damper set **140** to transition to an open position, or to a partially open position, thereby increasing a flow rate of conditioned air or cooled air that is supplied to the first zone **120** via the HVAC system **138**. Accordingly, the HVAC system **138** may gradually reduce the current temperature within the first zone **120**, such that the current temperature may approach the target temperature setpoint of the first zone **120**. In accordance with the techniques described herein, the zone controller **104** may similarly control operation of the second, third, and fourth damper sets **142**, **144**, and **146** to regulate air flow conditioned by the HVAC system **138** and supplied to the second, third, and fourth zones **122**, **124** and **126**. In this manner, the zone controller **104** may ensure that a current temperature within each of the zones **128** remains within a threshold range of respective target temperature setpoints of the zones **128**.

(56) As noted above, the zone controller **104** generally or traditionally includes a damper support limit that is indicative of a particular quantity of dampers that the zone controller **104** may simultaneously operate at a given instance in time. For example, the zone controller **104** may include internal hardware or software limitations that enable the zone controller **104** to output an electrical current or a control signal that is suitable to simultaneously operate, for example, twenty dampers or less at a particular time. Accordingly, as used herein, the “damper support limit” of the zone controller **104** is indicative of a maximum quantity of dampers the zone controller **104** may effectively operate simultaneously or concurrently.

(57) In some embodiments, when multiple zones **128** of the building **10** concurrently send a call for heating or cooling to the zone controller **104**, a cumulative quantity of dampers associated with these zones **128** may exceed the damper support limit of the zone controller **104**. For example, if the control devices **108** of the first and second zones **120** and **122** concurrently send a call for cooling to the zone controller **104**, where the first damper set **140** of the first zone **120** includes fifteen dampers, the second damper set **142** of the second zone **122** includes six dampers, and the damper support limit of the zone controller **104** is twenty dampers, the damper support limit of the zone controller **104** is exceeded, such that the zone controller **104** may be unable to simultaneously operate all of the dampers in the first and second damper sets **140** and **142**. Indeed, in such an example, the zone controller **104** may shut down or deactivate to prevent wear or overloading on certain electrical components of the zone controller **104**.

(58) Accordingly, embodiments of the present disclosure include a processor-executable algorithm or process, referred to herein as a zoning algorithm, which enables the zone controller **104** to sequentially operate the damper sets **150** when a request to operate a cumulative quantity of dampers at a particular time exceeds the damper support limit of the zone controller **104**. Particularly, in the present example, the zoning algorithm may enable the zone controller **104** to first operate, for example, the first damper set **140** and, upon completing actuation of the first damper set **140**, subsequently operate the second damper set **142**. Indeed, it should be understood that the first damper set **140** and the second damper set **142** each include a quantity of individual dampers that is within the damper support limit of the zone controller **104**. In this manner, the zoning algorithm may enable the zone controller **104** to control operation of an HVAC system that may include a total quantity of dampers that exceeds the damper support limit of the zone controller **104**. The zoning algorithm may be executed by the processor **112** of the zone controller **104**, the microprocessor **86** of the control panel **82**, and/or any other suitable processor or controller of the HVAC system **138**. As discussed below, the zoning algorithm may instruct the zone controller **104** to sequentially operate the damper sets **150** based on certain zone parameters associated with each of the zones **128**, such as a user selected priority level of the zones **128** and/or an upper airflow limit of the zones **128**.

(59) In some embodiments, the zone controller **104** may be configured to determine a quantity of individual dampers that are associated with each of the zones **128** by referencing a zoning database that is stored within, for example, the memory device **114** of the zone controller **104** and/or the

memory device **88** of the control panel **82**. That is, the zoning database may store and catalogue a quantity of dampers that are respectively included in the first, second, third, and fourth damper sets **140**, **142**, **144** and **146**. Additionally, the zoning database may store user-specified priority levels associated with the zones **128** and/or the upper airflow limits of the zones **128**, which enable the zone controller **104** to determine an order in which to sequentially control the individual dampers sets **150** during operation of the HVAC system **138**. Particularly, the zone controller **104** may reference the zoning database during execution of the zoning algorithm to determine an appropriate sequence by which to operate, for example, the first, second, third, and/or fourth damper sets **140**, **142**, **144** and/or **146** when the first, second, third, and/or fourth zones **120**, **122**, **124** and/or **126**, respectively, send a call for heating or cooling to the zone controller **104**.

(60) With the foregoing in mind, FIG. 7 is flow diagram of an embodiment of a process **160** that may be used to generate the zoning database. It should be appreciated that one or more of the steps discussed below may be performed during installation or initial set-up of the control system **102** and/or the HVAC system **138**. For example, as discussed below with reference to FIGS. **10-16**, a user may generate the zoning database by implementing the steps of process **160** on a GUI of the display device **106**. In other embodiments, certain of the steps may be performed after the control system **102** is installed and operating within the building **10**. For example, the control system **102** may gradually receive new and/or updated zone parameters, such as updated zone priority levels, during operation and/or after installation of the HVAC system **138**. Moreover, it should be noted that the steps of the process **160** discussed below may be performed in any suitable order and are not limited to the order shown in the illustrated embodiment of FIG. 7. In some embodiments, the process **160** may be executed on the processor **112**, the microprocessor **86**, and/or any other suitable processor of the HVAC system **138**.

(61) In the illustrated embodiment, the process **160** begins with generating a zone profile for one of the zones **128** included in the building **10**, as indicated by step **162**. For example, the GUI of the display device **106** may prompt a user, such as an occupant of the building **10** or a service technician installing the control system **102**, to generate a zone profile that is associated with, for example, the first zone **120**. The GUI subsequently prompts the user to input certain zone parameters associated with the first zone **120**, such as a quantity of dampers included in the first zone **120** and/or a desired priority level of the first zone **120**, as indicated by step **164**. For example, the GUI, via a touchscreen or another suitable input device of the display device **106**, may enable the user to specify a quantity of dampers that are included within the first damper set **140**, as well as a priority level of the first zone **120**. As discussed below, in some embodiments, the priority levels of the zones **128** may be represented by non-repeating integer values. In certain embodiments, the GUI may also prompt the user to input an upper airflow limit of the first zone **120** at the step **164**. As used herein, the “upper airflow limit” of a particular zone may be indicative of a suitable, upper flow rate of air the zone may receive from the HVAC system **138** to achieve a particular air exchange rate within that zone. In certain embodiments, the zoning algorithm may use the upper airflow limits associated with the zones **128** in addition to, or in lieu of, the priority levels of the zones **128** to determine an appropriate sequence in which to operate the damper sets **150** when a call for heating or cooling is sent to the zone controller **104** for multiple zones **128** or damper sets **150**. It should be understood that, in other embodiments, the control system **102** may be communicatively coupled to any other suitable input device, such as a keyboard, a tracking pad, a microphone, a mouse, or the like, that is configured to receive a user input from a user and enable the user to generate the zoning database.

(62) Continuing through the illustrated embodiment of the process **160**, upon receiving the zone parameters of, for example, the first zone **120**, via the GUI in the step **164**, the zone controller **104** determines whether the user-associated quantity of dampers corresponding to the first zone **120** exceeds the damper support limit of the zone controller **104**, as indicated by step **166**. For example, in some embodiments, if the user attempts to associate the first zone **120** with a quantity of

dampers that exceeds the damper support limit of the zone controller **104**, the GUI may display an error message, as indicated by step **168**. That is, the GUI may indicate that the user is attempting to associate the first damper set **140** with a quantity of dampers that exceeds a quantity of dampers that the zone controller **104** may simultaneously operate for a particular zone, such as for the first zone **120**. If the user attempts to associate the first zone **120** with a quantity of dampers that is equal to or less than the damper support limit of the zone controller **104**, the zone controller **104** may proceed to assign this user-associated quantity of dampers to the first zone **120**, as indicated by step **170**, and may store this user-selected zone parameter in the memory device **114**.

Additionally, at the step **170**, the zone controller **104** may assign the user-selected priority level to the first zone **120**. It should be noted that the damper support limit of the zone controller **104** may be stored within the memory device **114** and/or within another suitable memory device of the HVAC system **138** for reference during execution of the process **160**.

(63) Upon completion of a zone profile for a particular zone, the GUI may prompt the user to generate an additional zone profile, as indicated by the step **172**, such as, for example, a zone profile corresponding to the second zone **122**. Accordingly, based on user input, the zone controller **104** may return to the step **162**, thereby enabling the user to input zone parameters associated with the second zone **122**, such as a quantity of dampers included in the second zone **122**, a user-selected priority level of the second zone **122**, and/or an upper airflow limit associated with the second zone **122**. As such, it should be understood that the steps **162**, **164**, **166**, **170**, and **172** may be repeated iteratively for each of the zones **128** of the building **10**. Accordingly, with respect to the exemplary embodiment of the building **10** discussed herein, the zone controller **104** may store, via the memory device **114**, a respective quantity of dampers, a respective priority level, and/or a respective upper airflow limit associated with the first, second, third, and fourth zones **120**, **122**, **124**, and **126**. Upon generation of the zone profiles for each of the zones **128**, execution of the process **160** concludes, as indicated by step **174**.

(64) As noted above, in some embodiments, the priority levels of the zones **128** may include non-repeating integer values that are stored within the respective zone profiles of the zones **128**. That is, each of the zones **128** may be assigned a unique priority level that is different than a priority level of other zones **128**. Larger integer values may correspond to zones **128** having a higher priority than zones **128** associated with lower integer values. However, it should be noted that the priority levels may be generated via any other suitable numerical, alphabetic, or alphanumeric character code in other embodiments of the control system **102**. Moreover, in certain embodiments, multiple zones **128** may be associated with the same priority level.

(65) FIG. **8** is a flow diagram of an embodiment of a process **180**, also referred to herein as the zoning algorithm, which may be used to operate the control system **102**. FIG. **9** is a flow diagram that illustrates additional steps included in an embodiment of the process **180**. FIGS. **8** and **9** are discussed concurrently below. It should be noted that one or more of the steps of the process **180** may be implemented using routines or code stored in the memory device **114** and may be executed by the processor **112** of the zone controller **104**. Moreover, the steps of the process **180** may be executed in any suitable order and are not limited to the order shown in the illustrated embodiment of FIG. **8** and the order shown in the illustrated embodiment of FIG. **9**. As discussed in detail below, the illustrated embodiment of the process **180** may be used to operate the zone controller **104** and the control system **102** in a manual mode of operation, in which the zone controller **104** and the control system **102** may be configured to control operation of the damper sets **150** based on the user-selected priority levels stored within the zoning database. However, in certain embodiments, the process **180** may also be used to operate zone controller **104** and the control system **102** in an automated mode of operation, in which the zone controller **104** and control system **102** may be configured to control operation of the damper sets **150** based on the respective upper airflow limits associated with each of the zones **128**.

(66) In the illustrated embodiment, the process **180** begins with determining whether one or more

of the zones **128** are offset from a respective temperature setpoint by a threshold amount, as indicated by step **182**. For example, as noted above, an occupant or resident of the building **10** may input a desired target temperature setpoint for each of the zones **128** using the control devices **108**. The control devices **108** may determine whether current temperatures within the zones **128** are within a threshold range of respective target temperature setpoints associated with the zones **128**. If none of the zones **128** have a current temperature that is offset from a corresponding temperature setpoint by the threshold amount, such as, for example, plus or minus 0.5 degrees Fahrenheit, the zone controller **104** continues normal operation of the HVAC system **138**, as indicated by step **184**. Accordingly, the zone controller **104** may continue to monitor the current temperatures within the zones **128**, as indicated by the step **182**.

(67) If a current temperature within at least one of the zones **128** deviates from a respective target temperature setpoint by the threshold amount, the zone controller **104** stores such zone(s) **128** as having a call status, as indicated by step **186**. Additionally, as indicated by step **186**, the zone controller **104** identifies which of the zones **128** having a call status has the highest relative conditioning demand. That is, the zone controller **104** may determine respective temperature differentials between the current temperature values and the corresponding temperature setpoints for each of the zones having a call status and may identify the zone having the largest temperature differential between its current temperature value and its corresponding temperature setpoint. For clarity, as used herein, a zone having a “call status” may be indicative of a zone that sends a call for heating or cooling to the zone controller **104**. In other words, a zone having a call status may be indicative of a zone having a current temperature that is offset from a corresponding target temperature setpoint of that zone by a threshold amount. Moreover, as user herein, a “call zone” may be indicative of a zone having a call status.

(68) Continuing through the illustrated embodiment of the process **180**, in the manual mode of operation, the zone controller **104** determines the priority level of the call zone having the highest relative conditioning demand, as indicated by step **188**. That is, the zone controller **104** may reference the zoning database to determine the user-selected priority level associated with the call zone having the highest relative conditioning demand. In the automated mode of operation, at the step **188**, the zone controller **104** may reference the zoning database to determine the upper airflow limit associated with the call zone having the highest relative conditioning demand. For conciseness, a call zone having a highest relative conditioning demand amongst the remaining call zones will be referred to herein as a “primary demand zone.”

(69) In the illustrated embodiment of the process **180**, at step **190**, the zone controller **104** determines whether the building **10** includes two or more call zones at the current iteration of the process **180**. If the zone controller **104** identifies only a single call zone, the zone controller **104** instructs the dampers associated with this call zone to transition to an open position or to a partially open position, as indicated by step **192**. For example, if the first zone **120** is the only one of the zones **128** having a call status, then the zone controller **104** instructs the first damper set **140** to transition to a fully open position or to a partially open position. In this manner, the zone controller **104** may increase a flow rate of conditioned air supplied to the first zone **120** to cause the current temperature within the first zone **120** to approach the target temperature setpoint of the first zone **120**. Upon instructing the first damper set **140** to transition to the open position, the zone controller **104** may determine whether a designated delay time or a target delay time has lapsed, as indicated by step **194**. As discussed in detail below, the delay time may be between about ten seconds and about 120 seconds and may ensure that the zone controller **104** provides sufficient time for a previously actuated damper set to transition to a desired position, such as an open position or a closed position, before the zone controller **104** actuates another damper set of the HVAC system **138**. That is, in the present example, the delay time may ensure that the zone controller **104** provides a time interval that is sufficient to enable the first damper set **140** to transition to an open position before the zone controller **104** actuates other damper sets **150** of the HVAC system **138**. In

this manner, the delay time may ensure that an actuation period of a particular damper set does not overlap with an actuation period of another damper set. Accordingly, the delay time may ensure that the zone controller **104** does not attempt to simultaneously operate a quantity of dampers that exceeds the damper support limit of the zone controller **104**.

(70) If the zone controller **104** determines that the delay time has not fully lapsed, the zone controller **104** proceeds to monitor a countdown or timer associated with the delay time, as indicated by step **195**. As indicated by step **196**, upon a determination that the delay time has lapsed, the zone controller **104** determines whether a temperature setpoint within the call zone is met. That is, the zone controller **104** may determine whether an actual temperature within the call zone is within a threshold range of a target temperature setpoint of the call zone and thus determines that the call for heating or cooling in the call zone is satisfied. If the temperature setpoint of the call zone is not met, the zone controller **104** returns to the step **182**. Accordingly, in embodiments where only a single zone, such as the first zone **120**, is associated with a call status for heating or cooling, the zone controller **104** may iterate through the steps **182**, **186**, **188**, **190**, **192**, **194**, and **196** until the temperature setpoint of the call zone is met. For conciseness, each iteration of the steps the steps **182**, **186**, **188**, **190**, **192**, **194**, and **196** will be referred to herein as a single zone inspection cycle of the zone controller **104**. In some embodiments, the zone controller **104** may skip the steps **192** and **194** in a subsequent iteration of the single zone inspection cycle if the damper set associated with the call zone has already transitioned to respective open positions or respective partially open positions in a previous iteration of the single zone inspection cycle. For example, in embodiments where the call zone is the first zone **120** and the zone controller **104** has already completed a first iteration of the single zone inspection cycle, the zone controller **104** may iterate through the steps **182**, **186**, **188**, **190**, and **196** until the temperature setpoint of the first zone **120** is achieved. If the temperature setpoint within the first zone **120** is met, the zone controller **104** may close the first damper set **140**, as indicated by step **198**, and may return to the step **182**.

(71) In embodiments where two or more of the zones **128** are associated with a call status at step **190**, the zone controller **104** proceeds to step **200** and determines which of the zones **128** has the next highest conditioning demand subsequent to the primary demand zone. In other words, the zone controller **104** determines which of the zones **128** having a call status, other than the primary demand zone, includes a largest relative temperature differential between a respective target temperature setpoint of the zone and an actual temperature value within the zone. A call zone having a second highest relative conditioning demand amongst the call zones will be referred to herein as a “secondary demand zone.”

(72) In the manual mode of operation, the zone controller **104** references the zoning database to determine the user-selected priority level associated with the secondary demand zone, as indicated by step **202**. Alternatively, in the automated mode of operation, at step **202**, the zone controller **104** may reference the zoning database to determine the upper airflow limit associated with secondary demand zone. In any case, at step **204** of the process **180**, the zone controller **104** may determine whether another one of the zones **128** includes a call status. If the zone controller **104** identifies another call zone, the zone controller **104** may repeat the steps **200**, **202**, and **204**. Particularly, it should be understood that the zone controller **104** may repeat the steps **200**, **202**, and **204** for all call zones of the building **10**. In this manner, the zone controller **104** may identify the secondary demand zone, a tertiary demand zone, a quaternary demand zone, and so forth, as well as determine a respective priority level or a respective upper airflow limit associated with the secondary demand zone, the tertiary demand zone, and the quaternary demand zone.

(73) Continuing through the illustrated embodiment of the process **180**, in the manual mode of operation, the zone controller **104** determines which call zone includes a highest relative priority level amongst the currently identified call zones, as indicated by step **206**. The call zone having the highest relative priority level amongst the remaining call zones will be referred to herein as a “priority zone.” Additionally, as indicated by the step **206**, the zone controller **104** instructs the

damper set associated with the priority zone to transition to an open position or to a partially open position. Accordingly, the zone controller **104** may enable the HVAC system **138** to initiate supply of conditioned air to the call zone having the highest relative user-selected priority level before initiating the supply of conditioned air to the remaining call zones. That is, upon identification of the priority zone, the zone controller **104** may control operation of the HVAC system **138** to condition air suitable for supply to the priority zone, thereby enhancing or accelerating a rate at which the priority zone is heated or cooled. It should be understood that the priority zone may include the primary demand zone, the secondary demand zone, the tertiary demand zone, or the quaternary demand zone. In other words, the priority zone is determined based on the highest relative user-selected priority level of the call zones instead of the cooling demands or the heating demands of the call zones.

(74) After the zone controller **104** instructs the damper set of the priority zone to transition to an open position, the zone controller **104** determines whether the designated delay time has lapsed, as indicated by step **208**. If the zone controller **104** determines that the delay time has not fully lapsed, the zone controller **104** proceeds to monitor a countdown or the timer associated with the delay time, as indicated by step **209**. Upon a determination that the delay time has lapsed, the zone controller **104** identifies the call zone having a second highest relative priority level and instructs the damper set associated with this call zone to transition to an open position, as indicated by step **210**. The call zone having the second highest relative priority level amongst the remaining call zones will be referred to herein as a “secondary priority zone.” By waiting for the delay time to lapse, the zone controller **104** may ensure that the damper set associated with the priority zone is provided with a sufficient time interval to fully transition to a particular position, such as the open position, before the zone controller **104** attempts to operate the damper set associated with the secondary priority zone. Indeed, as noted above, the delay time may be indicative of a time period that enables a damper or a dampers associated with a particular zone to transition from a closed position to an open position, or vice versa. Therefore, the zoning algorithm may ensure that the zone controller **104** does not attempt to simultaneously operate damper sets of more than one of the call zones, which may cause the zone controller **104** to attempt to actuate a quantity of dampers at a particular instance in time that exceeds the damper support limit of the zone controller **104**.

(75) For example, if the damper support limit of the zone controller **104** is twenty dampers, if the priority zone includes a damper set having fifteen dampers, and if the secondary priority zone includes a damper set having six dampers, then the damper support limit of the zone controller **104** would be exceeded if the zone controller **104** attempts to concurrently operate the damper set of the secondary priority zone and the damper set of the priority zone. That is, in such an example, the damper support limit of the zone controller **104** would be exceeded if the zone controller **104** attempts to operate the damper set of the secondary priority zone before the damper set of the of the priority zone has completed transitioning from, for example, a closed position to an open position. Accordingly, by waiting for the delay time to lapse at the step **208**, the zone controller **104** may ensure that the damper set associated with the priority zone has ceased operation before attempting to operate the damper set associated with the secondary priority zone. In this manner, the zoning algorithm may enable the zone controller **104** to operate an HVAC system that includes a total quantity of dampers that may exceed the damper support limit of the zone controller **104**. Indeed, through such sequential operation of the damper sets **150**, the zoning algorithm may enable the zone controller **104** to effectively control an HVAC system that includes a plurality of zones, where each of the zones includes a damper set having a quantity of dampers that is equal to, or less than, the damper support limit of the zone controller **104**. However, it should be noted that, in some embodiments, the zone controller **104** may be configured to operate damper sets of multiple calls zones simultaneously if a cumulative quantity of dampers included in these call zones does not exceed the damper support limit of the zone controller **104**.

(76) Continuing through the illustrated embodiment of the process **180**, after the zone controller

104 instructs the damper set of the secondary priority zone to transition to an open position at the step **210**, the zone controller **104** again evaluates whether the delay time has lapsed, as indicated by step **212**. If the zone controller **104** determines that the delay time has not fully lapsed, the zone controller **104** proceeds to monitor the timer associated with the delay time, as indicated by step **213**. Upon lapse of the delay time, the zone controller **104** identifies whether additional call zones exist for which the zone controller **104** has not yet adjusted corresponding damper sets, as indicated by step **214**. If the zone controller **104** identifies another zone having a call status, the zone controller **104** may repeat the steps **210**, **212**, and **214**. Specifically, it should be understood that the zone controller **104** may repeat the steps **210**, **212**, and **214** for all of the remaining call zones, such that the zone controller **104** may sequentially open the damper sets associated with, for example, a tertiary priority zone, a quaternary priority zone, and so forth.

(77) It is important to note that, in the automated mode of operation, the zone controller **104** may identify the priority zone, the secondary priority zone, the tertiary priority zone, the quaternary priority zone, and so forth, based on the previously assigned upper airflow limits associated with the zones **128**, instead of the user-selected priority levels of the zones **128**. For example, as noted above, an operator may use the display device **106** to assign a respective upper airflow limit to each of the zones **128** during installation or initial setup of the control system **102**, which may be stored within the zoning database of the control system **102**. Accordingly, when iterating through the steps of the process **180** in the automated mode of operation, the zone controller **104** may identify the priority zone as the call zone having a highest relative upper airflow limit amongst remaining call zones of the building **10**. The zone controller **104** may identify the secondary priority zone as the call zone having the next highest relative upper airflow limit subsequent to the priority zone. The zone controller **104** may identify the tertiary priority zone as the call zone having the next highest relative upper airflow limit subsequent to the secondary priority zone, and so forth.

(78) In embodiments, where two or more call zones include the same upper airflow limit, the zone controller **104** may assign the call zone having a higher cooling or heating demand with a higher relative priority status. For example, if the first zone **120** and the second zone **122** are both associated with the same upper airflow limit, if a current temperature of the first zone **120** is offset from a respective temperature setpoint by a first differential, if a current temperature of the second zone **122** is offset from a respective temperature setpoint by a second differential, and if the first differential is greater than the second differential, then the zone controller **104** will identify the first zone **120** as, for example, the priority zone, and may identify the second zone as the secondary priority zone. In any case, the zone controller **104** may iterate through the steps of the process **180** in the manner discussed above to sequentially open respective damper sets **150** of the call zones based on the upper airflow limits of these zones **128** and the cooling or heating demands of the zones **128**. As discussed in detail below, a user may utilize the display device **106** to instruct the zone controller **104** to operate in the automated mode or the manual mode.

(79) Regardless of whether the zone controller **104** operates in the manual mode or the automated mode, at step **216**, the zone controller **104** determines whether a respective temperature setpoint of at least one call zone is met. If the temperature setpoint of no call zone is met, then zone controller **104** returns to the step **182** and proceeds to iterate through the process **180** until the HVAC system **138** sufficiently conditions at least one of the call zones to its corresponding temperature setpoint. Particularly, if the temperature setpoint of at least one call zone is met, the zone controller **104** may proceed to step **220**. For clarity, a call zone that has been conditioned to have an actual temperature that is substantially equal to the target temperature of that call zone will be referred to herein as a “conditioned zone.”

(80) As shown in the illustrated embodiment of FIG. **9**, the process **180** includes closing a damper or dampers of a conditioned zone that is associated with a lowest relative upper airflow limit, with respect to other conditioned zones, as indicated by step **220**. For example, the zone controller **104** may reference the zoning database or a cache of the memory device **114** to determine which of the

one or more conditioned zones includes a lowest relative upper airflow limit and, upon identification of the zone, may instruct the damper set associated with this zone to transition to a closed position or to a partially closed position. A conditioned zone having a lowest relative upper airflow limit of the remaining conditioned zones will be referred to herein as a “primary conditioned zone.”

(81) The process **180** further includes waiting for the delay time to lapse upon actuation of the damper set of the primary conditioned zone, as indicated by step **222**. If the zone controller **104** determines that the delay time has not fully lapsed, the zone controller **104** proceeds to monitor the timer associated with the delay time, as indicated by step **223**. Upon a determination that the delay time has lapsed, the zone controller **104** determines whether additional conditioned zones exist that have met their respective temperature setpoint, as indicated by step **224**. If the zone controller **104** does not identify another conditioned zone in the current iteration of the process **180**, then the zone controller **104** returns to the step **182**, as indicated by step **226**. Accordingly, the zone controller **104** may initiate another iteration of the process **180**. In embodiments where the zone controller **104** identifies two or more conditioned zones, the zone controller **104** proceeds to identify the conditioned zone having the next lowest upper airflow limit subsequent to the primary conditioned zone and instructs the damper set of this zone to transition to a closed position, as indicated by step **228**. In other words, the zone controller **104** determines which of the conditioned zones, other than the primary conditioned zone, includes a lowest relative upper airflow limit, and proceeds to instruct the damper set associated with this zone to transition to a closed position. A conditioned zone having a second lowest relative upper airflow limit amongst the conditioned zones will be referred to herein as a “secondary conditioned zone.”

(82) At step **230** of the process **180**, the zone controller **104** evaluates the timer associated with the delay time and may remain idle until the delay time has lapsed, as indicated by step **231**. Upon lapse of the delay time, the zone controller **104** determines whether another conditioned zone exists that has met its respective temperature setpoint. If the zone controller **104** identifies another conditioned zone, the zone controller **104** may repeat the steps **228**, **230**, and **232**. Particularly, it should be understood that the zone controller **104** may repeat the steps **228**, **230**, and **232** for all conditioned zones within the building **10**, such that the zone controller **104** may identify a tertiary conditioned zone, a quaternary conditioned zone, and so forth, as well as sequentially close respective damper sets associated with the tertiary conditioned zone, the quaternary conditioned zone, and/or any additional conditioned zones within the building **10**. That is, the zone controller **104** may sequentially close or partially close respective dampers sets associated with these conditioned zones in ascending order of the respective upper airflow limits of the conditioned zones. Upon closing the damper sets of all conditioned zones, the zone controller **104** may return to the step **182** to perform another iteration of the process **180**, as indicated by the step **234**.

(83) It should be appreciated that sequentially closing the damper sets based on the upper airflow limits associated with the conditioned zones may mitigate a likelihood of over conditioning the zones via the HVAC system **138**. For example, as noted above, the upper airflow limits of the zones **128** may be indicative of air flow rates that enable the HVAC system **138** to achieve a particular air exchange rate within the zones **128**. Accordingly, in certain embodiments, zones **128** associated with relatively small upper airflow limits may be indicative of zones **128** having a relatively small interior volume, while zones **128** associated with a relatively large upper airflow limits may be indicative of zones **128** having relatively large interior volumes. As such, zones **128** having a low upper airflow limit may be more susceptible to over conditioning than zones **128** having a high upper airflow limit. Therefore, by sequentially closing damper sets of the conditioned zones in ascending order of the upper airflow limits associated with the conditioned zones, the zone controller **104** may mitigate a likelihood of over conditioning zones **128** having relatively small interior volumes. That is, by closing damper sets associated with relatively small zones **128** before closing damper sets associated with larger zones **128**, the zone controller **104** may mitigate a

likelihood of over conditioning smaller zones **128** of the building **10**.

(84) FIG. **10** is an illustration of an embodiment of a graphical user interface (GUI) **240** that may be displayed on the display device **106** to enable a user to generate the zoning database in accordance with the steps of the process **160**. FIGS. **11-16** are illustrations of various screens that may be included in the GUI **240**, which may further facilitate generation of the zoning database. As shown in the illustrated embodiment of FIG. **10**, a first screen **242** of the GUI **240** may include a zone selection field **244** that enables a user to select and/or generate a zone profile for a particular zone **128**. For example, the user may instruct the zone controller **104**, via the GUI **240**, to generate a zone profile for the first zone **120**, which may be indicated as “Zone **01**” in the GUI **240**.

(85) As shown in FIG. **11**, the user may toggle to a second screen **246** of the GUI **240** that includes a lower airflow limit selection field **248** and an upper airflow limit selection field **250**, which enable the user to specify a lower airflow limit and an upper airflow limit of, for example, the first zone **120**. However, in other embodiments, the lower airflow limit selection field **248** and the upper airflow limit selection field **250** may auto-populate based on the type of HVAC system to which the display device **106** is coupled. The GUI **240** enables a user to specify a quantity of dampers included within a damper set of a particular zone via a third screen **254** and a fourth screen **256** of the GUI **240**, as respectively shown in FIGS. **12** and **13**. For example, the user may specify a quantity of dampers included in the first damper set **140** of the first zone **120** via a damper selection field **258**. As discussed above, in some embodiments, the GUI **240** may display an error message if the user attempts to associate the first zone **120**, or any other zone of the building **10**, with a quantity of dampers that exceeds the damper support limit of the zone controller **104**. The GUI **240** may include a fifth screen **260**, as shown in FIG. **14**, which enables the user to instruct the control system **102** to operate in the automated mode or the manual mode via a mode selection field **262**. In embodiments where the user selects the automated mode, the GUI **240** may return to the first screen **242**. Accordingly, the user may iteratively toggle through the first, second, third, fourth, and fifth screen **242**, **246**, **254**, **256**, and **260** to specify the lower airflow limit, the upper airflow limit, and the quantity of dampers associated with remaining zones **128** of the building **10**. However, in embodiments where the user selects the manual mode, shown in FIG. **14** as the “installer configured” mode of operation, the GUI **240** may proceed to display a sixth screen **270**, as shown in FIG. **15**.

(86) Specifically, via the sixth screen **270**, the user may specify a priority level associated with each of the zones **128**. For example, the user may specify a priority level of the first zone **120** via a zone priority field **272**. The user may confirm and assign the selected priority level with the first zone **120** by selecting a save selection field **274**, as shown in FIG. **16**, which is displayed on a seventh screen **276**, as shown in FIG. **16**, of the GUI **240**. As such, the user may iterate across the first through seventh screen **242**, **246**, **254**, **256**, **260**, **270**, and **276** of the GUI **240** to generate the zoning database.

(87) As set forth above, embodiments of the present disclosure may provide one or more technical effects useful for enabling an individual zone controller **104** to operate an HVAC system that includes more dampers than a quantity of dampers allotted by a damper support limit of the zone controller **104**. Indeed, the control system **102** of the present disclosure enables the zone controller **104** to sequentially control operation of various damper sets in the building **10**, such that the zone controller **104** does not, at a particular instance in time, attempt to operate a total quantity of dampers that exceeds the damper support limit of the zone controller **104**. That is, the control system **102** may ensure that the zone controller **104** does not attempt to operate two or more damper sets simultaneously if a total quantity of dampers included in the two or more damper sets exceeds the damper support limit of the zone controller **104**. Indeed, in this manner, the control system **102** may ensure that the zone controller **104** is not overloaded during operation of the HVAC system **138**. Accordingly, by enabling an individual zone controller **104** to control HVAC systems having a relatively large quantity of dampers, the present control system **102** may reduce

an installation complexity of the HVAC systems, as well as decrease operational costs and/or maintenance costs associated with the HVAC systems. The technical effects and technical problems in the specification are examples and are not limiting. It should be noted that the embodiments described in the specification may have other technical effects and can solve other technical problems.

(88) While only certain features and embodiments of the present disclosure have been illustrated and described, many modifications and changes may occur to those skilled in the art, such as variations in sizes, dimensions, structures, shapes and proportions of the various elements, values of parameters, such as temperatures and pressures, mounting arrangements, use of materials, colors, orientations, and so forth, without materially departing from the novel teachings and advantages of the subject matter recited in the claims. The order or sequence of any process or method steps may be varied or re-sequenced according to alternative embodiments. It is, therefore, to be understood that the appended claims are intended to cover all such modifications and changes as fall within the true spirit of the present disclosure. Furthermore, in an effort to provide a concise description of the exemplary embodiments, all features of an actual implementation may not have been described, such as those unrelated to the presently contemplated best mode of carrying out the present disclosure, or those unrelated to enabling the claimed embodiments. It should be appreciated that in the development of any such actual implementation, as in any engineering or design project, numerous implementation specific decisions may be made. Such a development effort might be complex and time consuming, but would nevertheless be a routine undertaking of design, fabrication, and manufacture for those of ordinary skill having the benefit of this disclosure, without undue experimentation.

Claims

1. A zoning system for a heating, ventilation, and/or air conditioning (HVAC) system having a plurality of zones, comprising: a controller having a damper support limit, wherein the controller is configured to: receive a first call for conditioning from a first zone that includes a first plurality of dampers and receive a second call for conditioning from a second zone that includes a second plurality of dampers, wherein a sum of the first plurality of dampers and the second plurality of dampers exceeds the damper support limit of the controller such that a cumulative quantity of dampers to be actuated at a particular time exceeds the damper support limit of the controller; determine a first user-selected zone priority level of the first zone and a second user-selected zone priority level of the second zone, wherein the first user-selected zone priority level and the second user-selected zone priority level indicate relative priority values of the first zone and the second zone with respect to one another; and control operation of the HVAC system to sequentially actuate the first plurality of dampers and the second plurality of dampers based on the first user-selected zone priority level of the first zone and the second user-selected zone priority level of the second zone to satisfy the first call for conditioning and the second call for conditioning and to operate a damper sum within the damper support limit of the controller.
2. The zoning system of claim 1, wherein controller is configured to: reference a zoning database to determine the first user-selected zone priority level of the first zone and the second user-selected zone priority level of the second zone, wherein the zoning database is configured to store user input indicative of the first user-selected zone priority level of the first zone and the second user-selected zone priority level of the second zone.
3. A control system for a zoned heating, ventilation, and/or air conditioning (HVAC) system including a plurality of zones, comprising: a controller having a damper support limit, wherein the controller is configured to: receive a call for conditioning from each of two zones of the plurality of zones, wherein each zone of the two zones includes a damper set, wherein a sum of dampers included in the damper sets of the two zones exceeds the damper support limit of the controller

such that a cumulative quantity of dampers to be actuated at a particular time exceeds the damper support limit of the controller; determine a user-selected zone priority level of each zone of the two zones to identify relative priority values of the two zones with respect to one another; and control operation of the zoned HVAC system to sequentially open the damper sets of the two zones based on the user-selected zone priority levels of the two zones to satisfy the call for conditioning of each of the two zones and to operate a quantity of dampers within the damper support limit of the controller.

4. The control system of claim 3, wherein, to control the operation of the zoned HVAC system to sequentially open the damper sets of the two zones based on the user-selected zone priority levels of the two zones, the controller is configured to: determine a priority zone of the two zones, the priority zone having a highest user-selected zone priority level among the two zones; instruct the damper set of the priority zone to open at a first time; determine a secondary priority zone of the two zones, the secondary priority zone having a second highest user-selected zone priority level among the two zones; and instruct the damper set of the secondary priority zone to open at a second time in response to a determination that a designated delay time has lapsed between the first time and the second time.

5. The control system of claim 4, wherein the controller is configured to transition each damper of the damper set of the priority zone from a closed position to an open position prior to lapse of the designated delay time.

6. The control system of claim 3, wherein the user-selected zone priority level of each zone of the two zones comprises a numerical value, an alphabetic value, or an alphanumeric character code.

7. The zoning system of claim 1, wherein the first-user user-selected zone priority level and the second user-selected zone priority level comprise numerical values, alphabetic values, or alphanumeric character codes.

8. The zoning system of claim 1, wherein, to control operation of the HVAC system to sequentially actuate the first plurality of dampers and the second plurality of dampers, the controller is configured to actuate the first plurality of dampers at a first time based on the first user-selected zone priority level and to actuate the second plurality of dampers at a second time based on the second user-selected zone priority level, wherein the first time and the second time are different.
