

US Patent & Trademark Office

Patent Public Search | Text View

United States Patent	12385963
Kind Code	B2
Date of Patent	August 12, 2025
Inventor(s)	Ramsey; James Raymond et al.

Monitoring system for critical electrical distribution systems

Abstract

Systems and techniques for monitoring critical electrical distribution systems in a manner that provides an early visible indication of deteriorating electrical connections in the critical electrical distribution system.

Inventors:	Ramsey; James Raymond (Gallatin, MA), Cecil; Clay Miller (Nashville, TN), O'Leary; Timothy (Antioch, TN)
Applicant:	Schneider Electric USA, Inc. (Andover, MA)
Family ID:	84425471
Assignee:	Schneider Electric USA, Inc. (Boston, MA)
Appl. No.:	18/568161
Filed (or PCT Filed):	June 07, 2022
PCT No.:	PCT/US2022/032568
PCT Pub. No.:	WO2022/261141
PCT Pub. Date:	December 15, 2022

Prior Publication Data

Document Identifier	Publication Date
US 20240288483 A1	Aug. 29, 2024

Related U.S. Application Data

us-provisional-application US 63324483 20220328
us-provisional-application US 63208324 20210608

Publication Classification

Int. Cl.: G01R31/08 (20200101); H02B1/20 (20060101); H02B1/48 (20060101)

U.S. Cl.:

CPC G01R31/086 (20130101); H02B1/202 (20130101); H02B1/48 (20130101);

Field of Classification Search

USPC: 324/126

References Cited

U.S. PATENT DOCUMENTS

Patent No.	Issued Date	Patentee Name	U.S. Cl.	CPC
2010/0237699	12/2009	Gibson et al.	N/A	N/A
2012/0013471	12/2011	Jones	340/584	G01R 31/69
2019/0103717	12/2018	Pever et al.	N/A	N/A

FOREIGN PATENT DOCUMENTS

Patent No.	Application Date	Country	CPC
203323879	12/2012	CN	N/A
107199914	12/2016	CN	N/A
2020260257	12/2019	WO	N/A

OTHER PUBLICATIONS

Caxias, Joao et al., "Transmission Line Inspection Robots: Design of the Power Supply System," 2010 1st International Conference on Applied Robotics for the Power Industry, Oct. 5, 2010, pp. 1-6. cited by applicant

Alippi, Cesare et al., "Energy Management in Wireless Sensor Networks with Energy-Hungry Sensors," IEEE Instrumentation & Measurement Magazine, vol. 12, No. 2, Apr. 1, 2009, pp. 16-23. cited by applicant

Braunovic, Milenko et al., "Shape-Memory Alloy Mechanical Contact Devices," IEEE Transactions on Components, Packaging and Manufacturing Technology—Part A, vol. 19, No. 3, Sep. 1, 1996, pp. 295-303. cited by applicant

Extended European Search Report dated Apr. 1, 2025 for corresponding European Patent Application No. 22820922.7, 15 pages. cited by applicant

International Search Report and Written Opinion for corresponding International Application No. PCT/US2022/032568 dated Oct. 26, 2022, 16 pages. cited by applicant

Primary Examiner: Hoque; Farhana A

Attorney, Agent or Firm: Troutman Pepper Locke LLP

Background/Summary

TECHNICAL FIELD

(1) The present disclosure relates to electrical distribution systems and, more particularly, to a continuous monitoring system which provides local and remote alarms when a monitored component of the electrical distribution system exceeds a predetermined value.

BACKGROUND

(2) While modern electrical systems are more reliable than ever before, any electrical connection can be degraded over time. For example, this degradation can be the result of insufficient compression at an electrical connection, corrosion, contamination of contact surfaces, water or moisture in the enclosure, and so on. Moreover, this degradation can lead to increased resistance at the affected electrical connection, and ultimately can lead to a temperature increase in equipment associated with the electrical connection (e.g., due to increased current draw, short circuit events, etc.). Insufficient compression of the electrical connection can also result from electrical joint bolts that have been loosened by material creep, mechanical shock, vibration, dynamic loading due to structure support of electrical distribution system, electrical transients, short circuit events and/or thermal cycling without proper expansion means. As a result, electrical connections are typically monitored and/or tested by technicians to ensure that the electrical connections do not degrade to unacceptable levels. In some instances, this monitoring may require that the electrical distribution system and associated equipment connected to the electrical distribution system must be shutdown to ensure the safety of the technicians. Therefore, monitoring is generally done on a yearly schedule, which could result in an unplanned shutdown of the electrical distribution system if a problem occurs between scheduled monitoring.

SUMMARY OF THE DISCLOSURE

(3) One embodiment described herein provides a monitoring system for continuously monitoring components of an electrical distribution system of the type generally found in workplaces that require more electrical power than homes or small business and where unexpected electrical power outages or damage to the electrical distribution system can significantly disrupt normal operations at the workplace. The monitoring system provides a warning of a potential power outage or damage to the electrical distribution system. The warning may be delivered in one or more of the following: a local visual/audible indicator, a visual/audible indicator at a remote monitoring station in the workplace or at any virtual location via a network, e.g., the Internet or a cellular network.

Description

BRIEF DESCRIPTION OF THE DRAWINGS

(1) A more detailed description of the disclosure, briefly summarized above, may be had by reference to various embodiments, some of which are illustrated in the appended drawings. While the appended drawings illustrate select embodiments of this disclosure, these drawings are not to be considered limiting of its scope, for the disclosure may admit to other equally effective embodiments.

(2) Identical reference numerals have been used, where possible, to designate identical elements that are common to the figures. However, elements disclosed in one embodiment may be beneficially utilized on other embodiments without specific recitation.

(3) FIG. 1 illustrates a typical electrical distribution system using a busway system, according to one embodiment described herein.

(4) FIG. 2 illustrates a typical busway system joint pack, according to one embodiment described herein.

(5) FIG. 3 illustrates a typical plug-in type tap-off device, according to one embodiment described herein.

(6) FIG. 4 illustrates a typical bolt-on type tap-off device, according to one embodiment described

herein.

(7) FIG. 5 illustrates a typical busway electrical distribution system on which a monitoring system of the present invention has been installed, according to one embodiment described herein.

(8) FIG. 6 illustrates an annotated 3D map of the electrical distribution system and nodes installed on the electrical distribution system and an associated node status chart, according to one embodiment described herein.

(9) FIG. 7 illustrates the installation of sensing devices on a busbar, according to one embodiment described herein.

(10) FIG. 8 illustrates a typical placement of sensing devices at a joint pack, according to one embodiment described herein.

(11) FIG. 9 illustrates an alternate method for determining a tight electrical connection between busbars of adjoining busway sections, according to one embodiment described herein.

(12) FIG. 10 illustrates an embodiment of the load sensor implementation of FIG. 9 according to aspects of the present disclosure.

(13) FIG. 11 illustrates a partial cutaway view of an embodiment of a load sensor implementation according to aspects of the present disclosure.

(14) FIG. 12 illustrates a perspective view of an embodiment of a load sensor coupled to a hollow cylinder according to aspects of the present disclosure.

(15) FIG. 13 illustrates a partial cutaway view of an embodiment of a load sensor embedded in a bolt shank according to aspects of the present disclosure.

(16) FIG. 14 illustrates a partial block diagram of an embodiment of a monitoring system according to aspects of the present disclosure.

DETAILED DESCRIPTION

(17) FIG. 1 illustrates components of a typical electrical distribution system **10** for workplaces requiring more electric power than homes and small business. Power from the utility provider enters the workplace through a service entrance panel **14** and is distributed throughout the workplace by a busway system **18**. The busway system **18** consist of factory assembled busway sections **22** having standard lengths such as 10, 8, 6 and 4 feet and special lengths or fittings as required for the particular electrical distribution system **10** installation. Each busway section **22** includes electrical conductors (commonly known as busbars **26**) enclosed in a busway housing **30**. Each busway section **22** is electrically connected to an adjoining busway section **22** by a joint pack **34**. The joint pack **34**, as shown in FIG. 2, includes connector plates **38**, which make the electrical connection between adjoining busway sections **22**, insulators **42**, which prevent electrical shorts between busbars **26** of different electrical phases and between the busbars **26** and the busway housing **30**, spring washers **46** (Bellville washers), which compress against the outer insulators when a joint bolt **50** extending through the spring washers **46** is tightened. The joint bolt **50** provides the means for a tight electrical connection between the busbars **26** of the adjoining busway sections **22** when it is torqued to 70+/-10 ft/lbs.

(18) Referring again to FIG. 1, busway sections **22** are generally manufactured in two types, feeder bus **54**, which has no means for tapping off electrical power and plug-in bus **58**, which has plug-in openings **62** (PIO) at intervals along its length for installing power tap-off devices **66**. Feeder bus **54** is generally used for direct connections between the service entrance panel **14** and large sub panelboards **70**, and horizontal runs where power tap-off devices **66** are not required. Plug-in bus **58** is used in areas where power is required for electrical equipment **74**, such as small panelboards, lighting panels, motors control centers and any other electrical equipment **74** that may be required in the workplace. Busway systems **18** are generally installed near the ceiling in runs that are positioned above areas of the workplace floor **78** where electrical equipment **74** is located. The electrical equipment **74** is generally located on or near the workplace floor **78** and is generally connected to power tap-off devices **66** by conduit and cable **82**.

(19) The power tap-off devices **66** are generally of three types. A joint pack **34** as shown in FIG. 2,

a plug-in unit (PIU) **86** as shown in FIG. 3 and a bolt-on tap-off unit **106**, shown in FIG. 4. A plug-in unit (PIU) **86** as shown in FIG. 3 incorporates a pair of opposed jaws **90**, which are pressed toward each other by springs **94** such that a tight electrical connection between the busbars **26** at a PIO **62** and the internal electrical conductors **98** of the plug-in unit **86** can be made. The internal electrical conductors **98** are generally connected to cable lugs **102**, which connect to the electrical cables and conduit **82** providing power to electrical equipment **74** located on or near the workplace floor **78**.

(20) A bolt-on tap-off unit **106**, shown in FIG. 4, also has opposed jaws **90**, but they are clamped together by a bolt **110** to make a tight electrical connection between the busbars **26** at a PIO **62** and the internal electrical conductors **98** of the bolt-on tap-off unit **106**. As in the plug-in unit **86**, internal electrical conductors **98** are generally connected to cable lugs **102**, which connect to the electrical cables and conduit **82** providing power to electrical equipment **74** located on or near the workplace floor **78**.

(21) Any of the electrical connections described above can degraded over time. This degradation is generally due to insufficient compression at the electrical connection, corrosion or contamination of contact surfaces, fretting or thermal expansion in over constrained systems. Any of these problems can increase resistance at the affected electrical connection, which is further exacerbated by normal cyclic heating and cooling caused by current drawn by the electrical equipment **74** connected to the electrical distribution system **10** and/or short circuit events or transient events in the electrical distribution system **10**. As the electrical connection degrades, the temperature of the busbars **26** will increase. However, an elevated temperature of the busbars **26** can be caused by a higher than normal current draw and/or elevated ambient temperatures around the electrical connection. Therefore, it is recommended that these electrical connections should be monitored periodically to ensure that the electrical connections do not degrade. This has normally been accomplished by a person standing on the workplace floor **78** below the busway system **18** using an infrared thermometer or camera or a person on a motorized lift at the physical location of the electrical connection. In some instances, such as an obstructed joint pack **34** or potential hazards on the workplace floor **78** may require a second person on the workplace floor **78** or shutting down of the busway system **18**. However, these methods are expensive and only provide a snapshot of the electrical connection's condition at the time it is being monitored.

(22) FIG. 5 illustrates an electrical distribution system **10** on which a monitoring system **114** of the present invention has been installed. The monitoring system **114** provides continuous monitoring of some, or all, of the electrical connections in the electrical distribution system **10**. The monitoring system **114** has a means for indicating the condition of each monitored electrical connection at the actual electrical connection location, at a remote monitoring station **118** in the workplace and to a responsible individual (electrical engineer or maintenance supervisor etc.) at any virtual location via network, internet or cell phone. The monitoring system **114** includes nodes **122**, each node **122** being connected to a network **126**, which could be a wireless network or a conventional hardwired network (not shown). The network **126** is connected to a remote monitoring device **130** at the remote monitoring station **118**. The nodes **122** can be connected to the remote monitoring device **130** at the remote monitoring station **118** individually, in series, or a combination thereof. The remote monitoring device **130** includes a microprocessor **134** for interpreting the information received from the nodes **122**. The interpreting is accomplished by the microprocessor **134** using an algorithm **138** stored in a memory **142** located in the remote monitoring device **130**. The interpreted information is stored in the memory **142** and can be displayed on a Graphical User Interface (GUI) or monitor **146** at the remote monitoring station **118**.

(23) As illustrated in FIG. 6, the interpreted information is displayed on the monitor **146** as an annotated 3D map **150** of the electrical distribution system **10** including the placement of the installed nodes **122** and an associated node status chart **154**. In the busway portion of the electrical distribution system **10** nodes **122** are located at the joint pack **34** between adjoining busway

sections **22**. Each node **122** has two parts, one inside the busway housing **30** at the joint pack **34** and one outside the busway housing **30** at the joint pack **34**. The inside part includes sensing devices for monitoring elements such as temperature, current, voltage, power loss, humidity and the presence of water inside the busway housing **30**. Referring to FIG. 7, the busbar temperature sensor **158** i.e. thermocouple, thermistor, resistance temperature detectors (RTD), silicon bandgap temperature sensor) and an energy harvesting ferromagnetic power supply **162** (HL110 or equivalent), are attached to the busbars **26** in an area (indicated in FIG. 8 by reference number **166**) between the joint pack **34** and the busway housing **30** where the busbars **26** are spaced apart. The energy harvesting ferromagnetic power supply **162** includes a metal band **170** around the busbar **26** for enhancing the energy harvesting. The busbar temperature sensor **158** and energy harvesting ferromagnetic power supply **162** are attached to the busbar **26** by a self-gripping tape **174**. A current sensor **178** (Rogowski coil or equivalent) and a water/humidity sensor **184** for monitoring the inside of the busway housing **30** are also located inside the busway housing **30**. Any of the sensors described above can be used in any electrical equipment **74** that has at least one busbar **26** type electrical conductor connected to another electrical conductor. For instance, in power tap-off devices **66** the busbar temperature sensor **158**, energy harvesting ferromagnetic power supply **162** and current sensor **178** (collectively indicated as reference number **200**) can be attached to the internal electrical conductors **98**. Electronics associated with the sensors listed above can be located outside the busway housing **30** to reduce exposure to heat generated by current flow in the busbars **26**.

(24) The monitoring system **114** may also be powered independent of the energy harvesting ferromagnetic power supply **162** or electrical power connected to the electrical distribution system **10**. The independent power source could be one or more of a lithium battery, a capacitor, or the network **126**. This may allow the installer and/or electrical maintenance teams to perform diagnostics on electrical joints that have a node **122**—prior to energizing the electrical distribution system **10**. This is a significant advantage, which allows the monitoring system **114** to detect installation errors and alert installers and/or electrical maintenance teams that corrective action should be performed before electrical power is supplied to the electrical distribution system **10**. These installation errors could result in electrical insulation system damage, overheating and/or short circuits that could damage the electrical distribution system **10**.

(25) Referring to FIG. 8, the outside part of each node **122** includes an ambient air temperature sensor **182** for monitoring the air temperature around the joint pack **34**, a joint cover temperature sensor **180** for monitoring the temperature of the joint pack **34** and an antenna **186** for connecting to the network **126** the remote monitoring station **118**, and a local node status indicator **190**. The outside parts of the node **122** are attached to the bottom of the busway housing **30** at the joint pack **34** such that they are protected from water that might be dripping from a leaking roof or a fire protection sprinkler. The local node status indicator **190** is attached to the busway housing **30** such that it is clearly visible from the workplace floor **78**. For other electrical equipment **74** in the electrical distribution system **10** (switchboards, switchgear, panelboards, motor control system, lighting panels, etc.) the local node status indicator **190** is located in an easily seen location on an exterior surface of the electrical equipment **74** enclosure. The local node status indicator **190** visually displays the current state of a state machine **230** that monitors electrical connections in-the electrical distribution system **10**. The local node status indicator **190** visual display is provided by one or more LED lights that can display one or more colors. Each color is associated with the current status of monitored components of the electrical distribution system **10**. For instance, Green=normal operation, Yellow=high temperature, Orange=low compressive force, Red=urgent action required, (Alternating Orange/Red=Low Compressive force/Urgent action required by the installers and/or electrical maintenance team). The light can also use a flash or strobe frequency to further indicate the status of monitored components of the particular node **122**. The flash/strobe feature can also draw attention to a particular node **122** that has detected a potential power outage

or damage to the electrical distribution system **10**. Any means for attaching the outside part of the node **122** to the outside surface of the busway housing **30** or the exterior surface of the electrical equipment **74** enclosure can be used as long as it does not interfere with the operation of the electronic components or visibility of the local node status indicator **190**.

(26) Depending on the security or importance of the electrical distribution system **10** being monitored, nodes **122** can be placed at each joint pack **34** of the busway system **18** and each electrical connection of the attached electrical equipment **74**, only on plug-in busway **58** joint packs **34**, only on joint packs **34** after the first installed plug-in unit **86** or combinations of the above.

(27) When the monitoring system **114** is powered by the energy harvesting ferromagnetic power supply **162** individual nodes **122** of the monitoring system **114** will go into a hibernation phase to save energy when their monitored current draw at the node **122** drops below approximately 50 amps and wake up when their monitored current draw exceeds approximately 50 amps. Nodes **122** having a monitored current draw greater than 50 amps will continue to send update information to the remote monitoring device **130**. The update information includes at least the name or serial number of the node **122** its location in the electrical distribution system **10** and status of the monitored electrical connection. When the monitoring system **114** is powered by an independent power source the monitoring system **114** could monitor the nodes **122** continuously, at preset intervals, at preset times, or at the request of the remote monitoring device **130**.

(28) The compressive forces or clamped joint forces can be measured by embedding a load sensor **194** in the electrical joint or in the direct compressive path. The load sensor **194** can be a load cell, a strain gauge, a thin film load sensor (e.g., a force sensing resistor) or similar means for measuring force. FIG. **9** illustrates an alternate construction of the joint pack **34** wherein a load sensor **194** can be installed between the spring washer **46** and the head **52** of joint bolt **50**. FIG. **10** further illustrates the load sensor **194** of FIG. **9**. In this embodiment one or more load sensors **194** are installed on a cylindrical base **198** that is slidably received on the joint bolt **50**. The cylindrical base **198** could also be installed between the spring washer **46** and the nut **202** of joint bolt **50**. The load sensor **194** determines the compressive force applied to the connector plates **38** and busbars **26** by the spring washer **46** of the joint pack **34**.

(29) FIG. **12** shows an example wherein a thin film load sensor **206** is positioned on the threaded end **210** of a joint bolt **50** between a spring washer **46** and nut **202** (not shown).

(30) When a thin film load sensor **206** is employed, as in FIGS. **11** and **12**, the force actually applied to the thin film load sensor **206** is reduced by a scaling device **214** to prevent damaging the thin film load sensor **206**.

(31) To accomplish this the compressive forces applied to the thin film load sensor **206** may be scaled down by the scaling device **214** to provide a reduced proportional force on the thin film load sensor **206**. One method to provide this scaled proportional force is illustrated in FIGS. **11** and **12**. In FIG. **11**, a Belleville washer **46** is deflected by tightening the joint bolt **50** to provide a large compressive force on the electrical joint through a spacer **218**. The spacer **218** defines a pocket **220** between the Belleville washer **46** and the top of the joint pack **34** for the scaling device **214** to operate in while allowing the full force of the deflected Belleville washer **46** to be exerted on the electrical joint through the spacer **218**. The spacer **218** having means, such as a narrow slot **219**, for connecting the pocket **220** to the area **166** between the joint pack **34** and the busway housing **30**, such that a connection to the antenna **186** or the conventional hardwired network via the load sensor conductors **238** (not shown) can be accomplished. The scaling device **214** comprising a series of flat washers **222**, wavy washers **226** and the thin film load sensor **206**, may be placed under the Belleville washer **46**. The Belleville washer **46** deflection, resulting from tightening the joint bolt **50**, will compress the wavy washer(s) **226** in the scaling device **214**. The wavy washers **226** have a lower spring constant and produce a lower force on the thin film load sensor **206**. The thin film load sensor **206** is capable of being monitored by the remote monitoring device **130** at the remote monitoring station **118**. The remote monitoring device **130** may include one or more of a

microprocessor **134** having an associated memory **142**, a state machine **230** stored in the memory **142**, the state machine indicating the current state of the monitored electrical connections in the electrical distribution system **10** and, an algorithm **138** stored in the memory **142**, the microprocessor **134** using the algorithm **138** and information from the monitoring system **114** to determine the current state of the state machine **230**. The node **122** utilizes sensing devices to sense the compression force in the electrical joint, temperature of the joint and the moisture at the electrical joint.

(32) As indicated in FIG. **14**, information from the various sensing devices will require conditioning (amplification and filtering the sensor signals to the optimal range for the analog to digital converter of the microprocessor **134**) by an associated conditioning circuit **242** before being accepted by or used by the microprocessor **134**. The microprocessor **134**, using the conditioned information from the conditioning circuit **242**, an algorithm **138** and correction factors for calibration, drift factors, temperature, and time since the load sensor **194** has been monitored are stored in the memory **142**, to determine the performance level of the electrical joint and the current state of the state machine **230**. The compensated compressive force, temperature and moisture level are communicated back to the remote monitoring device **130**, a light source, operating in response to the current state of the state machine **230**, displays a visible coded signal indicating a current state of the electrical joint monitoring system **114**.

(33) FIG. **13** shows another embodiment wherein the load sensor **194** is embedded into a cavity **234** defined in the shank **48** of the joint bolt **50**. The cavity **234** is bored along the longitudinal centerline of the joint bolt **50**. Load sensor conductors **238** from the load sensor **194** exit the cavity **234** and connect to the node **122** which is connected to the remote monitoring station **118** by the network **126**.

(34) An alternate construction of the load sensor **194** can be washer shaped similar to the spacer **218** but, as in the spacer **218**, must be at least as large in diameter as the spring washer **46** in order to exert the full compressive force applied to the spring washer **46** to the join pack **34** by the tightened joint bolt **50**. In this construction the load sensor conductors **238** exits the washer like load sensor **194** along its perimeter, which should be at least equal to the diameter of the spring washer **46** to prevent possible damage to the load sensor conductors **238**.

(35) In another alternate construction of the monitoring system **114** each node **122** may include one or more of a microprocessors **134** having an associated memory **142**, a state machine **230** stored in the memory **142**, an algorithm **138** stored in the memory **142**, the microprocessor **134** using the algorithm **138** and information from the sensing devices and conditioned by a conditioning circuit **242** to determine the current state of the state machine **230** which it displays on the local node status indicator **190**. The node **122** sends the determined current state of the state machine **230** to the remote monitoring device **130**, which stores the determined current state in its memory **142**.

(36) The monitoring system **114** of the present invention has been designed such that it can be retrofit on existing installed busway systems **18**.

(37) In the preceding, reference is made to various embodiments. However, the scope of the present disclosure is not limited to the specific described embodiments. Instead, any combination of the described features and elements, whether related to different embodiments or not, is contemplated to implement and practice contemplated embodiments. Furthermore, although embodiments may achieve advantages over other possible solutions or over the prior art, whether or not a particular advantage is achieved by a given embodiment is not limiting of the scope of the present disclosure. Thus, the preceding aspects, features, embodiments and advantages are merely illustrative and are not considered elements or limitations of the appended claims except where explicitly recited in a claim(s).

(38) The various embodiments disclosed herein may be implemented as a system, method or computer program product. Accordingly, aspects may take the form of an entirely hardware embodiment, an entirely software embodiment (including firmware, resident software, micro-code,

etc.) or an embodiment combining software and hardware aspects that may all generally be referred to herein as a “circuit,” “module” or “system.” Furthermore, aspects may take the form of a computer program product embodied in one or more computer-readable medium(s) having computer-readable program code embodied thereon.

(39) Any combination of one or more computer-readable medium(s) may be utilized. The computer-readable medium may be a non-transitory computer-readable medium. A non-transitory computer-readable medium may be, for example, but not limited to, an electronic, magnetic, optical, electromagnetic, infrared, or semiconductor system, apparatus, or device, or any suitable combination of the foregoing. More specific examples (a non-exhaustive list) of the non-transitory computer-readable medium can include the following: an electrical connection having one or more wires, a portable computer diskette, a hard disk, a random access memory (RAM), a read-only memory (ROM), an erasable programmable read-only memory (EPROM or Flash memory), an optical fiber, a portable compact disc read-only memory (CD-ROM), an optical storage device, a magnetic storage device, or any suitable combination of the foregoing. Program code embodied on a computer-readable medium may be transmitted using any appropriate medium, including but not limited to wireless, wireline, optical fiber cable, RF, etc., or any suitable combination of the foregoing.

(40) Computer program code for carrying out operations for aspects of the present disclosure may be written in any combination of one or more programming languages. Moreover, such computer program code can execute using a single computer system or by multiple computer systems communicating with one another (e.g., using a local area network (LAN), wide area network (WAN), the Internet, etc.). While various features in the preceding are described with reference to flowchart illustrations and/or block diagrams, a person of ordinary skill in the art will understand that each block of the flowchart illustrations and/or block diagrams, as well as combinations of blocks in the flowchart illustrations and/or block diagrams, can be implemented by computer logic (e.g., computer program instructions, hardware logic, a combination of the two, etc.). Generally, computer program instructions may be provided to a processor(s) of a general-purpose computer, special-purpose computer, or other programmable data processing apparatus. Moreover, the execution of such computer program instructions using the processor(s) produces a machine that can carry out a function(s) or act(s) specified in the flowchart and/or block diagram block or blocks.

(41) The flowchart and block diagrams in the Figures illustrate the architecture, functionality and/or operation of possible implementations of various embodiments of the present disclosure. In this regard, each block in the flowchart or block diagrams may represent a module, segment or portion of code, which comprises one or more executable instructions for implementing the specified logical function(s). It should also be noted that, in some alternative implementations, the functions noted in the block may occur out of the order noted in the figures. For example, two blocks shown in succession may, in fact, be executed substantially concurrently, or the blocks may sometimes be executed in the reverse order, depending upon the functionality involved. It will also be noted that each block of the block diagrams and/or flowchart illustration, and combinations of blocks in the block diagrams and/or flowchart illustration, can be implemented by special purpose hardware-based systems that perform the specified functions or acts, or combinations of special purpose hardware and computer instructions.

(42) It is to be understood that the above description is intended to be illustrative, and not restrictive. Many other implementation examples are apparent upon reading and understanding the above description. Although the disclosure describes specific examples, it is recognized that the systems and methods of the disclosure are not limited to the examples described herein but may be practiced with modifications within the scope of the appended claims. Accordingly, the specification and drawings are to be regarded in an illustrative sense rather than a restrictive sense.

The scope of the disclosure should, therefore, be determined with reference to the appended claims, along with the full scope of equivalents to which such claims are entitled.

Claims

1. A monitoring system for critical electrical distribution systems, the systems comprising: an electrical distribution system constructed from preassembled sections, each section including one or more insulated electrical conductors enclosed within a housing, the electrical conductors of adjoining sections being electrically connected together by a joint pack which includes connector plates that engage end portions of the electrical conductors of adjoining sections, the connector plates and electrical conductors being compressed together by spring washers as a joint bolt passing through the spring washers is tightened thereby completing the electrical connection of the adjoining electrical conductors; some preassembled sections include plug-in openings which permit power tap-off devices to the electrical conductors inside the housing such that electrical power from the electrical distribution system can be provided to electrical equipment; and a monitoring system having at least one node attached to the electrical distribution system adjacent to the electrical connection of two sections of the electrical distribution system, the node having sensing devices for monitoring the electrical connection of the adjoining electrical conductors and the intermediate joint pack, the node being in communication with a remote monitoring device at a remote monitoring station, the remote monitoring device evaluates information received from the sensing devices to determine a current state of the electrical connection of the adjoined electrical conductors and their intermediate joint pack, the determined current state of the electrical connection being displayed at one or both of the remote monitoring station and a local node status indicator located adjacent to the node.
2. The monitoring system for critical electrical distribution systems of claim 1, wherein the electrical equipment includes at least one of switchboards, switchgear, panelboards, motor control system, or lighting panels, which can have nodes attached such that their electrical connection to the electrical distribution system can be monitored by the monitoring system.
3. The monitoring system for critical electrical distribution systems of claim 1, the node includes an inside part that includes sensing devices for monitoring elements such as electrical conductor temperature, current, voltage, power loss, compressive force, humidity and the presence of water/moisture inside the housing and an outside part that includes an ambient air temperature sensor for monitoring the air temperature around the joint pack, a temperature sensor on the joint pack cover for monitoring the joint pack temperature the local node status indicator and means for communicating with the remote monitoring device via a wired or wireless network.
4. The monitoring system for critical electrical distribution systems of claim 1, wherein the local node status indicator employs colored lights and/or strobe frequencies to indicate the current state of the electrical connection at its associated node.
5. The monitoring system for critical electrical distribution systems of claim 1, wherein a load sensor is used to determine the compressive force applied to the adjoined electrical conductors and their intermediate joint pack by the spring washer and tightened joint bolt, the load sensor can be a load cell, a strain gauge or a thin film load sensor.
6. The monitoring system for critical electrical distribution systems of claim 5, wherein the force actually applied to the thin film load sensor is reduced by a scaling device residing in a pocket defined by the spring washer and a spacer, the spacer exerts the full force of the spring washer and tightened joint bolt on joint pack.
7. The monitoring system for critical electrical distribution systems of claim 6, wherein the scaling device includes a sandwich of flat washers and wavy washers slidably received on the joint bolt and compressed by the spring washer as the joint bolt is tightened.
8. The monitoring system for critical electrical distribution systems of claim 1, wherein the remote

monitoring device includes a microprocessor, a conditioning circuit, a memory, and an algorithm stored in the memory, information received at the remote monitoring device from the sensing devices of a particular node is passed through the conditioning circuit before being accepted by or used by the microprocessor, the microprocessor uses the conditioned information and the algorithm to determine the current state of the electrical connection at particular node.

9. The monitoring system for critical electrical distribution systems of claim 8, wherein the remote monitoring device communicates the current state of the electrical connection at the particular node to the particular node, which displays its current state on the local node status indicator.

10. The monitoring system for critical electrical distribution systems of claim 1, wherein the sensing devices include a temperature sensor located on the joint pack cover for monitoring the joint pack temperature.

11. A monitoring system for a critical electrical distribution system, the monitoring system comprising: at least one node having at least one sensing device for sensing a characteristic of the critical electrical distribution system that could require unscheduled down time for maintenance or repair; the at least one sensing device being a temperature sensor, a current sensor, a voltage sensor, a power loss sensor, a water/humidity sensor, or a load sensor; the at least one node having one or more of a microprocessor having an associated memory, a state machine stored in the memory, a conditioning circuit for conditioning the sensed information and, an algorithm stored in the memory, the microprocessor using the algorithm the conditioned sensor information and information from the monitoring systems to determine the current state of the critical electrical distribution system; the microprocessor displaying the current state of the critical electrical distribution system on at least one of a local node status indicator or the remote monitoring device; the microprocessor storing the current state of the critical electrical distribution system in its associated memory, and the remote monitoring device storing the current state of the critical electrical distribution system in its memory.

12. The monitoring system of claim 11, wherein the electrical equipment includes switchboards, switchgear, panelboards, motor control system, lighting panels, all of which can have nodes attached such that their electrical connection to the critical electrical distribution system can be monitored by the monitoring system.

13. The monitoring system of claim 11, wherein the local node status indicator employs colored lights and/or strobe frequencies to indicate the current state of the critical electrical distribution system at its associated node.

14. The monitoring system of claim 11, wherein each node of the monitoring system is powered by its own energy harvesting ferromagnetic power supply which harvests power from the current flowing in the critical electrical distribution system; individual nodes of the monitoring system will enter a hibernation phase to save energy when their monitored current draw at the node drops below approximately 50 amps and wake up when their monitored current draw at the node exceeds approximately 50 amps; nodes having a monitored current draw greater than 50 amps will continue to monitor the critical electrical distribution system and send update information to the remote monitoring device; update information includes at least the name or serial number of the node the node's location in the critical electrical distribution system and status of the electrical connection monitored by the node.

15. The monitoring system of claim 11, wherein the monitoring system is powered by an independent power source other than an energy harvesting ferromagnetic power supply or power from the critical electrical distribution system.

16. The monitoring system of claim 15, the monitoring system could monitor the nodes continuously, at preset intervals, at preset times, monitor at dynamic intervals dependent on the rate of change of the sensors and/or the proximity to thresholds or at the request of the node.

17. The monitoring system of claim 11, wherein each node is individually connected to the remote monitoring device.

18. The monitoring system of claim 11, wherein the nodes are serially connected to the remote monitoring device.
