

US Patent & Trademark Office

Patent Public Search | Text View

United States Patent	12399517
Kind Code	B2
Date of Patent	August 26, 2025
Inventor(s)	Walser; Jay C.

Single zone variable air volume control systems and methods

Abstract

A control system for a climate management system configured to control climate characteristics of a building includes a memory device and a processor. The memory device includes instructions that, when executed by the processor, cause the processor to receive, via a sensor, data indicative of an evaporator coil temperature of the climate management system, and operate an air mover of the climate management system to control supply of conditioned air to the building based on the evaporator coil temperature.

Inventors: Walser; Jay C. (Norman, OK)

Applicant: JOHNSON CONTROLS LIGHT COMMERCIAL IP GMBH (Neuhausen am Rheinfall, CH)

Family ID: 1000008781176

Assignee: JOHNSON CONTROLS LIGHT COMMERCIAL IP GMBH (Neuhausen am Rheinfall, CH)

Appl. No.: 17/894923

Filed: August 24, 2022

Prior Publication Data

Document Identifier	Publication Date
US 20230063806 A1	Mar. 02, 2023

Related U.S. Application Data

continuation parent-doc US 16014735 20180621 US 11429122 child-doc US 17894923
us-provisional-application US 62686473 20180618
us-provisional-application US 62523144 20170621

Publication Classification

Int. Cl.: **G05D23/19** (20060101); **F24F3/044** (20060101); **F24F3/14** (20060101); **F24F11/49** (20180101); **F24F11/65** (20180101); **F24F11/74** (20180101); **F24F11/77** (20180101); **F24F11/86** (20180101); F24F110/10 (20180101); F24F110/20 (20180101); F24F140/20 (20180101)

U.S. Cl.:

CPC **G05D23/1927** (20130101); **F24F3/0442** (20130101); **F24F3/14** (20130101); **F24F11/49** (20180101); **F24F11/65** (20180101); **F24F11/74** (20180101); **F24F11/77** (20180101); **F24F11/86** (20180101); **G05D23/1923** (20130101); F24F2110/10 (20180101); F24F2110/20 (20180101); F24F2140/20 (20180101); F24F2203/02 (20130101); F25B2700/2104 (20130101); F25B2700/2117 (20130101)

Field of Classification Search

CPC: G05D (23/1927); G05D (23/1923); F24F (11/77); F24F (11/74); F24F (11/86); F24F (11/49); F24F (11/65); F24F (3/0442); F24F (3/14); F24F (2110/20); F24F (2110/10); F24F (2140/20); F24F (2203/02); F25B (2700/2104); F25B (2700/2117)

References Cited

U.S. PATENT DOCUMENTS

Patent No.	Issued Date	Patentee Name	U.S. Cl.	CPC
3945432	12/1975	Tamblyn	N/A	N/A
4291542	12/1980	Sminge et al.	N/A	N/A
5065593	12/1990	Dudley	62/227	F25D 21/006
6938433	12/2004	Bash et al.	N/A	N/A
7784291	12/2009	Butler et al.	N/A	N/A
8145363	12/2011	Bean, Jr. et al.	N/A	N/A
8538585	12/2012	Thøgersen et al.	N/A	N/A
9400119	12/2015	Malloy	N/A	N/A
9453656	12/2015	Liu	N/A	N/A
9574810	12/2016	West	N/A	N/A
9671125	12/2016	Mowris et al.	N/A	N/A
9690307	12/2016	Kates	N/A	N/A
2004/0231832	12/2003	Schlecht et al.	N/A	N/A
2005/0091997	12/2004	Lee	62/175	F25B 49/022
2006/0037332	12/2005	Hwang et al.	N/A	N/A
2007/0227168	12/2006	Simmons	N/A	N/A
2012/0221150	12/2011	Arensmeier	702/183	G05B 23/0221
2013/0220589	12/2012	Liu	N/A	N/A
2013/0261809	12/2012	Morrow et al.	N/A	N/A
2014/0257575	12/2013	Roy	N/A	N/A
2015/0191305	12/2014	Ueno	62/457.1	F25B 49/02
2016/0245569	12/2015	Unezaki et al.	N/A	N/A
2019/0322158	12/2018	Chevers	N/A	B60H 1/3208

FOREIGN PATENT DOCUMENTS

Patent No.	Application Date	Country	CPC
102338443	12/2011	CN	N/A
S6358049	12/1987	JP	N/A
H10197028	12/1997	JP	N/A
H10339500	12/1997	JP	N/A

OTHER PUBLICATIONS

Deng et al., Device for Preventing Evaporator or Automobile Air Conditioner . . . , Feb. 1, 2012, CN102338443A, Whole Document (Year: 2012). cited by examiner

Primary Examiner: Furdge; Larry L

Attorney, Agent or Firm: Fletcher Yoder, PC

Background/Summary

CROSS-REFERENCE TO RELATED APPLICATIONS (1) This is a continuation application of U.S. Non-Provisional application Ser. No. 16/014,735, entitled “SINGLE ZONE VARIABLE AIR VOLUME CONTROL SYSTEMS AND METHODS,” filed Jun. 21, 2018, which claims priority to and the benefit of U.S. Provisional Application No. 62/523,144, entitled “SINGLE ZONE VARIABLE AIR VOLUME (VAV) ALGORITHM,” filed Jun. 21, 2017, and U.S. Provisional Application No. 62/686,473, entitled “SINGLE ZONE VARIABLE AIR VOLUME CONTROL SYSTEMS AND METHODS,” filed Jun. 18, 2018, each of which is hereby incorporated by reference in its entirety for all purposes.

BACKGROUND

(1) The present disclosure relates generally to heating, ventilation, and air conditioning systems. A wide range of applications exist for heating, ventilation, and air conditioning (HVAC) systems. For example, residential, light commercial, commercial, and industrial systems are used to control temperatures and air quality in residences and buildings. Such systems often are dedicated to either heating or cooling, although systems are common that perform both heating and cooling functions. Very generally, these systems operate by implementing a thermal cycle in which fluids are heated and cooled to condition a controlled space, typically the inside of a residence or building, to a desired temperature. Similar systems are used for vehicle heating and cooling, and as well as for general refrigeration. In some HVAC systems, such as single zone variable air volume (VAV) systems, compression and airflow may be adjusted to condition an area, or zone, of a building.

SUMMARY

(2) The present disclosure relates to a climate management system having a control system configured to control climate characteristics of a building. The control system further includes a memory device and a processor. The memory device includes instructions that, when executed by the processor, cause the processor to receive, via a sensor, data indicative of an evaporator coil temperature of the climate management system, and operate an air mover of the climate management system to control supply of conditioned air to the building based on the evaporator coil temperature.

(3) The present disclosure also relates to a climate management system having a control system configured to control climate characteristics of a building. The control system includes a memory device and a processor. The memory device includes instructions that, when executed by the processor, cause the processor to receive, via a first sensor, data indicative of an evaporator coil

temperature of the climate management system, and receive, via a second sensor, data indicative of a supply air temperature of the climate management system. The memory device further includes instructions that, when executed by the processor, cause the processor to, in a first mode of operation of the climate management system, operate an air mover to supply conditioned air to the building based on the evaporator coil temperature relative to an evaporator coil set-point temperature, and in a second mode of operation of the climate management system, operate the air mover to supply the conditioned air to the building based on the evaporator coil temperature and based on the supply air temperature relative to a supply air set-point temperature.

(4) The present disclosure further relates to a climate management system having an evaporator coil, a blower configured to move air across the evaporator coil, a compressor system configured to operate in multiple compression stages, a first sensor configured detect an evaporator coil temperature of the evaporator coil, a second sensor configured to detect a supply air temperature of the air downstream of the evaporator coil, and a controller. The controller is configured to control an operational fan speed of the blower based on the evaporator coil temperature in a first mode of operation and based on the supply air temperature in a second mode of operation.

Description

DRAWINGS

(1) FIG. 1 is a perspective view of an embodiment of a heating, ventilation, and air conditioning (HVAC) system for building environmental management that may employ one or more HVAC units, in accordance with aspects of the present disclosure;

(2) FIG. 2 is a perspective view of an embodiment of an HVAC unit of the HVAC system of FIG. 1, in accordance with aspects of the present disclosure;

(3) FIG. 3 is a perspective view of an embodiment of a residential split heating and cooling system, in accordance with aspects of the present disclosure;

(4) FIG. 4 is a schematic view of an embodiment of a vapor compression system that may be used in an HVAC system, in accordance with aspects of the present disclosure;

(5) FIG. 5 is a schematic view of an embodiment of a climate management system used to condition a building, in accordance with aspects of the present disclosure;

(6) FIG. 6 is a flow chart of an embodiment of a first mode of operation of the climate management system of FIG. 5, in accordance with aspects of the present disclosure;

(7) FIG. 7 is a flow chart of an embodiment of a second mode of operation of the climate management system of FIG. 5, in accordance with aspects of the present disclosure; and

(8) FIG. 8 is a flow chart of an embodiment of a process to switch between the first mode of operation and the second mode of operation of the climate management system of FIG. 5, in accordance with aspects of the present disclosure.

DETAILED DESCRIPTION

(9) Certain heating, ventilation, and air conditioning (HVAC) systems, such as single zone variable air volume (VAV) systems, may operate inefficiently due to discrete control of compressor staging and/or fan speed. In such HVAC systems, an air handler may vary a flow rate of conditioned air, or a fan speed, based on a temperature of the conditioned space, or zone temperature, and may vary compressor staging, or a number of compressors in operation, on a supply air temperature.

However, the supply air temperature may fluctuate based on changing conditions. Indeed, the supply air temperature may be affected by a return air temperature, an outside air temperature, and/or a cooling capacity of the evaporator coil, which may be inconsistent and irregular. The fluctuating supply air temperature may cause an increase in the number of compressor “starts” during compressor staging operations, thereby resulting in increased degradation of components of the HVAC system and increased energy usage. As used herein, a compressor “start” refers to the

energization of a non-operating compressor during a compressor staging operation or sequence.

(10) Accordingly, the present disclosure is directed to a heating and cooling system in which compressor staging is based on a temperature of a space conditioned by the heating and cooling system, such as a zone of a building. Particularly, the temperature of a conditioned space or zone may have a high thermal inertia, thereby resulting in slower, or fewer, changes or fluctuations in the zone temperature as compared to the changes or fluctuations in supply air temperature. Controlling compressor staging based on the temperature of the zone instead of supply air temperature may result in fewer compressor starts. Moreover, in certain embodiments, fan speed, such as indoor fan speed, of the HVAC system may be based at least in part on a temperature of the evaporator coil of the HVAC system. In this manner, air flow over the evaporator coil may block, reduce, or prevent freezing of liquid on the evaporator coil and may exchange heat with refrigerant flowing through the evaporator coil to cool the air flow, thereby increasing an efficiency of the heating and cooling system.

(11) Turning now to the drawings, FIG. 1 illustrates a heating, ventilating, and air conditioning (HVAC) system for building environmental management that may employ one or more HVAC units. In the illustrated embodiment, a building 10 is air conditioned by a system that includes an HVAC unit 12. The building 10 may be a commercial structure or a residential structure. As shown, the HVAC unit 12 is disposed on the roof of the building 10; however, the HVAC unit 12 may be located in other equipment rooms or areas adjacent the building 10. The HVAC unit 12 may be a single package unit containing other equipment, such as a blower, integrated air handler, and/or auxiliary heating unit. In other embodiments, the HVAC unit 12 may be part of a split HVAC system, such as the system shown in FIG. 3, which includes an outdoor HVAC unit 58 and an indoor HVAC unit 56.

(12) The HVAC unit 12 is an air cooled device that implements a refrigeration cycle to provide conditioned air to the building 10. Specifically, the HVAC unit 12 may include one or more heat exchangers across which an air flow is passed to condition the air flow before the air flow is supplied to the building. In the illustrated embodiment, the HVAC unit 12 is a rooftop unit (RTU) that conditions a supply air stream, such as environmental air and/or a return air flow from the building 10. After the HVAC unit 12 conditions the air, the air is supplied to the building 10 via ductwork 14 extending throughout the building 10 from the HVAC unit 12. For example, the ductwork 14 may extend to various individual floors or other sections of the building 10. In certain embodiments, the HVAC unit 12 may be a heat pump that provides both heating and cooling to the building with one refrigeration circuit configured to operate in different modes. In other embodiments, the HVAC unit 12 may include one or more refrigeration circuits for cooling an air stream and a furnace for heating the air stream.

(13) A control device 16, one type of which may be a thermostat, may be used to designate the temperature of the conditioned air. The control device 16 also may be used to control the flow of air through the ductwork 14. For example, the control device 16 may be used to regulate operation of one or more components of the HVAC unit 12 or other components, such as dampers and fans, within the building 10 that may control flow of air through and/or from the ductwork 14. In some embodiments, other devices may be included in the system, such as pressure and/or temperature transducers or switches that sense the temperatures and pressures of the supply air, return air, and so forth. Moreover, the control device 16 may include computer systems that are integrated with or separate from other building control or monitoring systems, and even systems that are remote from the building 10.

(14) FIG. 2 is a perspective view of an embodiment of the HVAC unit 12. In the illustrated embodiment, the HVAC unit 12 is a single package unit that may include one or more independent refrigeration circuits and components that are tested, charged, wired, piped, and ready for installation. The HVAC unit 12 may provide a variety of heating and/or cooling functions, such as cooling only, heating only, cooling with electric heat, cooling with dehumidification, cooling with

gas heat, or cooling with a heat pump. As described above, the HVAC unit **12** may directly cool and/or heat an air stream provided to the building **10** to condition a space in the building **10**.

(15) As shown in the illustrated embodiment of FIG. 2, a cabinet **24** encloses the HVAC unit **12** and provides structural support and protection to the internal components from environmental and other contaminants. In some embodiments, the cabinet **24** may be constructed of galvanized steel and insulated with aluminum foil faced insulation. Rails **26** may be joined to the bottom perimeter of the cabinet **24** and provide a foundation for the HVAC unit **12**. In certain embodiments, the rails **26** may provide access for a forklift and/or overhead rigging to facilitate installation and/or removal of the HVAC unit **12**. In some embodiments, the rails **26** may fit into “curbs” on the roof to enable the HVAC unit **12** to provide air to the ductwork **14** from the bottom of the HVAC unit **12** while blocking elements such as rain from leaking into the building **10**.

(16) The HVAC unit **12** includes heat exchangers **28** and **30** in fluid communication with one or more refrigeration circuits. Tubes within the heat exchangers **28** and **30** may circulate refrigerant, such as R-**410A**, through the heat exchangers **28** and **30**. The tubes may be of various types, such as multichannel tubes, conventional copper or aluminum tubing, and so forth. Together, the heat exchangers **28** and **30** may implement a thermal cycle in which the refrigerant undergoes phase changes and/or temperature changes as it flows through the heat exchangers **28** and **30** to produce heated and/or cooled air. For example, the heat exchanger **28** may function as a condenser where heat is released from the refrigerant to ambient air, and the heat exchanger **30** may function as an evaporator where the refrigerant absorbs heat to cool an air stream. In other embodiments, the HVAC unit **12** may operate in a heat pump mode where the roles of the heat exchangers **28** and **30** may be reversed. That is, the heat exchanger **28** may function as an evaporator and the heat exchanger **30** may function as a condenser. In further embodiments, the HVAC unit **12** may include a furnace for heating the air stream that is supplied to the building **10**. While the illustrated embodiment of FIG. 2 shows the HVAC unit **12** having two of the heat exchangers **28** and **30**, in other embodiments, the HVAC unit **12** may include one heat exchanger or more than two heat exchangers.

(17) The heat exchanger **30** is located within a compartment **31** that separates the heat exchanger **30** from the heat exchanger **28**. Fans **32** draw air from the environment through the heat exchanger **28**. Air may be heated and/or cooled as the air flows through the heat exchanger **28** before being released back to the environment surrounding the rooftop unit **12**. A blower assembly **34**, powered by a motor **36**, draws air through the heat exchanger **30** to heat or cool the air. The heated or cooled air may be directed to the building **10** by the ductwork **14**, which may be connected to the HVAC unit **12**. Before flowing through the heat exchanger **30**, the conditioned air flows through one or more filters **38** that may remove particulates and contaminants from the air. In certain embodiments, the filters **38** may be disposed on the air intake side of the heat exchanger **30** to prevent contaminants from contacting the heat exchanger **30**.

(18) The HVAC unit **12** also may include other equipment for implementing the thermal cycle. Compressors **42** increase the pressure and temperature of the refrigerant before the refrigerant enters the heat exchanger **28**. The compressors **42** may be any suitable type of compressors, such as scroll compressors, rotary compressors, screw compressors, or reciprocating compressors. In some embodiments, the compressors **42** may include a pair of hermetic direct drive compressors arranged in a dual stage configuration **44**. However, in other embodiments, any number of the compressors **42** may be provided to achieve various stages of heating and/or cooling. As may be appreciated, additional equipment and devices may be included in the HVAC unit **12**, such as a solid-core filter drier, a drain pan, a disconnect switch, an economizer, pressure switches, phase monitors, and humidity sensors, among other things.

(19) The HVAC unit **12** may receive power through a terminal block **46**. For example, a high voltage power source may be connected to the terminal block **46** to power the equipment. The operation of the HVAC unit **12** may be governed or regulated by a control board **48**. The control

board **48** may include control circuitry connected to a thermostat, sensors, and alarms. One or more of these components may be referred to herein separately or collectively as the control device **16**. The control circuitry may be configured to control operation of the equipment, provide alarms, and monitor safety switches. Wiring **49** may connect the control board **48** and the terminal block **46** to the equipment of the HVAC unit **12**.

(20) FIG. **3** illustrates a residential heating and cooling system **50**, also in accordance with present techniques. The residential heating and cooling system **50** may provide heated and cooled air to a residential structure, as well as provide outside air for ventilation and provide improved indoor air quality (IAQ) through devices such as ultraviolet lights and air filters. In the illustrated embodiment, the residential heating and cooling system **50** is a split HVAC system. In general, a residence **52** conditioned by a split HVAC system may include refrigerant conduits **54** that operatively couple the indoor unit **56** to the outdoor unit **58**. The indoor unit **56** may be positioned in a utility room, an attic, a basement, and so forth. The outdoor unit **58** is typically situated adjacent to a side of residence **52** and is covered by a shroud to protect the system components and to prevent leaves and other debris or contaminants from entering the unit. The refrigerant conduits **54** transfer refrigerant between the indoor unit **56** and the outdoor unit **58**, typically transferring primarily liquid refrigerant in one direction and primarily vaporized refrigerant in an opposite direction.

(21) When the system shown in FIG. **3** is operating as an air conditioner, a heat exchanger **60** in the outdoor unit **58** serves as a condenser for re-condensing vaporized refrigerant flowing from the indoor unit **56** to the outdoor unit **58** via one of the refrigerant conduits **54**. In these applications, a heat exchanger **62** of the indoor unit functions as an evaporator. Specifically, the heat exchanger **62** receives liquid refrigerant (which may be expanded by an expansion device, not shown) and evaporates the refrigerant before returning it to the outdoor unit **58**.

(22) The outdoor unit **58** draws environmental air through the heat exchanger **60** using a fan **64** and expels the air above the outdoor unit **58**. When operating as an air conditioner, the air is heated by the heat exchanger **60** within the outdoor unit **58** and exits the unit at a temperature higher than it entered. The indoor unit **56** includes a blower or fan **66** that directs air through or across the indoor heat exchanger **62**, where the air is cooled when the system is operating in air conditioning mode. Thereafter, the air is passed through ductwork **68** that directs the air to the residence **52**. The overall system operates to maintain a desired temperature as set by a system controller. When the temperature sensed inside the residence **52** is higher than the set-point on the thermostat, or the set-point plus a small amount, the residential heating and cooling system **50** may become operative to refrigerate additional air for circulation through the residence **52**. When the temperature reaches the set-point, or the set-point minus a small amount, the residential heating and cooling system **50** may stop the refrigeration cycle temporarily.

(23) The residential heating and cooling system **50** may also operate as a heat pump. When operating as a heat pump, the roles of heat exchangers **60** and **62** are reversed. That is, the heat exchanger **60** of the outdoor unit **58** will serve as an evaporator to evaporate refrigerant and thereby cool air entering the outdoor unit **58** as the air passes over outdoor the heat exchanger **60**. The indoor heat exchanger **62** will receive a stream of air blown over it and will heat the air by condensing the refrigerant.

(24) In some embodiments, the indoor unit **56** may include a furnace system **70**. For example, the indoor unit **56** may include the furnace system **70** when the residential heating and cooling system **50** is not configured to operate as a heat pump. The furnace system **70** may include a burner assembly and heat exchanger, among other components, inside the indoor unit **56**. Fuel is provided to the burner assembly of the furnace **70** where it is mixed with air and combusted to form combustion products. The combustion products may pass through tubes or piping in a heat exchanger, separate from heat exchanger **62**, such that air directed by the blower **66** passes over the tubes or pipes and extracts heat from the combustion products. The heated air may then be routed

from the furnace system **70** to the ductwork **68** for heating the residence **52**.

(25) FIG. **4** is an embodiment of a vapor compression system **72** that can be used in any of the systems described above. The vapor compression system **72** may circulate a refrigerant through a circuit starting with a compressor **74**. The circuit may also include a condenser **76**, an expansion valve(s) or device(s) **78**, and an evaporator **80**. The vapor compression system **72** may further include a control panel **82** that has an analog to digital (A/D) converter **84**, a microprocessor **86**, a non-volatile memory **88**, and/or an interface board **90**. The control panel **82** and its components may function to regulate operation of the vapor compression system **72** based on feedback from an operator, from sensors of the vapor compression system **72** that detect operating conditions, and so forth.

(26) In some embodiments, the vapor compression system **72** may use one or more of a variable speed drive (VSDs) **92**, a motor **94**, the compressor **74**, the condenser **76**, the expansion valve or device **78**, and/or the evaporator **80**. The motor **94** may drive the compressor **74** and may be powered by the variable speed drive (VSD) **92**. The VSD **92** receives alternating current (AC) power having a particular fixed line voltage and fixed line frequency from an AC power source, and provides power having a variable voltage and frequency to the motor **94**. In other embodiments, the motor **94** may be powered directly from an AC or direct current (DC) power source. The motor **94** may include any type of electric motor that can be powered by a VSD or directly from an AC or DC power source, such as a switched reluctance motor, an induction motor, an electronically commutated permanent magnet motor, or another suitable motor.

(27) The compressor **74** compresses a refrigerant vapor and delivers the vapor to the condenser **76** through a discharge passage. In some embodiments, the compressor **74** may be a centrifugal compressor. The refrigerant vapor delivered by the compressor **74** to the condenser **76** may transfer heat to a fluid passing across the condenser **76**, such as ambient or environmental air **96**. The refrigerant vapor may condense to a refrigerant liquid in the condenser **76** as a result of thermal heat transfer with the environmental air **96**. The liquid refrigerant from the condenser **76** may flow through the expansion device **78** to the evaporator **80**.

(28) The liquid refrigerant delivered to the evaporator **80** may absorb heat from another air stream, such as a supply air stream **98** provided to the building **10** or the residence **52**. For example, the supply air stream **98** may include ambient or environmental air, return air from a building, or a combination of the two. The liquid refrigerant in the evaporator **80** may undergo a phase change from the liquid refrigerant to a refrigerant vapor. In this manner, the evaporator **80** may reduce the temperature of the supply air stream **98** via thermal heat transfer with the refrigerant. Thereafter, the vapor refrigerant exits the evaporator **80** and returns to the compressor **74** by a suction line to complete the cycle.

(29) In some embodiments, the vapor compression system **72** may further include a reheat coil in addition to the evaporator **80**. For example, the reheat coil may be positioned downstream of the evaporator relative to the supply air stream **98** and may reheat the supply air stream **98** when the supply air stream **98** is overcooled to remove humidity from the supply air stream **98** before the supply air stream **98** is directed to the building **10** or the residence **52**.

(30) It should be appreciated that any of the features described herein may be incorporated with the HVAC unit, the residential heating and cooling system **50**, or other HVAC systems. Additionally, while the features disclosed herein are described in the context of embodiments that directly heat and cool a supply air stream provided to a building or other load, embodiments of the present disclosure may be applicable to other HVAC systems as well. For example, the features described herein may be applied to mechanical cooling systems, free cooling systems, chiller systems, or other heat pump or refrigeration applications.

(31) As discussed below, a climate management system **100**, such as the HVAC unit **12**, the climate management system **50**, and/or the vapor compression system **72**, may supply conditioned air to a conditioned space **101**, or zone, of a building **102** with a blower **104**, or a fan, that supplies

conditioned air to the building **102** by forcing the air over an evaporator coil **105** of the evaporator **80**, as shown by arrows **106**. Particularly, the blower **104** is configured to push, pull, or other wise move air over the evaporator coil **105** at an air flow rate that is based at least in part on a temperature of the evaporator coil **105**. In certain embodiments, the climate management system **100** may be a single zone variable air volume (VAV) system that is configured to adjust the air flow rate based conditions of the conditioned space **101**. In certain embodiments, compressor operation and/or compressor staging may also be controlled based on conditions of the conditioned space **101**. Indeed, refrigerant compression and supply air flow rate of the climate management system **100** may be adjusted to efficiently provide heated, cooled, and/or dehumidified air to the conditioned space **101**.

(32) To illustrate, FIG. 5 is a schematic of an embodiment of the climate management system **100**, which is configured to supply conditioned air, such as heated, cooled, and/or dehumidified air, to the building **102**, via an air handler **103**, which may be a packaged rooftop unit. Particularly, the climate management system **100** may include the blower **104** that is configured to pull, push, or otherwise move air over the evaporator coil **105** to dehumidify and/or reduce a temperature of the air before it is supplied to the conditioned space **101** within the building **102**. Indeed, the blower **104** is configured to place the air in a heat exchange relationship with refrigerant flowing through the evaporator coil **105**, such that the refrigerant within the evaporator coil **105** absorbs heat from the air, thereby dehumidifying and/or reducing a temperature of the air before it is supplied to the conditioned space **101**. Further, it should be understood that the illustration of the climate management system **100** has been simplified to highlight certain aspects, as discussed herein. As such, it should be understood that the climate management system **100** may include additional elements that are not illustrated, which would fall within the scope of the present disclosure.

(33) As discussed herein, the blower **104** may be a modulating blower, such as a modulating fan, that is configured to supply air at a variable air flow speed, or cubic feet per minute (CFM), based at least in part on a temperature of the evaporator coil **105**. To this end, the climate management system **100** may include a temperature sensor **110** configured to detect and/or measure a temperature of the evaporator coil **105**. Particularly, the temperature sensor **110** may be a thermistor that is insulated and is in contact with an external surface of the evaporator coil **105**. The climate management system **100** may further include a variable frequency drive (VFD) **112** configured to drive operation of the blower **104** based at least on feedback from the temperature sensor **110**. Particularly, the VFD **112** may be configured to supply between approximately 25 hertz (Hz) and 60 Hz to drive an output, or fan speed, of the blower **104** between approximately 25% and 100%, respectively, of a maximum potential output of the blower **104**.

(34) The condition of the air that is supplied to the conditioned space **101** may also depend at least in part on a number of compressors and/or a number of compressor stages in operation, which may be referred to herein as “compression.” For example, in certain embodiments, the compressor **74** may include multiple compressors and/or multiple compressor stages and may be configured to provide multiple cooling stages via operation of different numbers of compressors or stages. Accordingly, as discussed herein, increasing compression may refer to increasing the number of compressors or compressor stages in operation and decreasing compression may refer to decreasing the number of compressors or compressor stages in operation of the compressor **74**. Generally, the cooling capacity of the evaporator coil **105** may increase as the compressor staging increases. That is, as compression increases, the rate at which chilled refrigerant flows the evaporator coil **105** increases, thereby allowing the evaporator **80** to absorb more heat from the air as the air passes over the evaporator coil **105**. As discussed herein, the compression of the climate management system **100** may depend on a temperature of the conditioned space **101** relative to a set-point temperature. In some embodiments, however, the compression of the climate management system **100** may depend on a supply air temperature.

(35) To this end, the climate management system **100** may further include a temperature sensor **114**

and a humidity sensor **116** disposed within the conditioned space **101** and configured to measure a temperature and a humidity level, respectively, of the conditioned space **101**. Additionally, the climate management system **100** may include a temperature sensor **118** configured to measure a temperature of the supply air, as illustrated by the arrows **106**, such as a supply air temperature (SAT).

(36) The climate management system **100** may further include a controller **120** configured to control compression and fan speed of the climate management system **100** based on the algorithms and processes discussed herein. The controller **120** may include a processor **121**, which may represent one or more processors, such as an application-specific processor. The controller **120** may also include a memory device **122** for storing instructions executable by the processor **121** to perform the methods and control actions described herein for the climate management system **100**. The processor **121** may include one or more processing devices, and the memory **122** may include one or more tangible, non-transitory, machine-readable media. By way of example, such machine-readable media can include RAM, ROM, EPROM, EEPROM, CD-ROM, or other optical disk storage, magnetic disk storage or other magnetic storage devices, or any other medium which can be used to carry or store desired program code in the form of machine-executable instructions or data structures and which can be accessed by the processor **121** or by any general purpose or special purpose computer or other machine with a processor.

(37) Particularly, as discussed below, the controller **120** may receive data from the sensors **110**, **114**, **116**, **118** and control the air handler **103** based on the data to provide conditioned air to the conditioned space **101** according to certain modes of operation. For example, in a first mode of operation, the controller **120** may adjust fan speed of the blower **104** based on a temperature of the evaporator coil **105**. The controller **120** may also adjust compression, via energizing and/or de-energizing one or more compressors **74** of the climate management system **100**, based on a temperature of the conditioned space **101**. As discussed below, the first mode of operation may enable increased humidity control in the conditioned space **101**. In a second mode of operation, the controller **120** may adjust fan speed of the blower **104** based on a supply air temperature. Control of the fan speed of the blower **104** may also include a minimum allowable fan speed offset of the blower **104** based on a temperature of the evaporator coil **105**. As discussed herein, the minimum allowable fan speed offset may be utilized to prevent, block, restrict, or otherwise inhibit freezing of liquid, such as condensate, on the evaporator coil **105**. Also, in the second mode of operation, the controller **120** may regulate compression based on a zone temperature of the conditioned space **101** or based on a supply air temperature. Generally, in both, or in either, of the first and second modes of operation, the compression of the climate management system **100** may be based on the zone temperature of the conditioned space **101** to enable reduction of a number of compressor **74** starts. As noted above, the conditioned space **101** may have a high thermal inertia, thereby resulting in slower, or fewer, changes in the zone temperature of the conditioned space **101**, thereby resulting in fewer compressor starts or compression adjustments.

(38) As mentioned above, in the first mode of operation, the controller **120** may control the fan speed of the blower **104** based on the evaporator coil temperature of the evaporator coil **105** and may control compression based on the zone temperature of the conditioned space **101**. For example, regarding the evaporator coil temperature, the fan speed may be adjusted to control the evaporator coil temperature according to an evaporator coil set-point temperature. In certain embodiments, the evaporator set-point temperature may be based on input received from a systems operator through an input device **130**, which, for example, may be an input/output device, such as a computing device. In other embodiments, the evaporator set-point temperature may be based on a manufacturer setting. Generally, the controller **120** may utilize a control loop feedback mechanism, such as a proportional-integral-derivative (PID) controller, to adjust the fan speed according to the evaporator set-point temperature.

(39) For example, if the evaporator coil temperature measured by sensor **110** drops below the

evaporator set-point temperature, the controller **120** may send one or more signals to the VFD **112** to increase the fan speed and increase the rate of airflow across the evaporator coil **105**, thereby increasing a temperature of the evaporator coil **105** and increasing the supply air temperature. More specifically, as the air speed across the evaporator coil **105** increases, more total air is moved over the evaporator coil **105** such the total amount of heat that the refrigerant flowing through the evaporator coil **105** absorbs from the air may increase by virtue of the greater volume of air moving over the evaporator coil **105**. However, because the air is flowing over the evaporator coil **105** at a faster rate, air particles of the air flow may be in contact with the evaporator coil **105** for shorter periods of time. In this manner, the amount of heat absorbed by the evaporator coil **105** per unit volume of air decreases, which correspondingly results in an increase in the supply air temperature. (40) Further, if the evaporator coil temperature rises above the evaporator set-point temperature, the controller **120** may send one or more signals to the VFD **112** to decrease the fan speed of the blower **104**, thereby decreasing a temperature of the evaporator coil **105** and decreasing the supply air temperature. To illustrate, as the air speed decreases, air is moved over the evaporator coil **105** at a slower rate, such that the total amount of heat that the refrigerant flowing through the evaporator coil **105** absorbs from the air decreases by virtue of the lesser volume of air moving over the evaporator coil **105**. As a result, a temperature of the evaporator coil **105** decreases. However, because the air is flowing over the coil at a slower rate, air particles of the air flow may be in contact with the evaporator coil **105** for longer periods of time. In this manner, the amount of heat absorbed by the evaporator coil **105** per unit volume of air increases, which correspondingly results in a decrease in the supply air temperature.

(41) As the fan speed, evaporator coil temperature, and supply air temperature decrease, the amount of humidity or moisture that is removed from the air correspondingly increases. Thus, the humidity level of the conditioned space may decrease as the fan speed decreases. Accordingly, the evaporator coil set-point temperature may be sufficiently low to decrease humidity in the conditioned space **101** and high enough to prevent or block freezing of moisture on the evaporator coil **105**. For example, in certain embodiments, the evaporator coil set-point temperature may be approximately 42° F., approximately between 42° F. and 44° F., approximately between 40° F. and 42° F., or approximately between 40° F. and 44° F.

(42) Moreover, in the first mode of operation, the compression of the climate management system **100** may be based on the zone temperature of the conditioned space **101**. For example, as the zone temperature increases, the controller **120** may send one or more signals to the air handler **103** to increase compression, thereby driving chilled refrigerant at an increased rate through the evaporator coil **105**. Indeed, the supply air temperature may decrease as the compression increases, thereby decreasing the zone temperature of the conditioned space **101**. Correspondingly, as the zone temperature decreases, the controller **120** may send or more signals to the air handler **103** to decrease compression, thereby driving chilled refrigerant at a decreased rate through the evaporator coil **105**. Indeed, the supply air temperature may increase as the compression decreases, thereby increasing a zone temperature of the conditioned space **101**. As discussed herein, compression may be based on the zone temperature due to the high thermal inertia of the conditioned space **101**. For example, in large areas, such as department stores, cafeterias, dance halls, and so forth, the zone temperature of the areas may be more resistant to change than smaller conditioned spaces or areas. Accordingly, as compression control is based on the zone temperature of the conditioned space, and due to the lower fluctuation in zone temperature, the compression may be varied less, thereby resulting in fewer compressor starts and correspondingly less wear on the climate management system **100**.

(43) Further, as mentioned above, in the second mode of operation, the controller may adjust the operating fan speed of the blower **104** based on a supply air temperature. Control of the blower **104** may also be made with reference to a minimum possible or allowable fan speed, such as a minimum allowable fan speed offset, a minimum air supply rate, or a minimum output percentage,

which is based on a temperature of the evaporator coil **105**. As an example, when the temperature of the evaporator coil **105** is above approximately 42° F., the blower **104** may operate with a normal range of fan speed, such as from 0% to 100%, or 25% to 100%, of the total blower output or maximum fan speed. In other words, zero minimum fan speed offset may be applied to the minimum possible fan speed of the blower **104** when the temperature of the evaporator coil **105** is above approximately 42° F. The fan speed of the blower **104** may adjusted during operation based on the supply air temperature relative to a supply air set-point temperature. For example, as discussed above, if the supply air temperature is below the supply air set-point temperature, the controller **120** may increase the fan speed to increase the supply air temperature. Similarly, if the supply air temperature is above the supply air set-point temperature, the controller **120** may decrease the fan speed to decrease the supply air temperature. In certain embodiments, the supply air set-point temperature may be based on a set-point temperature of the conditioned space **101**, which may be set via the input device **130**, or via a thermostat **132**. In certain embodiments, the input device **130** or the thermostat **132** may include the temperature sensor **114** and the humidity sensor **116**.

(44) However, in certain embodiments, the evaporator coil **105** may form or accumulate ice if the evaporator coil temperature drops below approximately 42° F., which may lead to inefficiencies in the operation of the climate management system **100**. Accordingly, if the evaporator coil temperature drops below approximately 42° F., the controller **120** may set or increase a minimum possible or allowable fan speed to prevent, block, reduce, or otherwise inhibit formation and accumulation of ice on the evaporator coil **105**. Indeed, as mentioned above, the evaporator coil temperature may increase as the fan speed of the blower **104** increases. For example, when the evaporator coil temperature drops below approximately 42° F., the controller **120** may increase the minimum allowable fan speed of the blower **104**. More particularly, the controller **120** may apply or add a minimum fan speed offset to the minimum allowable fan speed of the blower **104** at which the blower **104** may operate in order to increase the minimum allowable fan speed of the blower **104** during operation. In certain embodiments, the minimum fan speed offset applied to the minimum allowable fan speed of the blower **104** may be incrementally increased as the evaporator coil temperature falls closer to 26° F. At 26° F., the minimum fan speed offset applied to the minimum allowable fan speed may be set to approximately 100% of the total blower output, such that the blower **104** does not operate at less than 100% capacity. In other words, when the evaporator coil temperature has reached 26° F. or below, the minimum allowable fan speed may be set to 100% of the total blower output, such as a maximum possible fan speed of the blower **104**. For example, the minimum fan speed of the blower **104** may be set according to equation (1):

$$MFS = (-6.25)(ECT) + 262.5^\circ \text{ F.} \quad (1)$$

where MFS is the minimum allowable fan speed, expressed as a percentage, from 1 to 100, of total blower **104** output at which the blower **104** may operate, and ECT is the evaporator coil temperature, which ranges from 42 to 26 in degrees Fahrenheit.

(45) In this manner, the fan speed of the blower **104** may be modulated to increase or decrease based on the supply air set-point temperature, while remaining equal to or greater than the minimum allowable fan speed that is set based on the evaporator coil temperature **105**. As discussed above, lower fan speeds may result in a decreased supply air temperature and increased humidity removal, which may be beneficial when providing conditioned air to the conditioned space **101**. Accordingly, in certain embodiments, the fan speed may be modulated such that the fan speed is set approximately equal to the minimum allowable fan speed set by the controller **120** according to equation (1).

(46) Moreover, in the second mode of operation, the compression of the climate management system **100** may be based on the zone temperature of the conditioned space **101**, similar to the first mode of operation. Indeed, as discussed above, compression may be based on the zone temperature due to the high thermal inertia of the conditioned space **101**. Particularly, the increased thermal

inertia of the conditioned space **101** may result in reduced fluctuation in the zone temperature. Accordingly, due to the low fluctuation in zone temperature, the compression may be varied less, thus resulting in fewer compressor starts and correspondingly less wear on the climate management system **100**. However, in certain embodiments, compression of the climate management system **100** may be based on the supply air temperature relative to the supply air set-point temperature. That is, compression may be increased as the supply air temperature rises above the supply air set-point temperature and may be decreased as the supply air temperature drops below the supply air set-point temperature.

(47) Further, as discussed below, in some embodiments, the climate management system **100** may switch between the first and second modes of operation based in part on a humidity level of the conditioned space **101** relative to a humidity level threshold value, such as a first humidity level threshold value, which may be set via the input device **130** and/or the thermostat **132**. For example, as mentioned above, in the first mode of operation, the controller **120** may adjust fan speed based on a temperature of the evaporator coil **105**. The controller **120** may adjust the fan speed to maintain the evaporator coil temperature at a sufficiently low temperature to efficiently remove humidity from the supplied air and maintain the humidity level below the first threshold value. However, if the climate management system **100** is operating in the second mode of operation and the humidity level of the conditioned space **101** rises above the first humidity level threshold value, the controller **120** may switch operation of the climate management system **100** from the second mode to the first mode to more actively reduce the humidity level of the conditioned space **101**, such that the humidity level falls below the first threshold value.

(48) In certain embodiments, once the humidity level of the conditioned space **101** falls below a second humidity level threshold value, the controller **120** may switch operation of the climate management system **100** from the first mode to the second mode. In some embodiments, the second humidity level threshold value may be lower than the first humidity threshold level. In certain embodiments, however, the controller **120** may switch between the first and second modes of operation based on a manual input, which may be received via the input device **130** or the thermostat **132**, for example.

(49) FIG. **6** is a flow chart illustrating an embodiment of a first mode of operation **600** of the climate management system **100**. At block **602**, the controller **120** may receive data indicative of an evaporator coil set-point temperature and a zone set-point temperature, which may be a set-point temperature of the conditioned space **101**. As discussed herein, the evaporator coil set-point temperature and the zone set-point temperature may be set via the input device **130**, which may be a thermostat, a computing device, or any device capable of receiving input and communicating the input to the controller **120**.

(50) At block **604**, the controller **120** may determine the evaporator coil temperature and the zone temperature. As discussed above, to determine the evaporator coil temperature, the controller **120** may receive data indicative of the evaporator coil temperature from the temperature sensor **110** that is in contact with the evaporator coil **105**. Similarly, to determine the zone temperature, the controller **120** may receive data indicative of the zone temperature from the temperature sensor **114** located in the conditioned space **101**.

(51) Once the evaporator coil temperature is determined, the controller **120** may adjust the fan speed to maintain the evaporator coil temperature at the evaporator coil set-point temperature, as indicated by block **606**. Particularly, in certain embodiments, the controller **120** may utilize a control loop feedback mechanism, such as a PID controller, or a proportional-integral (PI) controller, to adjust the fan speed to achieve the evaporator coil set-point temperature. For example, as discussed above, if the evaporator coil temperature is above the set-point temperature, the controller **120** may decrease the fan speed to decrease the evaporator coil temperature. Similarly, if the evaporator coil temperature is below the set-point temperature, the controller may increase the fan speed to increase the evaporator coil temperature. As discussed above, in certain embodiments,

the evaporator coil set-point temperature may be set to approximately 42° F. to inhibit the formation and accumulation of ice on the evaporator coil **105** and to efficiently remove humidity from the supply air provided to the conditioned space **101**.

(52) Further, once the zone temperature is determined, the controller **120** may adjust the compression of the climate management system **100** to achieve or maintain the zone temperature at the zone set-point temperature, as indicated by block **608**. For example, as the zone temperature increases above the zone set-point temperature, the controller **120** may increase the compression, such as by increasing the number of compressors or compressor stages in operation. In this way, the controller **120** may increase the amount of cooling provided by the climate management system **100** as the difference between the zone temperature and the zone set-point temperature increases.

(53) As illustrated, the controller **120** may repeatedly determine the evaporator temperature and repeatedly reevaluate and/or adjust the fan speed based on the evaporator coil temperature relative to the evaporator coil set-point temperature, as indicated by blocks **604** and **606**. Indeed, the controller **120** may also repeatedly determine the zone temperature and repeatedly reevaluate and/or adjust the compression based on zone temperature relative to the zone set-point temperature, as indicated by blocks **604** and **608**.

(54) FIG. 7 is a flow chart illustrating an embodiment of a second mode of operation **700** of the climate management system **100**. At block **702**, the controller **120** may receive data indicative of an evaporator coil set-point temperature, a zone set-point temperature, and a supply air set-point temperature. As discussed herein, the evaporator coil set-point temperature, the zone set-point temperature, and the supply air set-point temperature may be set via the input device, in certain embodiments.

(55) At block **704**, the controller **120** may determine the evaporator coil temperature, the zone temperature, and the supply air temperature. Particularly, as discussed above, to determine the evaporator coil temperature, the controller **120** may receive data indicative of the evaporator coil temperature from the temperature sensor **110** that is in contact with the evaporator coil **105**. Similarly, to determine the zone temperature, the controller **120** may receive data indicative of the zone temperature from the temperature sensor **114** located in the conditioned space **101**. Further, to determine the supply air temperature, the controller may receive data indicative of the supply air temperature from the temperature sensor **118**.

(56) Once the evaporator coil temperature is determined, the controller **120** may determine the minimum allowable fan speed based on the evaporator coil temperature, as indicated by block **706**. For example, as discussed above, as the evaporator coil temperature decreases below 42° F., the controller **120** may increase the minimum allowable fan speed pro rata. For example, the minimum allowable fan speed may be set to 0% of total blower **104** capacity when the evaporator coil temperature is at 42° F., may be set to 50% of total blower **104** capacity when the evaporator coil temperature is at 34° F., and may be set to 100% of total blower **104** capacity when the evaporator coil temperature is at 26° F. In this manner, the controller **120** may inhibit the formation and accumulation of ice on the evaporator coil **105**.

(57) Once the minimum allowable fan speed and the supply air temperature are determined, the controller **120** may adjust the fan speed to maintain the supply air temperature according the supply air set-point temperature, while maintaining the fan speed equal to or above the determined minimum allowable fan speed, as indicated by block **708**. For example, as discussed above, the controller **120** may generally increase the fan speed to increase the supply air temperature and may decrease the fan speed to decrease the supply temperature.

(58) Further, once the zone temperature is determined, at block **704**, the controller **120** may adjust the compression of the climate management system **100** to achieve or maintain the zone temperature at the zone set-point temperature, as indicated by block **710**. For example, as the zone temperature increases above the zone set-point temperature, the controller **120** may increase compression, such as by increasing the number of compressors or compressor stages in operation.

In this way, the controller **120** may increase the amount of cooling provided to the conditioned space **101** by the climate management system **100** as the difference between the zone temperature and the zone set-point temperature increases. Similarly, the controller **120** may decrease compression as the zone temperature decreases below the zone set-point temperature. In other embodiments, the compression may be based on the supply air temperature relative to the supply air set-point temperature. That is, compression may be increased if the supply air temperature increases above the supply air set-point temperature, and compression may be decreased if the supply air temperature decreases below the supply air set-point temperature.

(59) Moreover, as illustrated, the controller **120** may repeatedly determine the evaporator temperature and repeatedly reevaluate and/or adjust the minimum allowable fan speed based on the evaporator coil temperature, as indicated by blocks **704** and **706**. The controller **120** may further repeatedly determine the supply air temperature and adjust the operating fan speed based on the minimum allowable fan speed and the supply air temperature relative to the supply air set-point temperature, as indicated by blocks **704** and **708**. Indeed, the controller **120** may also repeatedly determine the zone temperature and repeatedly reevaluate and/or adjust the compression based on the zone temperature relative to the zone set-point temperature, as indicated by blocks **704** and **710**.

(60) FIG. **8** is a flow chart illustrating an embodiment of a process **800** to select, and/or switch between, the first mode of operation described with reference to FIG. **6** and the second mode of operation described with reference to FIG. **7**. At block **802**, the controller **120** may determine whether an input has been received to select either the first or second mode of operation. For example, an input may be received through the input device **130**, as discussed above. If the input to select either the first or second mode of operation is received, the controller **120** may operate the climate management system **100** according to the selection, as indicated at block **804**.

(61) If an input for a selection of either the first or second mode of operation has not been received, the controller **120** may determine whether the humidity level of the conditioned space **101** is above a first threshold, as indicated by block **806**. As discussed above, the controller **120** determines the humidity level of the conditioned space **101** based on data received from the humidity sensor **116**. If the humidity level is above the first threshold, the controller **120** may operate the climate management system **100** according to the first mode of operation, as indicated by block **808**. The controller **120** may then determine whether the humidity level is below a second threshold, as indicated by block **810**. If the humidity level is below the second threshold, the controller may once again determine whether the humidity level is above the first threshold, as indicated by block **806**. If the humidity level is below the first threshold at block **806**, the controller **120** may proceed to operate the climate management system **100** in the second mode of operation, as indicated by block **812**.

(62) In certain embodiments, the second threshold may be less than the first threshold. In this manner, the controller **120** may switch between the first and second modes of operation less often than if the first and second thresholds were even. That is, once the humidity level rises above the first threshold, and the climate management system **100** is operated in the first mode of operation, the humidity level must first decrease below the second threshold before the controller **120** may consider operating the climate management system **100** in the second mode of operation, as indicated by block **806**. Otherwise, the controller **120** continues to operate in the first mode of operation, as indicated at block **808**. If the humidity level is below the first threshold at block **806**, the controller **120** may operate the climate management system **100** in the second mode of operation, at block **812**, as discussed above. Further, in certain embodiments, the controller **120** may operate the climate management system **100** in either the first or second mode of operation based on a single humidity threshold level. That is, if the humidity level is above the single humidity threshold level, the controller **120** may operate the climate management system **100** in the first mode of operation. Correspondingly, if the humidity level is below the single humidity threshold level, the controller **120** may operate the climate management system **100** in the second

mode of operation. Further, if at any time the controller **120** receives a user input regarding a selection of operating mode, the controller **120** may simply operate the climate management system **100** according the user input, as indicated at block **804**.

(63) Accordingly, the present disclosure is directed to providing systems and methods for efficiently controlling a climate management system, such as a single zone variable air volume (VAV) system. Particularly, an evaporator fan speed, such as a minimum allowable evaporator fan speed, may be determined at least in part based on a temperature of an evaporator coil. In this manner, the evaporator coil temperature may be maintained low enough to adequately cool and dehumidify the air and high enough to inhibit freezing of liquid on the coil, thereby increasing an efficiency of the climate management system. Further, compression of the climate management system **100** may be based on a zone temperature of a conditioned space, which may have a high thermal inertia. That is, the zone temperature of the conditioned space may be more resistant to change than supply air temperature, for example, thereby resulting in less cycling of the compressors and less wear on the climate management system.

(64) While only certain features and embodiments of the present disclosure have been illustrated and described, many modifications and changes may occur to those skilled in the art, such as variations in sizes, dimensions, structures, shapes and proportions of the various elements, values of parameters, such as temperatures or pressures, mounting arrangements, use of materials, colors, orientations, and so forth, without materially departing from the novel teachings and advantages of the subject matter recited in the claims. The order or sequence of any process or method steps may be varied or re-sequenced according to alternative embodiments. It is, therefore, to be understood that the appended claims are intended to cover all such modifications and changes as fall within the true spirit of the present disclosure. Furthermore, in an effort to provide a concise description of the exemplary embodiments, all features of an actual implementation may not have been described, such as those unrelated to the presently contemplated best mode of carrying out the present disclosure, or those unrelated to enabling the claimed embodiments. It should be appreciated that in the development of any such actual implementation, as in any engineering or design project, numerous implementation specific decisions may be made. Such a development effort might be complex and time consuming, but would nevertheless be a routine undertaking of design, fabrication, and manufacture for those of ordinary skill having the benefit of this disclosure, without undue experimentation.

Claims

1. A non-transitory computer-readable medium, comprising instructions that, when executed by one or more processors, are configured to cause the one or more processors to: receive, via a first sensor, data indicative of an evaporator coil temperature of a heating, ventilation, and air conditioning (HVAC) system; receive, via a second sensor, data indicative of a humidity level in a space conditioned by the HVAC system; operate a blower of the HVAC system at an operating fan speed to control supply of conditioned air to the space based on the evaporator coil temperature relative to an evaporator coil set-point temperature in response to a determination that the humidity level is above a threshold level; and regulate the operating fan speed of the blower to be equal to or greater than a minimum allowable fan speed in response to a determination that the humidity level is below the threshold level.
2. The non-transitory computer-readable medium of claim 1, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to adjust the operating fan speed of the blower to maintain the evaporator coil temperature at the evaporator coil set-point temperature in response to the determination that the humidity level is above the threshold level.
3. The non-transitory computer-readable medium of claim 2, wherein the instructions, when

executed by the one or more processors, are configured to cause the one or more processors to: reduce the operating fan speed in response to a determination that the evaporator coil temperature is above the evaporator coil set-point temperature; and increase the operating fan speed in response to a determination that the evaporator coil temperature is below the evaporator coil set-point temperature.

4. The non-transitory computer-readable medium of claim 1, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to: receive, via a third sensor, data indicative of a temperature in the space conditioned by the HVAC system; and stage operation of a compressor system of the HVAC system based on the temperature relative to a set-point temperature of the space.

5. The non-transitory computer-readable medium of claim 4, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to increase compression by the compressor system in response to determining the temperature is above the set-point temperature of the space.

6. The non-transitory computer-readable medium of claim 1, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to adjust the minimum allowable fan speed based on the data indicative of the evaporator coil temperature in response to the determination that the humidity level is below the threshold level.

7. The non-transitory computer-readable medium of claim 1, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to: receive, via a third sensor, data indicative of a supply air temperature; and adjust the operating fan speed of the blower and regulate the operating fan speed to be equal to or greater than the minimum allowable fan speed to maintain the supply air temperature at a supply air set-point temperature in response to the determination that the humidity level is below the threshold level.

8. A heating, ventilation, and air conditioning (HVAC) system, comprising: an evaporator coil; a blower configured to direct air across the evaporator coil; and a controller configured to: receive, via a sensor, data indicative of a humidity level within a space conditioned by the HVAC system; operate the blower at an operating speed to maintain a temperature of the evaporator coil at a set-point temperature of the evaporator coil in response to a determination that the humidity level within the space conditioned by the HVAC system is above a threshold level; and regulate the operating speed of the blower to be equal to or greater than a minimum allowable speed in response to a determination that the humidity level within the space conditioned by the HVAC system is below the threshold level.

9. The HVAC system of claim 8, comprising a compressor system, wherein the controller is configured to operate the compressor system based on a temperature of the space conditioned by the HVAC system relative to a set-point temperature of the space.

10. The HVAC system of claim 9, wherein the compressor system comprises a plurality of compressors, and the controller is configured to increase a quantity of the plurality of compressors of the compressor system in operation in response to determining the temperature of the space is above the set-point temperature of the space.

11. The HVAC system of claim 8, wherein the controller is configured to adjust the operating speed of the blower to maintain a temperature of a supply air flow directed into the space at a set-point temperature of the supply air flow in response to the determination that the humidity level within the space is below the threshold level.

12. The HVAC system of claim 11, wherein the controller is configured to: increase the operating speed of the blower in response to a determination that the temperature of the supply air flow is below the set-point temperature of the supply air flow; and decrease the operating speed of the blower in response to a determination that the temperature of the supply air flow is above the set-point temperature of the supply air flow.

13. The HVAC system of claim 8, wherein the controller is configured to adjust the minimum

allowable speed based on the temperature of the evaporator coil in response to the determination that the humidity level is below the threshold level.

14. A control system for a heating, ventilation, and air conditioning (HVAC) system, comprising: one or more processors; and a memory comprising instructions that, when executed by the one or more processors, are configured to cause the one or more processors to: determine, based on data received via a first sensor, an evaporator coil temperature of the HVAC system; determine, based on data received via a second sensor, a humidity level in a space conditioned by the HVAC system; adjust an operating speed of a blower configured to supply conditioned air to the space based on the evaporator coil temperature relative to an evaporator coil set-point temperature in response to a determination that the humidity level is above a threshold value; and regulate the operating speed of the blower to be equal to or greater than a minimum allowable speed in response to a determination that the humidity level is below the threshold value.

15. The control system of claim 14, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to: operate a compressor system of the HVAC system at a first stage based on a first difference between a temperature of the space conditioned by the HVAC system and a set-point temperature of the space; and operate the compressor system at a second stage based on a second difference between the temperature of the space and the set-point temperature of the space, wherein the second stage is greater than the first stage, and the second difference is greater than the first difference.

16. The control system of claim 14, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to adjust the operating speed of the blower based on a temperature of the conditioned air supplied to the space relative to a set-point temperature of the conditioned air supplied to the space in response to the determination that the humidity level is below the threshold value.

17. The control system of claim 14, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to: increase the minimum allowable speed in response to a determination that the evaporator coil temperature is below the evaporator coil set-point temperature; and decrease the minimum allowable speed in response to a determination that the evaporator coil temperature is above the evaporator coil set-point temperature.

18. The control system of claim 14, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to adjust the operating speed of the blower based on the evaporator coil temperature relative to the evaporator coil set-point temperature in response to receipt of a user input.

19. The control system of claim 14, wherein the instructions, when executed by the one or more processors, are configured to cause the one or more processors to determine the evaporator coil set-point temperature based on a user input.
