

**Device Sensors**

**Device Sensors**

This dialog shows the current sensor data for the selected device.

Hostname: 150.202.151.43  
 Location: Not Available  
 Last Contact: Oct 21, 2008 10:38:50 AM

Set: All Sensors

Search:  Clear

Sensor	Sensor Value
RTU1 Econ. Enabled	Disabled
RTU13 Cooling State	On
RTU2 Econ. Enabled	Enabled
RTU12 Cooling State	On
Humidity Failure	Unknown
Humidifier Run Status	Idle
RTU13 System State	On
RTU12 System State	On
Link Status	Online
Humidifier Steam Output	0.0
RTU1 Control Status	4361.0
RTU2 Control Status	4361.0
Humidifier Bed Life (Minutes)	30.0 min
Humidifier Run Time (Minutes)	59.0 min
Humidifier Bed Life (Hours)	0.0 h
RTU13 Cooling Mode Hrs	460.0 h
Humidifier Run Time (Hours)	0.0 h
RTU12 Cooling Mode Hrs	709.0 h
Humidifier RH/Demand (Analog Input)	0 % RH
RTU12 Control Humidity	45 % RH
Humidifier Desired RH/Demand	0 % RH
RTU13 Control Humidity	45 % RH
RTU1 Return Air Temp	32.0 °F
RTU12 Return Air Temp	32.0 °F
RTU12 Ambient Temp	158.0 °F
RTU12 Control Temp	154.4 °F
RTU2 Return Air Temp	32.0 °F
RTU12 Supply Air Temp	32.0 °F
RTU13 Supply Air Temp	32.0 °F
RTU1 Space Temp	159.8 °F
RTU13 Ambient Temp	158.0 °F
RTU1 Supply Air Temp	156.2 °F
RTU2 Space Temp	158.0 °F
RTU13 Return Air Temp	32.0 °F
RTU2 Supply Air Temp	125.6 °F
RTU13 Control Temp	154.4 °F

?
OK
Cancel

No...  
 1=Enabled  
 Local Display  
 is 16/hr ?  
 still clarifying

No Sensor  
 Exists  
 Do not  
 convert  
 No Sensor

Values in  
 °F already  
 Do Not Convert