LRANEW 2.5 21/03/11

Carel	Modbus	LRANEW 2.5 21/03/11 Description	Unit	Read -	Min value	Max Value
address	Address	· ·	measure	write		
0	1	DIGITAL VARIABLES (COILS)				1
1	2	Not used System On		r		
2	3	Compressor 1		r		
3	4	Compressor 2		r		
4	5	Condensing Regulation Active		r		
5	6	Reserved Variable				
6	7	Reserved Variable				
7	8	Antifreeze heaters (option)		r		
8	9	Circuit Defrost (Heat pump only)		r		
9	10	Reserved Variable				
10	11	Winter mode (Heat pump only)		r		
11	12			•••		
12	13	-				
13	14	-				
14 15	15 16			•••		
16	17			•••		
17	18					
18	19					
19	20	Wrong password Alarm		r		
20	21	Water inlet High Temperature Alarm		r		
21	22	Water inlet Low Temperature Alarm		r		
22	23	Loss of water flow Alarm		r		
23	24	Low Pressure PreAlarm (Autom.Reset)		r		
24	25	Low Pressure Alarm		r		
25	26	High Pressure Alarm		r		
26	27	Compressor 1 Overload Alarm		r		
27	28	Compressor 2 Overload Alarm		r		
28	29	Circulating Pump Loss flow Alarm		r		
29	30	Circuit Antifreeze Alarm		r		
30	31	Interrupted LAN Alarm		r		
31	32	Water Inlet Temp. Sensor Failure/Disconnected		r		
32	33	Water Outlet Temp. Sensor Failure/Disconnected		r		
33	34	Outdoor air Temp. Sensor Failure/Disconnected		r		
34	35	Condensing Temp. Sensor Failure/Disconnected		r		
35	36	Circulating Pump 1		r		
36	37					
37	38			•••		
38	39 40					
40	41					
41	42			•••		
42	43	<u></u>				
43	44					
44	45					
45	46					
46	47					
47	48					
48	49					
49	50					
50	51					
51	52					
52	53					
53	54	Compressor 1: hour counter threshold Alarm		r		
54	55	Compressor 2: hour counter threshold Alarm		r		
55	56	Circulating Pump: hour counter threshold Alarm		r		
56	57	General Alarm State		r		
57	58	2nd Level Alarm State		r		
58	59	Summar/Minter made remate control				
59	60	Summer/Winter mode remote control		r/w		
60	61	Unit Remote Switch-On/Off Control		r/w		
61 62	62 63	Buzzer and Alarm Remote Reset Control		r/w		
63	64	Set Back Mode (Sleep Mode)		r/w		
64	65	Set Back mode: Cyclical Start of Fan		r/w		
65	66	Usage of Temp. Values: Local (0) / Mean (1)		r/w		
66	67	No. Of Stand-by Units: one (0) / two (1)		r		
67	68	Reserved Variable				
68	69	Operational Limits Of Evaporation		r		
69	70	Operational Limits Of Condensation		r		
70	71	Circuit Compressor malfunction		r		
71	72	High Condensing Temperature		r		
72	73	Circuit Compressor Operative Limits		r		
73	74	Defrost Limits		r		
74	75					
75	76					
		ANALOG VARIABLES (HOLDING or INPUT REGISTERS)	all values x	10)		
0	1	Not used .	-	-		
1	2	Water Outlet Temperature	°C	r		
2	3	Water Outlet Temp. used by regulator	°C	r		
			°C	r		

LRANEW 2.5 21/03/11

		LRANEW 2.5 21/03/11				
4	5	Outdoor Air Temperature	°C	r		
5	6	Condensing Temperature	°C	r		
6	7	Suction Pressure	Bar	r		
7	8	Evaporating Temperature	°C	r		
8	9	Suction Temperature	°C	r		
9	10	Fan Speed Modulation (0-100,0%)	%	r		
10	11	Regulation Ramp	°C	r		
11	12	Real Superheat	°C	r		
12	13	Actual Superheat circuit	°C	r		
13	14		-	-		
14	15		_	-		
15	16		°C			
		Delivery Water Temp. Actual Set Point		r		
16	17	Delivery Water Temp. Max. Hysteresi	°C	r		
17	18	Sending variables Offset		r/w	0,1	
18	19	Delivery Water Temp. Summer STD Set Point	°C	r/w	6.0(2)	13.0 (2)
19	20	Delivery Water Temp. Summer OPT Set Point	°C	r/w	6.0(2)	13.0 (2)
20	21	Del.Water T. Summer SetBack mode SetP.	°C	r/w	6.0(2)	13.0 (2)
21	22	Delivery Water Temp. Winter Set Point	°C	r/w	28 (2)	53 (2)
22	23	Del.Water T. Winter SetBack mode SetP.	°C	r/w	28 (2)	53 (2)
23	24		°C			
		CW inlet High Temp. Alarm Threshold		r/w	-15,0	25,0
24	25	CW inlet Low Temp. Alarm Threshold	°C	r/w	-15,0	35,0
25	26	HW inlet High Temp. Alarm Threshold	°C	r/w	30,0	58,0
26	27	HW inlet Low Temp. Alarm Threshold	°C	r/w	20,0	50,0
27	28	Summer T.ext Compens.: P1 T.ext SetP.	°C	r/w	10,0	45,0
28	29	Summer T.ext Compens.: P2 T.wout SetP.	°C	r/w	6.0(2)	13.0 (2)
29	30	Summer T.ext Compens.: P2 T.ext SetP.	°C	r/w	10,0	45,0
30	31	Winter T.ext Compens.: P1 T.ext SetP.	°C	r/w	-10,0	15,0
31	32	,	°C	r/w		
		Winter T.ext Compens.: P2 T.ext SetP.			28,0	53,0
32	33	Winter T.ext Compens.: P2 T.ext SetP.	°C	r/w	-10,0	15,0
33	34	Automatic switch summer/winter - External temperature on Winter	°C	r/w	8,0	24,0
34	35	Automatic switch summer/winter - External temperature on Summer	°C	r/w	12,0	28,0
		INTEGER VARIABLES (HOLDING or INPUT REGIST	ED6/			
_	400	· · · · · · · · · · · · · · · · · · ·	EKOJ		1	
0	129	Not Used	-	-		
1	130	Compressor 1 hour counter	h	r		
2	131	Compressor 2 hour counter	h	r		
3	132	Circulating Pump 1 hour counter	h	r		
4	133	Compressor 1 Starting counter	n	r		
5	134	Compressor 1 Starting counter x10.000	nx10 ⁴	r		
6	135	Compressor 2 Starting counter	n	r		
7	136	Compressor 2 Starting counter x10.000		r		
		1 - 1	nx10 ⁴			
8	137	Circuit Defrost counter	n	r		
9	138	Circuit Defrost counter x10.000	nx10 ⁴	r		
10	139	Non Performing Defrost counter	n	r		
11	140	Non Performing Defrost counter x10.000	nx10 ⁴	r		
12	141					
13	142					
14	143					
15	144					
16	145					
17	146				1	
18	147					
19	148		I		<u> </u>	
20	149					
21	150					
22	151		 			
23	152		-		1	
24	153	Unit Type (0= STD Chiller, 1=Technologic Use Chiller, 2=Heat Pump)	-	···	1	
		11 1		r	1	
25	154	Position Valve	n	r		
26	155	Total of units connected in LAN	n	r		
27	156	Comp.1 Status (0=Off,1=On,2=AL,3=Pump.Down)	n	r		
28	157	Comp.2 Status		r	1	
			i			
29	158	Pump 1 Status		r		1
				r		
29	158	Pump 1 Status Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset				
29	158	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote				
29 30	158 159	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset	S			
29 30 31 32	158 159 160 161	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght		r	0	300
29 30 31 32 33	158 159 160 161 162	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay	s	r r r/w	0	300
29 30 31 32 33 34	158 159 160 161 162 163	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory	s s	r r r/w r/w	15	99
29 30 31 32 33 34 35	158 159 160 161 162 163 164	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay	S S S	r r r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36	158 159 160 161 162 163 164 165	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay	s s	r r r/w r/w	15	99
29 30 31 32 33 34 35 36 37	158 159 160 161 162 163 164 165 166	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36	158 159 160 161 162 163 164 165	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay	S S S	r r r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37	158 159 160 161 162 163 164 165 166	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38	158 159 160 161 162 163 164 165 166	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38	158 159 160 161 162 163 164 165 166 167	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41	158 159 160 161 162 163 164 165 166 167 168 169	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42	158 159 160 161 162 163 164 165 166 167 168 169 170	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r t/w t/w t/w t/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42 43	158 159 160 161 162 163 164 165 166 167 168 169 170 171	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44	158 159 160 161 162 163 164 165 166 167 168 169 170 171 172	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r t/w t/w t/w t/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45	158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44	158 159 160 161 162 163 164 165 166 167 168 169 170 171 172	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300
29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45	158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173	Actual set Point mode (0=std,1= T.ext Compens., 2=OPT SetP., 3=Setback SetP., 4=Remote Offset Reserved Variable Last Defrost Lenght Restart Delay Regulation Start Transitory Low Pressure Delay Water High/Low Temp. Alarm Delay Reserved Variable	S S S	r r r/w r/w r/w r/w	15 0	99 300

LRANEW 2.5 21/03/11

48	177					
49	178					
50	179					
51	180					
52	181					
53	182					
54	183					
55	184					
56	185					
57	186					
58	187					
59	188					
60	189	Automatic switch summer/winter - Delay On Winter	min	r/w	1	300
61	190	Automatic switch summer/winter - Delay On Summer	min	r/w	1	300
62						