[Program Name : MainTask]

[Section Name : ADC_Scalling]

000000
(000011)

CF113
P_On
Always ON Flag

SCL (194)
201 STEAM_PRESSURE
D20
D101 PV_STEAM

[OP1] STEAM PRESSURE ADC
[OP2] VARIABEL Scalling Steam
<cD00020>
c001
[OP3] PV Steam Pressure Bar*100
<cD00101>
c082 c101

SCL (194)
202 T_RESIDUE
D30
D102 PV_TResidue

[OP1] T ADC
[OP2] Variable Scalling Suhu Residu
<cD00030>
c005
[OP3] PV T Residue Celcius*100
<cD00102>
c028