
(a) Truth switch
1
Ground truth
inner space (EnergyPlus)
(b) VAV-Core_mid graphic: zone values
ZONE Core_mid
Core · represents 10 floors (×10)
2
Zone temp
24.1 °C
E+ 20.3 Δ+3.84
Heating SP
21.0 °C
Cooling SP
24.0 °C
Zone RH
59 %RH
E+ 59 Δ−0.1
Zone CO₂
742 ppm
E+ 718 Δ+23.8
Occ. heating SP
21.0 °C
Occ. cooling SP
24.0 °C
Occupancy sensor
OCCUPIED
Lighting
24.3 kW
E+ 24.5 Δ−0.22
Plug loads
24.4 kW
E+ 24.5 Δ−0.12
People (truth)
111 people
PMV (truth)
-1.64
E+ -1.48 Δ−0.158
(c) Terminal status
Terminal status
3
Zone temperature
24.1 °C E+ 20.3 Δ+3.84
Active heating SP
21.0 °C
Active cooling SP
24.0 °C
Airflow
69.8 m³/s E+ 69.5
Flow set point
71.8 m³/s
Damper cmd → pos
69 % → 67 % E+ 67
Reheat valve
0 % E+ 0
Zone mode
OCC
Terminal mode
COOLING
True occupants
111 people
4
PMV
-1.64 E+ -1.48
Low-flow alarm NORMAL
(d) Trends, 7-day window, truth overlay on
6h
24h
3d
7d
14d
Auto refresh
Truth overlay on: dashed lines = EnergyPlus
8
Clear
CSV
ZN-Core_mid/ZN-T
ZN-Core_mid/CLG-SP
ZN-Core_mid/PMV
ZN-Core_mid/ZN-T
ZN-Core_mid/ZN-T (truth)
ZN-Core_mid/CLG-SP
ZN-Core_mid/PMV
ZN-Core_mid/PMV (truth)
°C
28
26
24
22
20
18
5
6
0.5
0.0
-0.5
-1.0
-1.5
-2.0
7
10 Jul
11 Jul
12 Jul
13 Jul
14 Jul