


Visible is not the same as costly (one simulated year, Phoenix office):

Duct-insulation gap
visible (≥ 1 K) in 97 % of hours with air flow,
adds 1 % to the office's cooling

Wall insulation void
contrast reverses sign on 306 of 365 days,
adds 21 % to the wall's heat gain