

## RTU Preventative Maintenance Report

Job Number	8401L0070
Report Form Type	Preventative Maintenance
System Description	ISOSS SECURITY SYSTEM
Station Name	Ang Mo Kio Offtake / 192.169.1.1
Project No	1500
Customer	PUB
Report Title	RTU Preventative Maintenance Report

## RTU Maintenance Summary

Date of Service	26/11/2025 13:00
Cleaning of Cabinet	PENDING
Attended By	Thant
Approved By	Choong Hwee
Remarks	PMReportForm Server (RTU)

## Main RTU Cabinet Checks

### Cabinet #1

RTU Cabinet	Acceptable
Equipment Rack	Acceptable
Monitor	Acceptable
Mouse / Keyboard	NA
CPU 6000 Card	N/A
Input Card	Acceptable
Megapop NTU	Acceptable
Network Router	Acceptable
Network Switch	Acceptable
Digital Video Recorder	NonAcceptable
RTU Door Contact	Acceptable
Power Supply Unit	Acceptable
UPS Taking Over Test	Acceptable
UPS Battery	Acceptable
Remarks	N/A

### RTU Cabinet Images



# WILLOWGLEN

**Willowglen Services Pte Ltd**

103 Defu Lane 10, #05-01 Singapore 539223


Tel: (65) 6280 0437 Fax: (65) 6286 2002

Company Registration No: 198602842C

## Chamber Magnetic Contact

#	Chamber No.	OG Box	Contact 1	Contact 2	Contact 3	Remarks
1	2	FAIL	PASS	PASS	FAIL	N/A
2	1	PASS	PASS	PASS	PASS	N/A


## Chamber Images



## RTU Cabinet Cooling

#	Fan Number	Functional Status	Remarks
1	1	PASS	Cabinet Cooling Test
2	2	FAIL	Cabinet Cooling Test 2

## Cabinet Cooling Images



## DVR Equipment Checks

### DVR Set #1

DVR Communication	PASS
DVR RAID Communication	N/A
Time Sync (NTP)	PASS
Recording 24 x 7	PASS
Remarks	Equipment

### DVR Equipment Images

