

Preventative Maintenance (RTU)

Job Number	8401L0070
Report Form Type	Preventative Maintenance
System Description	ISOSS SECURITY SYSTEM
Station Name	Ang Mo Kio Offtake / 192.169.1.1
Project No	1500
Customer	PUB
Report Title	Preventative Maintenance (RTU)

RTU Maintenance Summary

Date of Service	26/11/2025 13:00
Cleaning of Cabinet	PENDING
Attended By	Thant
Approved By	Choong Hwee
Remarks	PMReportForm Server (RTU)

Thant

Attended By Signature

Choong Hwee

Approved By Signature

Main RTU Cabinet Checks

Cabinet #1

RTU Cabinet	Acceptable
Equipment Rack	Acceptable
Monitor	Acceptable
Mouse / Keyboard	NA
CPU 6000 Card	Acceptable
Input Card	Acceptable
Megapop NTU	Acceptable
Network Router	Acceptable
Network Switch	Acceptable
Digital Video Recorder	NonAcceptable
RTU Door Contact	Acceptable
Power Supply Unit	Acceptable
UPS Taking Over Test	Acceptable
UPS Battery	Acceptable
Remarks	N/A


RTU Cabinet Images



Chamber Magnetic Contact

Chamber No.	OG Box	Contact 1	Contact 2	Contact 3	Remarks
2	FAIL	PASS	PASS	FAIL	N/A
1	PASS	PASS	PASS	PASS	N/A

Chamber Images



RTU Cabinet Cooling

Fan Number	Functional Status	Remarks
1	PASS	Cabinet Cooling Test
2	FAIL	Cabinet Cooling Test 2

Cabinet Cooling Images



DVR Equipment Checks

DVR Set #1

DVR Communication	PASS
DVR RAID Communication	PASS
Time Sync (NTP)	PASS
Recording 24 x 7	PASS
Remarks	Equipment

DVR Equipment Images

