

ANNEXURE- A
c) BESCOM NOC



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

o: SEE/BRC/EE(O)/AEE(O)/AE(O)F-1(A) & F-22/ 2023-24/

ncl: One proposal file

119-22

Office of the

Superintending Engineer (Ele).

(C, O&M), B'lore Rural Circle,

BESCOM, TTMC, 1st floor

Kengeri, Bangalore - 560060

Ph No. 28482410

E-mail id: sebrce@bescom.co.in

Date: 05-4-2023

To:

M/s. Prestige Projects Pvt Ltd

Sy.No.13/2 and Others,

Chikkabanahalli village & Manduru Village,

Bidarahalli hobli

Bangalore East Taluk

Sir,

Sub: Issue of NOC to the proposed Residential Apartment purpose to an extent of 1000kVA in favour of M/s. Prestige Projects Pvt. Ltd., Sy. No 13/2 and Others, Chikkabanahalli Village & Mandura Village, Bangalore East Taluk

Ref: Consumer request letter No NIL dated 31.03.2023

With reference to the above, 'No Objection Certificate' from Bangalore Rural Circle, BESCOM is hereby issued for the proposed Residential apartment purpose to an extent of 1000kVA in favour of M/s. Prestige Projects Pvt. Ltd., Sy. No. 13/2 and others, Chikkabanahalli Village & Mandure Village, Bangalore East Taluk subject to the following conditions:

1. It is proposed to tap the existing 66 KV line from Hoodi RS to 66/11 KV AWHO MUSS. (LJLO)
2. You have to develop the infrastructure including the cost of 11kV lines etc., as mentioned above on Self execution basis through a Government Super Grade electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT line are passing through your premises for which NOC is to be obtained from the concerned authorities.
4. The installations existing shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said premises at the above address, all prevailing rules of KERSC at that time and conditions of supply shall be observed

6. BESCOM will not be held responsible for any liability arising from the issue of NOC.
7. Power supply shall be arranged to the said residential based on the provisions of regulation of BESCOM as applicable at the time.
8. This "NOC" is issued only for the purpose of obtaining sanction plan for proposed residential development from BDA/BBMP/Competent authorities and is not a commitment when applied for subject to feasibility at that time.
9. The approximate load requirement of the above building is 1000KVA.
10. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV sub-station inside the premises under self execution.
11. This NOC is valid for a period of Two years from the date of issues

Yours faithfully,


Superintendent Engineer (Elec),
B'lore Rural Circle, BESCOM

5/4/22