RentalEase
Ease Every Lease

2026

GAS SAFETY CHECK REPORT

03 5906 7723

www.rentalease.com.au

-Safety checks made easy
-Trades services
-Seamless software integration
-Ease for property managers.

Gas Compliance Report

Non-Compliant

Address:	123 Demo Street, Melbourne VIC 3000
Technician Details:	Demo Technician | Licence: LIC-DEMO-001
Assessment:	Non-Compliant
Inspection Date:	Wednesday 6 May 2026

Urgent / Mandatory Rectifications

- Issue Description: No rectification works required.
- Risk Level: non-urgent

Recommendations From Tradie

- Comments: Compliant demo response using local asset-backed report generation.

LP Gas Checklist

Item	Result
LP Gas cylinders and associated components (i.e. regulators, pigtails) installed correctly	Yes
Gas installation leakage test	Pass
Comments	Compliant demo response using local asset-backed report generation.



Gas Installation Photo - Gas Installation Photo demo photo (electrical-safety-cover.jpg)

General Gas Checks & Pressure Retention Test

Item	Result
Gas Pressure Test Result	Pass
Pressure Loss (5 min)	0
Comments	Compliant demo response using local asset-backed report generation.

Photo – Gas Meter - Photo – Gas Meter demo photo (electrical_safety_report_cover_page.jpg)

Pressure Test Photo - Pressure Test Photo demo photo (gas_safety_report_cover_page.jpg)

Appliance 1

Appliance Name	Demo response
Appliance Type	Cooktop
Location	Kitchen
Room Sealed Appliance	Yes

Installation & Safety Checks

Item	Result
Installation Gastight in accordance to AS/NZS 5601.1	Yes
Accessible for servicing	Yes
Isolation valve provided	Yes
Electrically safe	Yes
Evidence of certification (AGA / SAI / Global-Mark / BSI)	Yes
Where applicable are gas appliances including cookers adequately restrained from tipping over?	Yes
Adequate room ventilation	Yes
Where visible are clearances from combustible surfaces in accordance with the installation instructions and AS/NZS 5601.1?	Yes
Where applicable is the cowl, chimney plate or flue terminal in good condition and clear of obstruction?	Yes
Where applicable is the flue correctly installed & supported	Yes
No signs of scorching or overheating	Yes

Operational Checks

Item	Result
Where applicable is the heat exchanger condition satisfactory	Yes
Appliance cleaned of dust/debris	Yes
Gas supply & burner pressure correct	Yes
Burner flame normal	Yes
Is the appliance operating correctly including safety devices such as pressure and temperature relief valves?	Yes

Room Sealed Checks

Item	Result
Negative pressure present?	No
CO spillage test conducted?	Pass

Comments

Compliant demo response using local asset-backed report generation.

Appliance Photo - Gas Appliances demo photo (smoke_alarm_safety_report_cover_page.jpg)

Rectification Works Required

Item	Result
Issues Identified?	No
Issue Description	No rectification works required.
Risk Level	Non-Urgent

Rectification Photos - Rectification Photos demo photo (minimum_standard_report_cover_page.jpg)

Audit Declaration & Sign-Off

COMPLIANT

This gas safety report is prepared in accordance with the requirements contained in the Residential Tenancies Regulations 2021 and all other applicable standards and codes. It has been conducted by a gas fitter with Type A Servicing accreditation.

Technician Signature	Captured
Sign-Off Date	Wednesday 6 May 2026
Sign-Off Time	10:30
Declaration	This gas safety report is prepared in accordance with the Residential Tenancies Regulations 2021 and AS/NZS 5601.1. The compliance outcome above is calculated from the inspection findings and cannot be manually changed.

Inspector Observations and Suggestions

Generated compliant demo report using local assets.

Gas Installation Hazards and Compliance

Gas Safety (Gas Installation) Regulations 2018 — Part 3, Division 3, Section 21

If a gasfitter finds a dangerous defect in a gas installation, they must act immediately to make it safe and notify the property owner and occupier. If it's not possible or reasonable for the gasfitter to fix the issue themselves, they must promptly notify Energy Safe Victoria. They must also inform:

- the gas distribution company if the installation uses natural gas, or
- the gas retailer if the installation uses LPG.

This ensures that any hazardous situation is reported and addressed quickly, keeping the property safe and compliant.

Declaration and Certification

This gas compliance report summarises the inspection findings and certifies that the attending technician has performed the required checks and recommendations recorded below.

- AS 4575 Gas installations
- AS 3786:2014 Gas appliances
- Residential Tenancies Regulations 2021

I certify that this inspection has been conducted by a qualified inspector and the information contained in this report is true and accurate to the best of my knowledge at the time of inspection.

Inspector Certification:

Inspector Name:
Demo Technician
Date: Wednesday 6 May 2026

Next Compliance Schedule

Next Inspection Date	Saturday 6 May 2028
Regulations	This gas safety check has been completed in line with the Residential Tenancies Regulations 2021 and AS/NZS 5601.1: Gas Installations. It confirms appliances, pipework, and ventilation are operating safely and documents any defects that require corrective action.

RentalEase

Ease Every Lease