



RentalEase
Ease Every Lease

2026

GAS SAFETY CHECK REPORT



03 5906 7723



www.rentalease.com.au

- Safety checks made easy
- Trades services
- Seamless software integration
- Ease for property managers.

Gas Compliance Report Summary

Details

Property Address: 12 Sample Street, Melbourne VIC 3000

Date: Tuesday 31 March 2026

Property Details

Site Address 12 Sample Street

Suburb Melbourne

State VIC

Postcode 3000

Property Type Rental Property

Technician Details

Technician Full Name John Gasfitter

Licence / Registration Number GF-445566

Business Name RentalEase Property Services
Pty Ltd

Inspection Date Tuesday 31 March 2026

Inspection Time 09:30

LP Gas Checklist

Item	Result
LP Gas cylinders and associated components (i.e. regulators, pigtails) installed correctly	Yes
Gas installation leakage test	Pass
Comments	LP gas components installed correctly.

General Gas Checks & Pressure Retention Test

Item	Result
Gas Pressure Test Result	Pass
Pressure Loss (5 min)	0.2
Comments	Pressure retained within acceptable range.

Appliance 1

Appliance Name	Westinghouse Cooktop
Appliance Type	Cooktop
Location	Kitchen
Room Sealed Appliance	No

Installation & Safety Checks

Item	Result
	—
	—
	—
	—
	—
	—
	—
	—
	—

Operational Checks

Item	Result
	—
	—
	—
	—
	—

Comments
 Appliance operating normally.

Appliance 2

Appliance Name	Rinnai Hot Water Unit
Appliance Type	Instantaneous Hot Water
Location	Laundry
Room Sealed Appliance	Yes

Installation & Safety Checks

Item	Result
	—
	—
	—
	—
	—
	—
	—
	—
	—
	—

Operational Checks

Item	Result
	—
	—
	—
	—
	—

Room Sealed Checks

Item	Result
	—
	—

Comments

Room-sealed unit passed CO spillage test.

Rectification Works Required

Item	Result
Issues Identified?	Yes
Issue Description	Cooktop electrical isolation needs corrective work.
Risk Level	Non-Urgent

Audit Declaration & Sign-Off

NON-COMPLIANT

This gas safety report is prepared in accordance with the requirements contained in the Residential Tenancies Regulations 2021 and all other applicable standards and codes. It has been conducted by a gas fitter with Type A Servicing accreditation.

Technician Signature	Captured
Sign-Off Date	Tuesday 31 March 2026
Sign-Off Time	10:15
Technician	John Gasfitter
Declaration	This gas safety report is prepared in accordance with the Residential Tenancies Regulations 2021 and AS/NZS 5601.1.

Gas Installation Hazards and Compliance

Gas Safety (Gas Installation) Regulations 2018 — Part 3, Division 3, Section 21

If a gasfitter finds a dangerous defect in a gas installation, they must act immediately to make it safe and notify the property owner and occupier. If it's not possible or reasonable for the gasfitter to fix the issue themselves, they must promptly notify Energy Safe Victoria. They must also inform:

- the gas distribution company if the installation uses natural gas, or
- the gas retailer if the installation uses LPG.

This ensures that any hazardous situation is reported and addressed quickly, keeping the property safe and compliant.

Declaration and Certification

This gas compliance report summarises the inspection findings and certifies that the attending technician has performed the required checks and recommendations recorded below.

- AS 4575 Gas installations
- AS 3786:2014 Gas appliances
- Residential Tenancies Regulations 2021

I certify that this inspection has been conducted by a qualified inspector and the information contained in this report is true and accurate to the best of my knowledge.

Inspector Certification:

Inspector Name:

John Gasfitter

Date:

Tuesday 31 March 2026

' **Digitally Certified**

Next Compliance Schedule

Next Inspection Due: Friday 31 March 2028

This gas safety check has been completed in line with the Residential Tenancies Regulations 2021 and AS/NZS 5601.1: Gas Installations. It confirms appliances, pipework, and ventilation are operating safely and documents any defects that require corrective action.



