



CE/T&QC/MS-C-II/ 14848

Date 04/05/2026

To,
M/s. Epicast Power Equipments,
W-134A, MIDC, Ambad,
Nashik (M.S.) - 422010.

Sub: Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV Current Transformer (400-200-100/1-1-1A) under ongoing schemes in MSEDCL.

Ref:

1. Application Letter received to this office on dtd 02.04.2026.
2. Previous Approval vide ref CE/T& QC/MS C II/Epicast/No 7483 dt 31.03.2021.
3. CE Testing TTR-Validity circular dt 22.06.2020.
4. Office note F-2020011400/2020 dt.08.01.2021 & F-2022009125/2022 dt 19.09.2022.
5. Original TTR verification dt 06.04.2026.
6. Submission of corrected GTP & drawings on dt 15.04.2026.
7. Factory Inspection carried out on dt. 10.04.2026.
8. Approval from Competent Authority F-2026005473/2026 dt 22.04.2026 approved on 30.04.26.

Sir,

As per request furnished by you vide ref (1), this office has evaluated the proposal & pleased to accord the approval as approved vendor for supply of 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV Current Transformer (400-200-100/1-1-1A) under ongoing schemes in MSEDCL.

The submitted GTPs and drawings along with proposal are scrutinized in light of MSEDCL technical specification & relevant standard.

The List of drawings of above material under MSEDCL ongoing schemes are as follows.

111KV Metering Cubicle (Horizontal) with CT Ratios 10/5A, 25/5A & 50/5A with accuracy class 0.5s and 100/5A with accuracy class 0.2s and PT ratio 11kV/$\sqrt{3}$/110V/$\sqrt{3}$ with accuracy class 0.2			
Sr. No.	Title of the Drawing	Drawing No.	Sheet
1	General Arrangement Drawing for 11 KV HT Metering Cubicle	EP/11/ID/MTRCUB-1	1
2	Mounting arrangement for TVM & PQM meter in HT Horizontal Cubicle	EP/MTRCUB-METER	1

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

3	11 KV HT Metering cubicle details (Top View)	EP/11/MTRCUB-TOP VIEW	1
4	Foundation drawing for 11 KV Metering Panel	EP/11/ID/MTRCUB/FDN	1
5	Connection Diagram for 11 KV Metering Panel	EP/11/ID/SLD	1
6	Bill of Material for 11 KV HT Metering Cubicle	EP/11/ID/MTRCUB/BOM	1
7	Epoxy cast bushing of 11 KV Metering Cubicle	EP/11/ID/MTRCUB/ BUSHING	1
8	Overall dimensions of 11 KV Resin Cast CT of ratio 10/5A, 10VA/0.5s	EP/11/ID/CT/GAD/10	1
9	Overall dimensions of 11 KV Resin Cast CT of ratio 25/5A, 10VA/0.5s	EP/11/ID/CT/GAD/25	1
10	Overall dimensions of 11 KV Resin Cast CT of ratio 50/5A, 10VA/0.5s	EP/11/ID/CT/GAD/50	1
11	Overall dimensions of 11 KV Resin Cast CT of ratio 100/5A, 10VA/0.2s	EP/11/ID/CT/GAD/100	1
12	Name Plate details of CT	EP/11/ID/CT/NP	1
13	Overall dimensions of 11 KV Resin Cast PT of ratio 11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$, 50VA/0.2 accuracy class	EP/11/ID/PT/GAD	1
14	Name Plate details of PT	EP/11/ID/PT/NP	1
15	Name Plate details of 11 KV Metering Cubicle	EP/11/ID/MTRCUB/NP	1
16	Danger Board of 11 KV Metering Panel	EP/11/ID/MTRCUB/DB	1

OD Resin Cast (Cycloaliphatic) Dry Type CT-PT			
Sr. No.	Title of the Drawing	Drawing No.	Sheet
1	11KV OD Resin Cast Dry Type CT Ratio: 600-300/5-5A, VA/CL;15+15VA/5P10+0.2S		
1	General Arrangement Drawing	EP/11/OD/CT/GAD-300	1
2	Sectional drawing showing detail	EP/11/OD/CT/CS/300	1
3	Name Plate drawing	EP/11/OD/CT/NP/300	1
4	Arrangement of secondary terminal box & details of connection studs provided	EP/11/CT/DRY/SEC BOX	1
2	11KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S		
1	General Arrangement Drawing	EP/11/OD/CT/GAD-100	1
2	Sectional drawing showing detail	EP/11/OD/CT/CS/100	1
3	Name Plate drawing	EP/11/OD/CT/NP/100	1
4	Arrangement of secondary terminal box & details of connection studs provided	EP/11/CT/DRY/SEC BOX	1
3	11KV OD Resin Cast Dry Type PT Ratio: 11kV/$\sqrt{3}$/110V/$\sqrt{3}$ VA/CL; 50+50 VA/3P10+0.2		
1	General Arrangement Drawing	EP/11/OD/PT/GAD	1
2	Sectional drawing showing detail	EP/11/OD/PT/CS	1
3	Name Plate drawing	EP/11/OD/PT/NP	1
4	Arrangement of secondary terminal box & details of connection studs provided	EP/11/PT/DRY/SEC BOX	1
4	22KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S		
1	General Arrangement Drawing	EP/22/OD/CT/GAD-100	1
2	Sectional drawing showing detail	EP/22/OD/CT/CS/100	1
3	Name Plate drawing	EP/22/OD/CT/NP/100	1
4	Arrangement of secondary terminal box & details of connection studs provided	EP/22/CT/DRY/SEC BOX	1

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

5	33KV OD Resin Cast Dry Type CT Ratio: 400-200-100/1-1-1A, VA/CL;15+15VA/5P10+0.2S		
1	General Arrangement Drawing	EP/33/OD/CT/GAD-100	1
2	Sectional drawing showing detail	EP/33/OD/CT/CS/100	1
3	Name Plate drawing	EP/33/OD/CT/NP/100	1
4	Arrangement of secondary terminal box & details of connection studs provided	EP/33/CT/DRY/SEC BOX	1

The details Type Test Reports are as below.

1) 11 kV Metering Cubicle:-

S.N.	Test Details	Type Test Report No. & Date	Place of Testing
1)	11KV HT Outdoor Metering Cubicle (Horizontal)		
A	IP – 55 Test	RP-2021-014816 DT 30.09.2020.	ERDA, Vadodara
B	Temperature Rise Test	TEST/2021/TR/183 DT 04.02.2021.	
C	Short Time Withstand Current & Peak Withstand Current Test	RP-2021-014688 DT 29.09.2020.	
D	Wet Power Frequency Voltage withstand Test	RP-2021-018604 DT 04.11.2020.	NEC, Nashik
E	Lightning Impulse Voltage withstand Test	TEST/2021/TR/182 DT 04.02.2021.	
2)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 10/5A, 0.5S)		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/64 dt 07.09.20.	NEC, Nashik
B	Short Time Current test	RP-2021-021755 dt 07.12.20.	ERDA, Vadodara
C	Determination of Errors according to the requirements of the appropriate accuracy class	RP-2021-014722 dt 30.09.20.	ERDA, Vadodara
D	Instrument Security Factor Test	Test/20-21/TR/194 dt 19.02.2021.	NEC, Nashik
E	Temperature Rise Test	RP-2021-017174 dt 24.10.2020.	ERDA, Vadodara
3)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 25/5A, 0.5S)		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/65 dt 07.09.20.	NEC, Nashik
B	Short Time Current test	RP-2021-021452 dt 02.12.2020.	ERDA, Vadodara
C	Determination of Errors according to the requirements of the appropriate accuracy class	RP-2021-014725 dt 30.09.2020.	ERDA, Vadodara
D	Instrument Security Factor Test	Test/20-21/TR/195 dt 19.02.2021.	NEC, Nashik
E	Temperature Rise Test	RP-2021-017175 dt 24.10.2020.	ERDA, Vadodara
4)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 50/5A, 0.5S)		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/204 dt 19.02.21.	NEC, Nashik
B	Determination of Errors according to the requirements of the appropriate accuracy class		

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

C	Instrument Security Factor Test		
D	Temperature Rise Test	Test/20-21/TR/206 dt 19.02.21.	NEC, Nashik
E	Short Time Current test	RP-2021-021452 dt 02.12.2020.	ERDA, Vadodara
5)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 100/5A, 0.2S)		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/66 dt 07.09.20.	NEC, Nashik
B	Instrument Security Factor Test	Test/20-21/TR/196 dt 19.02.21.	
C	Temperature Rise Test	Test/20-21/TR/205 dt 21.01.21.	
D	Short Time Current test	RP-2021-021459 dt 04.12.2020.	ERDA, Vadodara
E	Determination of Errors according to the requirements of the appropriate accuracy class		
6)	Epoxy Resin Moulded Potential Transformer voltage Ratio: 11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ VA/CL; 50/0.2		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/67 dt 07.09.20.	NEC, Nashik
B	Determination of Errors according to the requirements of the appropriate accuracy class	Test/20-21/TR/68 dt 07.09.20.	
C	Power Frequency Dry withstand Test	ERTO/TRP/2021/0501 dt 06.11.20.	ERTO, Vadodara
D	Temperature Rise Test		
E	Short Time Withstand capability test	RP-2021-023708 dt 25.01.2021.	ERDA, Vadodara

2) **11KV OD Resin Cast (Cycloaliphatic) Dry Type CT-PT:-**

7)	11KV OD Resin Cast Dry Type CT Ratio: 600-300/5-5A, VA/CL;15+15VA/5P10+0.2S		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/60 dt 07.09.20.	NEC, Nashik
B	Test for accuracy	Test/20-21/TR/61 dt 07.09.20.	
C	Temperature Rise Test	Test/20-21/TR/62 dt 07.09.20.	
D	Short Time Current Test	RP-2021-015214 dt 07.10.2020.	ERDA, Vadodara
E	Wet Test for Outdoor Type Transformers	ERTO/TRP/2021/0423 dt 05.10.20.	ERTO, Vadodara
8)	11KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/58 dt 07.09.20.	NEC, Nashik
B	Test for accuracy	Test/20-21/TR/59 dt 07.09.20.	
C	Temperature Rise Test	Test/20-21/TR/80 dt 13.09.20.	
D	Short Time Current Test	RP-2021-015220 dt 07.10.2020.	ERDA, Vadodara
E	Wet Test for Outdoor Type Transformers	ERTO/TRP/2021/0524 dt 27.11.20.	ERTO, Vadodara
9)	11KV OD Resin Cast Dry Type PT Ratio: 11kV/$\sqrt{3}$/110V/$\sqrt{3}$ VA/CL; 50+50 VA/3P10+0.2		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/69 dt 07.09.20.	NEC, Nashik
B	Test for accuracy	Test/20-21/TR/70 dt 07.09.20.	
C	Short Time Current Test	RP-2021-023720 dt 28.01.2021.	ERDA, Vadodara

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

D	Wet Test for Outdoor Type Transformers	ERTO/TRP/2021/0500 dt 06.11.20.	ERTO, Vadodara
E	Temperature Rise Test		
10)	22KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/128 dt 30.11.20.	NEC, Nashik
B	Test for accuracy	RP-2021-022580 dt 16.12.2020.	ERDA, Vadodara
C	Temperature Rise Test	Test/20-21/TR/129 dt 30.11.20.	NEC, Nashik
D	Short Time Current Test	RP-2021-022580 dt 16.12.2020.	ERDA, Vadodara
E	Wet Test for Outdoor Type Transformers	ERTO/TRP/2021/0575 dt 14.12.20.	ERTO, Vadodara
11)	33KV OD Resin Cast Dry Type CT Ratio: 400-200-100/1-1-1A, VA/CL;15+15VA/5P10+0.2S		
A	Lightning Impulse Voltage withstand Test	Test/20-21/TR/55 dt 07.09.20.	NEC, Nashik
B	Test for accuracy	Test/20-21/TR/57 dt 07.09.20.	
C	Temperature Rise Test	Test/20-21/TR/56 dt 07.09.20.	
D	Short Time Current Test	RP-2021-014817 dt 07.10.2020.	ERDA, Vadodara
E	Wet Test for Outdoor Type Transformers	ERTO/TRP/2021/0424 dt 05.10.20.	ERTO, Vadodara

In view of the above, the proposal submitted by M/s. Epicast Power Equipments, MIDC, Ambad, Nashik to 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV Current Transformer (400-200-100/1-1-1A) under ongoing schemes in MSEDCL is accorded approval on following terms and conditions:

- All routine and acceptance tests on 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV Current Transformer (400-200-100/1-1-1A) shall be carried out as per latest relevant IS/IEC at supplier's factory in presence of concerned Executive Engineer (Testing Division), MSEDCL before dispatch.
- This approval shall not be considered for technical/commercial evaluation of any ongoing and future tender in MSEDCL.
- Unconditional Performance guarantee of Five years shall be given in writing to the end consumer.
- The procedure for inspection shall be adopted scrupulously as per relevant IS and MSEDCL technical specification.
- The Guaranteed Technical Particulars of the 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV Current Transformer (400-200-100/1-1-1A) should be strictly in accordance with the approved GTP, drawings, MSEDCL technical specifications & relevant IS/IEC standards (amended up to date).
- To maintain the same design & construction parameters of 11 kV HT Metering Cubicle (Horizontal), 11 KV OD Dry Type Potential Transformer, 11KV Current Transformer (600-300/5-5A, 400-200-100/5-5A), 22KV Current Transformer (400-200-100/5-5A) and 33 KV

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

Current Transformer (400-200-100/1-1-1A) to be supplied under ongoing schemes as per approved GTP & drawings only.

g) This approval shall not relieve Vendor from responsibilities and liabilities for ensuring correctness of the drawings and correct interpretation for meeting the requirements as per tender technical specifications and specified standards amended up to date.

h) The validity of Approval will be as follows:

S.N.	Particulars of Item	Validity
1	11KV HT Outdoor Metering Cubicle (Horizontal)	Vendor approval shall remain valid till validity of Type Test Reports i.e. up to 06.09.2027.
(i)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 10/5A, 0.5S)	
(ii)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 25/5A, 0.5S)	
(iii)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 50/5A, 0.5S)	
(iv)	11kV Epoxy Resin Moulded Current Transformer (Ratio: 100/5A, 0.2S)	
(v)	Epoxy Resin Moulded Potential Transformer voltage Ratio: 11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ VA/CL; 50/0.2	
2	OD Resin Cast (Cycloaliphatic) Dry Type CT-PT:-	Vendor approval shall remain valid till validity of Type Test Reports i.e. up to 06.09.2027.
(i)	11KV OD Resin Cast Dry Type CT Ratio: 600-300/5-5A, VA/CL;15+15VA/5P10+0.2S	
(ii)	11KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S	
(iii)	11KV OD Resin Cast Dry Type PT Ratio: 11kV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ VA/CL; 50+50 VA/3P10+0.2	
(iv)	22KV OD Resin Cast Dry Type CT Ratio: 400-200-100/5-5A, VA/CL;15+15VA/5P10+0.2S	
(v)	33KV OD Resin Cast Dry Type CT Ratio: 400-200-100/1-1-1A, VA/CL;15+15VA/5P10+0.2S	

One set of approved GTP & drawings duly signed & stamped is enclosed herewith.

This approval is issued without prejudice to all other terms and conditions of the tender under ongoing schemes.

Thanking You.

Yours faithfully



Dr. M. G. Wath
Chief Engineer (Testing & QC)
MSEDCL, MUMBAI.

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.

Copy s.w.r.to

The Director (Operations), MSEDCL, Mumbai

Copy fwc to:

Chief Engineer (O&M), All Zones.

Copy to:

- 1) Superintending Engineer (O&M), All Circles.
- 2) Superintending Engineer TQA (Kalyan/Pune/Nagpur/Aurangabad)

Vendor approval to M/s Epicast Power Equipments, MIDC, Ambad, Nashik for supply of 11 kV HT Metering Cubicle (Horizontal) & OD Resin Cast Dry Type CT & PT.