

Disclaimer: This is an automatically generated electronic document which requires no signature. The generated report specifies information regarding compliance of parameters against Unified Development Control and Promotion Regulations for THE HARYANA BUILDING CODE, 2017

Building Type : Industrial Building

AIN:

Details of Application						
Proposal Details				Consumer Details		
Reference Scrutiny Number		SCR-108		LandType		Industrial Building
Case Type		Fresh		District		
Date of Scrutiny		11/24/2023 4:17:48 PM		Purpose		
Building Category		Industrial Building		File Number		
Core Area		Other than Core Area		Applicant Name		
Building Sub Category		General Industry		Activity		
Type of Building		Detached		Revenue Estate		
Purchasable FAR		No		Control Area		
Warehouse Type				Plot Area		
Applicant Details				License Number		
Name		NAYANTARA		Case Number		
Address		Indira Nagar		Developer name		
E-Mail Address		farida123@gmail.com		Development Plan		
Contact No		7894561250		Sector		
Architect Details				Colony		
Name of Architect		Smith		Area of Land (Plot Area)		
Address		Faridabad		As per Physical Possession		
E-Mail Address		haryana123@gmail.com		As per Drawing		1563.41
Registration Number		ALOOT0007				
Contact No		8945612378				
Building Category Details						
Block Name	Building Category	Building Height	Total number of Floors	Total Builtup Area	Non FAR Area in all Floor	FAR Area
Single	INDUSTRIAL	12.39	BF-1 + Ground + 2 Floors	3269.22	940.73	2328.49
				3269.22	940.73	2328.49
Parameter List as per Rules						
Section	Parameter		Min	Max	Provided	As per HBC Rules
-	Net Plot Area		N.A.	N.A.	1563.41	N.A
-	Road Width		N.A.	N.A.	24.00	N.A
6.3.3 (1(iv))	Building Height		N.A.	30.00	12.39	Yes
6.3.3 (1(iv))	FAR		N.A.	1.50	1.49	Yes
6.3.3 (1(iv))	Ground Coverage(In Percentage)		N.A.	60.00	57.25	Yes
-	Coverage Area		N.A.	938.05	894.99	N.A.
-	Frontsetback		N.A.	N.A.	5.03	Yes
-	Side1setback		N.A.	N.A.	5.94	Yes

Disclaimer: This is an automatically generated electronic document which requires no signature. The generated report specifies information regarding compliance of parameters against Unified Development Control and Promotion Regulations for THE HARYANA BUILDING CODE, 2017

-	Side2setback	N.A.	N.A.	4.00	Yes
-	RearSetback	N.A.	N.A.	3.51	Yes
-	Floor Area (For FAR)	N.A.	2,345.12	2,328.49	Yes

Basement Setbacks												
Block Name	FSB Required	FSB Provided	FSB HBC Rules	SSB1 Required	SSB1 Provided	SSB1 HBC Rules	SSB2 Required	SSB2 Provided	SSB2 HBC Rules	RSB Required	RSB Provided	RSB HBC Rules
Single	1.80	5.03	Yes	1.8	5.94	Yes	1.8	4	Yes	1.8	3.51	Yes

Secondary Parameter					
Section	Parameter	Min	Max	Provided	As per HBC Rules
	No.of Basement	N.A	2	1	Yes
-	Compound Wall Height in Front(open)	N.A	N.A	1.20	N.A
-	Compound Wall Height in Side1	N.A	N.A	1.00	N.A
-	Compound Wall Height in Side2	N.A	N.A	1.00	N.A
-	Compound Wall Height in Rear	N.A	N.A	1.00	N.A
-	Gate Width	N.A.	N.A.	3.65	N.A.
-	Parapet wall Height	N.A	1.2	1.00	Yes
-	Plinth Height	0.45	1.5	0.75	Yes 1
-	Lift Lobby	1.80 x 2.00	N.A.	2.21 x 2.13	Yes 8

Floorwise Breakup										
Block Name	Floor Name	Total Area	Deduction	Non FAR Area	Builtup (FAR) Area					
					Res	Com	Ind	Ins	Edu	Existing
Single	FLOOR-BF	859.11	-	859.11	-	-	-	-	-	-
	FLOOR-GROUND	894.99	-	28.11	-	-	866.88	-	-	-
	FLOOR01	894.99	-	35.87	-	-	859.12	-	-	-
	FLOOR02	620.13	-	17.64	-	-	602.49	-	-	-
	Total	3,269.22	-	940.73	-	-	2,328.49	-	-	-

List of Non FAR			
Block Name	Floor Name	Non FAR	Area
Single	FLOOR-BF	PARKING	859.11
Total	-	-	859.11

ECS Parking Required				
Section	Category	FAR Area/Covered Area (Sq.m.)/Dwell Count	ECS Calculation	Required ECS
	INDUSTRIAL	2328.49	300	7.76

ECS Parking Provided				
Section	Parking	Provided Area	ECS Calculation	ECS
	Space for Car (Basement Parking)	814.6565	@ 32	25.46

Disclaimer: This is an automatically generated electronic document which requires no signature. The generated report specifies information regarding compliance of parameters against Unified Development Control and Promotion Regulations for THE HARYANA BUILDING CODE, 2017

ECS Parking Provided				
Section	Parking	Provided Area	ECS Calculation	ECS
Total		814.66		25.46
Summary		Required ECS = 7.76	Provided ECS = 25.46	Result = Yes

Area and Dimensions Details							
Typical Block	Typical Floor	Dwelling Unit	Parameter	Min	Max	Provided	As per HBC Rules
Single	FLOOR01	-	WaterCloset Area	1.1	N.A.	2.32	Yes...4
			WaterCloset Height	2.45	N.A.	3.65	Yes...4
			WaterCloset Width	0.9	N.A.	1.52	Yes...4
	FLOOR02	-	WaterCloset Area	1.1	N.A.	2.32	Yes...4
			WaterCloset Height	2.45	N.A.	3.65	Yes...4
			WaterCloset Width	0.9	N.A.	1.52	Yes...4
	FLOOR-GROUND	-	WaterCloset Area	1.1	N.A.	2.32	Yes...4
			WaterCloset Height	2.45	N.A.	3.65	Yes...4
			WaterCloset Width	0.9	N.A.	1.52	Yes...4

Staircase Details					
Block Name	Floor Name	Staircase Name	Minimum Staircase Width Required	Staircase Width Provided	Staircase Width As per HBC Rules
Single	FLOOR02	STAIR-02	1.5	1.52	Yes
Single	FLOOR02	STAIR-01	1.5	1.52	Yes
Single	FLOOR01	STAIR-02	1.5	1.52	Yes
Single	FLOOR01	STAIR-01	1.5	1.52	Yes
Single	FLOOR-GROUND	STAIR-02	1.5	1.52	Yes
Single	FLOOR-GROUND	STAIR-01	1.5	1.52	Yes
Single	FLOOR-BF	STAIR-02	1.5	1.52	Yes
Single	FLOOR-BF	STAIR-01	1.5	1.52	Yes

Disclaimer: This is an automatically generated electronic document which requires no signature. The generated report specifies information regarding compliance of parameters against Unified Development Control and Promotion Regulations for THE HARYANA BUILDING CODE, 2017

Tread/Riser Details								
Block Name	Floor Name	Staircase Name	Minimum Tread Required	Tread Provided	Tread HBC Rules	Maximum Riser Allowable	Riser Provided	Riser - As per HBC Rules
Single	FLOOR02	STAIR-02	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR02	STAIR-01	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR01	STAIR-02	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR01	STAIR-01	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR-GROUND	STAIR-02	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR-GROUND	STAIR-01	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR-BF	STAIR-02	0.3	0.30	Yes	0.15	0.15	Yes
Single	FLOOR-BF	STAIR-01	0.3	0.30	Yes	0.15	0.15	Yes

Lift Details									
Block Name	Floor Name	Lift Name	No.of Persons	Min Depth	Depth Provided	Depth HBC Rules	Min Width	Width Provided	Width HBC Rules
Single	FLOOR02	Lift - 02PH		1.1	2.21	Yes	2	2	Yes
Single	FLOOR02	Lift Doorway	-	-	-		0.9	1.07	Yes
Single	FLOOR02	Lift - 01		N.A.	1.83	N.A.	N.A.	1.83	N.A.
Single	FLOOR01	Lift - 02PH		1.1	2.21	Yes	2	2	Yes
Single	FLOOR01	Lift Doorway	-	-	-		0.9	1.07	Yes
Single	FLOOR01	Lift - 01		N.A.	1.83	N.A.	N.A.	1.83	N.A.
Single	FLOOR-GROUND	Lift - 02PH		1.1	2.21	Yes	2	2	Yes
Single	FLOOR-GROUND	Lift Doorway	-	-	-		0.9	1.07	Yes
Single	FLOOR-GROUND	Lift - 01		N.A.	1.83	N.A.	N.A.	1.83	N.A.
Single	FLOOR-BF	Lift - 02PH		1.1	2.21	Yes	2	2	Yes
Single	FLOOR-BF	Lift Doorway	-	-	-		0.9	1.07	Yes
Single	FLOOR-BF	Lift - 01		N.A.	1.83	N.A.	N.A.	1.83	N.A.

Number of Steps per Staircase Flight					
Block Name	Floor Name	Staircase Reference	Maximum	Provided	As per HBC Rules
Single	FLOOR02	STAIR-02	14	7	Yes
Single	FLOOR02	STAIR-02	14	10	Yes
Single	FLOOR02	STAIR-02	14	10	Yes
Single	FLOOR02	STAIR-01	14	10	Yes
Single	FLOOR02	STAIR-01	14	7	Yes

Disclaimer: This is an automatically generated electronic document which requires no signature. The generated report specifies information regarding compliance of parameters against Unified Development Control and Promotion Regulations for THE HARYANA BUILDING CODE, 2017

Number of Steps per Staircase Flight					
Block Name	Floor Name	Staircase Reference	Maximum	Provided	As per HBC Rules
Single	FLOOR02	STAIR-01	14	10	Yes
Single	FLOOR01	STAIR-02	14	7	Yes
Single	FLOOR01	STAIR-02	14	10	Yes
Single	FLOOR01	STAIR-02	14	10	Yes
Single	FLOOR01	STAIR-01	14	10	Yes
Single	FLOOR01	STAIR-01	14	7	Yes
Single	FLOOR01	STAIR-01	14	10	Yes
Single	FLOOR-GROUND	STAIR-02	14	7	Yes
Single	FLOOR-GROUND	STAIR-02	14	9	Yes
Single	FLOOR-GROUND	STAIR-02	14	9	Yes
Single	FLOOR-GROUND	STAIR-01	14	10	Yes
Single	FLOOR-GROUND	STAIR-01	14	7	Yes
Single	FLOOR-GROUND	STAIR-01	14	10	Yes
Single	FLOOR-BF	STAIR-02	14	7	Yes
Single	FLOOR-BF	STAIR-02	14	7	Yes
Single	FLOOR-BF	STAIR-02	14	8	Yes
Single	FLOOR-BF	STAIR-01	14	8	Yes
Single	FLOOR-BF	STAIR-01	14	7	Yes
Single	FLOOR-BF	STAIR-01	14	7	Yes