SIGNAL LIST - MACHINERY (EU EXPORT)

Decimal comma, thousands dot, combined range column

Pos	Tag No.	Service	Eng. unit	Range	LL	L	H	HH	Delay [s]	Signal
1	TANK-OWS1-XA02	Separator alarm 2								Digital in
2	ME-HPU1-PT01	Hydraulic power unit pressure 1	bar(g)	0 … 400	44	80	320		15	4-20mA
3	ME-HPU1-PT02	Hydraulic power unit pressure 2	bar(g)	0 … 400	20	60	300		3	4-20mA
4	ME-HPU1-PT03	Hydraulic power unit pressure 3	bar	0 … 400	20	60	300		3	4-20mA
5	ME-HPU1-TT01	Hydraulic oil temperature 1	°C	0 … 100			85	88	10	Pt100
6	ME-HPU1-TT02	Hydraulic oil temperature 2	degC	0 … 100			75	92	3	4-20mA
7	ME-HPU1-LT01	Hydraulic oil tank level	%	0 … 100	8	15			30	4-20mA
8	ME-HPU1-XS01	Hydraulic pump 1 running								Digital in
9	ME-HPU1-XS02	Hydraulic pump 2 running								Digital in
10	ME-HPU1-XS03	Hydraulic pump 3 running								Digital in
11	ME-HPU1-XS04	Hydraulic pump 4 running								Digital in
12	ME-CPD1-PT01	Cylinder pressure indicator 1	barg	0 … 200			170		5	4-20mA
13	ME-CPD1-PT02	Cylinder pressure indicator 2	barg	0 … 200			170		10	4-20mA
14	ME-CPD1-PT03	Cylinder pressure indicator 3	bar	0 … 200			160		30	4-20mA
15	ME-CPD1-PT04	Cylinder pressure indicator 4	barg	0 … 200			150		10	4-20mA
16	ME-CPD1-TT01	Cylinder liner temperature 1	degC	0 … 300			225	264	30	Pt100
17	ME-CPD1-TT02	Cylinder liner temperature 2	degC	0 … 300			225	288	30	Pt100
18	ME-CPD1-TT03	Cylinder liner temperature 3	degC	0 … 300			255	288	30	4-20mA
19	ME-CPD1-TT04	Cylinder liner temperature 4	degC	0 … 300			225	288	0	Pt100
20	ME-CPD1-VT01	Cylinder block vibration 1	mm/s	0 … 50			37,5	46	15	4-20mA
21	ME-CPD1-VT02	Cylinder block vibration 2	mm/s	0 … 50			37,5	44	5	4-20mA
22	AE-SCV1-TT01	Scavenge air temperature 1	degC	0 … 150			112	132	5	4-20mA
23	AE-SCV1-TT02	Scavenge air temperature 2	°C	0 … 150			128	138	15	Pt100
24	AE-SCV1-TT03	Scavenge air temperature 3	degC	0 … 150			120	138	2	4-20mA

INSTRUMENT INDEX (US EXPORT)

Decimal point, thousands comma, Min/Max and Lo-Lo..Hi-Hi columns

Tag	Description	Type	Units	Min	Max	Lo-Lo	Lo	Hi	Hi-Hi	Delay (s)
AE-SCV1-PT01	Scavenge air pressure 1	AI	bar	0	4		1	3.2		10
AE-SCV1-PT02	Scavenge air pressure 2	AI	bar g	0	4		0.8	3		2
AE-SCV1-PT03	Scavenge air pressure 3	AI	bar	0	4		1	3.2		10
AE-SCV1-ST01	Turbocharger speed 1	AI	rpm	0	40,000			30,000	38,400	10
AE-SCV1-ST02	Turbocharger speed 2	AI	rpm	0	40,000			34,000	38,400	2
BLR-SPH1-TT01	Steam superheater outlet temperature 1	AI	°C	0	450			360	432	30
BLR-SPH1-TT02	Steam superheater outlet temperature 2	AI	deg C	0	450			360	396	30
BLR-SPH1-TT03	Steam superheater outlet temperature 3	AI	°C	0	450			360	396	10
BLR-SPH1-PT01	Steam header pressure 1	AI	bar	0	25		6.2	21.2	23	15
BLR-SPH1-PT02	Steam header pressure 2	AI	bar	0	25		3.8	21.2	23	15
BLR-SPH1-PT03	Steam header pressure 3	AI	bar g	0	25		6.2	21.2	23	10
BLR-SPH1-FT01	Steam flow 1	AI	t/hr	0	40.5			34.4		5
BLR-SPH1-FT02	Steam flow 2	AI	t/h	0	40.5			34.4		10
PMS-UPS1-VT01	UPS battery voltage 1	AI	V	0	300	33	60	225		3
PMS-UPS1-VT02	UPS battery voltage 2	AI	V	0	300	15	60	255		5
PMS-UPS1-VT03	UPS battery voltage 3	AI	V	0	300	24	75	225		3
PMS-UPS1-II01	UPS output current 1	AI	A	0	200			160		3
PMS-UPS1-II02	UPS output current 2	AI	A	0	200			150		30
PMS-UPS1-II03	UPS output current 3	AI	A	0	200			170		10
PMS-UPS1-TT01	UPS cabinet temperature 1	AI	°C	0	80			68	73.6	10
PMS-UPS1-TT02	UPS cabinet temperature 2	AI	°C	0	80			64	73.6	2
PMS-UPS1-XA01	UPS alarm 1	DI								
PMS-UPS1-XA02	UPS alarm 2	DI								
PMS-UPS1-XA03	UPS alarm 3	DI								

ALARM SCHEDULE (COMPACT)

No borders, decimal comma, span in a single cell

Tag	Description	Unit	Span	HH	H	L	LL	Delay	I/O
BWTS-CHM1-LT01	Neutralising chemical tank level 1	pct	0-100			15	11	0	Analog in
BWTS-CHM1-LT02	Neutralising chemical tank level 2	%	0-100			20	8	10	Analog in
ME-SCR2-AT01	NOx analyser reading 1 (bank 2)	PPM	0-2000	1920	1500			10	Analog in
ME-SCR2-AT02	NOx analyser reading 2 (bank 2)	PPM	0-2000	1760	1500			5	Analog in
ME-EGR2-ST01	EGR blower speed (bank 2)	rpm	0-12000	10560	9000			15	Analog in
BLR-BRN2-TT01	Burner flame temperature 1 (bank 2)	C	0-1200	1056	960			5	Analog in
BLR-BRN2-TT02	Burner flame temperature 2 (bank 2)	°C	0-1200	1104	900			10	Analog in
BLR-BRN2-TT03	Burner flame temperature 3 (bank 2)	°C	0-1200	1152	900			10	Analog in
BLR-BRN2-ST01	Burner fan speed 1 (bank 2)	rpm	0-3600	3168	2700			10	Analog in
BLR-BRN2-ST02	Burner fan speed 2 (bank 2)	rpm	0-3600	3456	2700			0	Analog in
BLR-BRN2-FT01	Burner fuel flow 1 (bank 2)	kg/h	0-1500,5		1275			5	Analog in
BLR-BRN2-FT02	Burner fuel flow 2 (bank 2)	kg/h	0-1500,5		1125			5	Analog in