
process start
Starting
BuildSim healthy,
MQTT connected
Syncing
retained states received /
equipment registered
Running
SIGTERM
inputs bad (gateway offline,
> 20 % zones stale, BuildSim
unreachable)
Degraded
SIGTERM
Stopping
tick finished,
"offline" published
Stopped
inputs recover
crash: last will "offline",
or watchdog exit after 120 s