
process start
Starting
BuildSim healthy, MQTT connected
Syncing
retained states received / equipment registered
Running
inputs bad: broker lost, gateway offline, > 20 % zones stale, BuildSim unreachable
Degraded
inputs recover (reconnected, fresh readings)
Network drop: reconnect every 1–10 s, re-subscribe, re-publish the status; QoS 1 commands wait in a queue. Meanwhile the last will says "offline"; the agent keeps all water on while Degraded.
SIGTERM
SIGTERM
Stopping
tick finished, "offline" published
Stopped
crash: last will "offline", or watchdog exit after 120 s