

rede BT Analógico Energia 555327 v	TC-08 medidor 15000 via RS485	DG 125 A 10000, 1000 v	DPS DPS Onipac 7 220 VAC, 3P+N	QDG QDG60 gen2 (4x modulos) 50 modulos 4 x 150 W
---	--	----------------------------------	--	---

[illegible]

QDS — Quadro superior 48 modulos - 22 circuitos - 37 vias (+20 % = 45) de 48

ACQUOTO	QO	TEPO	VA	V	FASE	RA	DEL	mm2	ELETTR.	L.W	0.01
TUR-VE	005	ter	7400	220	A-B	35.6	40.4 20 P	5	DN25	1.1	0.90
TUR-22	005	ter	7400	220	A-C	35.6	40.4 20 P	6	DN25	20.9	1.80
TUR-1	005	ter	4000	220	A-B	20.9	25.4 20 P	4	DN25	1.2	0.90
TUR-2	005	ter	4000	220	A-C	20.9	25.4 20 P	4	DN25	17.8	1.42
TUR-3	005	ter	4000	220	A-B	20.9	25.4 20 P	4	DN25	17.2	1.38
TUR-4	005	ter	4000	220	A-C	20.9	25.4 20 P	4	DN25	32.2	0.82
TUR-5	005	ter	3000	220	A-B	15.8	18.4 20 P	2.5	DN20	18.9	1.82
TUR-7 (GSD)	005	ter	2700	220	A-B	13.8	15.4 20 P	4	DN20	3.8	0.82
TUR-10	005	ter	2700	220	A-C	13.8	15.4 20 P	3.5	DN20	36.2	1.25
TUR-T-C02	005	ter	2000	127	B	10.7	20.4 10 P	4	DN25	22.5	0.94
TUR-6	005	ter	2000	127	A-C	10.7	15.4 20 P	2.5	DN20	12.8	0.84
TUR-T-C03	005	ter	2000	127	A-B	10.7	15.4 20 P	2.5	DN20	16.2	0.94
TUR-T-L40	005	ter	1000	127	A	10.0	18.4 10 P	2.5	DN20	18.4	2.08
TUR-T-DEP	005	ter	1000	127	B	10.2	20.4 10 P	2.5	DN20	20.4	5.13
TUR-12	005	ter	1000	127	C	11.8	18.4 10 P	2.5	DN20	22.4	2.07
TUR-14	005	ter	1000	127	B	11.8	18.4 10 P	2.5	DN20	17.4	2.06
TUR-6	005	ter	1400	220	A-A	8.4	15.4 20 P	5.5	DN20	17.4	0.90
TUR-7	005	ter	1400	220	A-C	8.4	15.4 20 P	2.5	DN20	17.3	0.90
TUR-8	005	ter	1400	220	A-B	8.4	15.4 20 P	2.5	DN20	14.3	0.97
TUR-9	005	ter	1400	220	A-C	8.4	15.4 20 P	2.5	DN20	11.6	0.96
TUR-5 (MAG)	005	ter	1000	127	B	7.1	15.4 10 P	2.5	DN20	18.9	1.40
TUR-11	005	ter	1000	127	C	7.9	15.4 10 P	2.5	DN20	18.9	1.40
TUR-T-GAR	005	ter	800	127	A	7.1	15.4 10 P	1.5	DN20	14.3	1.00
TUR-16	005	ter	800	127	B	7.1	15.4 10 P	2.5	DN20	25.4	1.00
TUR-T-G04	005	ter	800	127	C	8.4	15.4 10 P	1.5	DN20	36.4	0.86
TUR-17	005	ter	800	127	A	7.1	15.4 10 P	1.5	DN20	25.4	1.00
TUR-14	005	ter	800	220	A-B	5.6	15.4 20 P	2.5	DN20	9.2	0.21
TUR-T-D02	005	ter	700	220	A-C	3.2	15.4 20 P	2.5	DN20	36.4	0.76
TUR-T-D03	005	ter	800	127	B	4.7	20.4 10 P	1.5	DN20	35.1	0.43
TUR-T-D04	005	ter	800	127	A	4.7	20.4 10 P	1.5	DN20	29.7	1.77
TUR-T-S03	005	ter	600	127	C	4.7	20.4 10 P	1.5	DN20	25.4	1.77
TUR-T-S04	005	ter	600	127	B	4.7	20.4 10 P	2.5	DN20	12.2	0.22
TUR-T-GAR	005	ter	500	127	A	3.9	20.4 10 P	2.5	DN20	11.2	0.46
TUR-T-CH	005	ter	500	127	C	3.9	20.4 10 P	3.5	DN20	12.3	0.61
TUR-T-F02	005	ter	500	127	B	3.9	20.4 10 P	2.5	DN20	25.4	0.61
TUR-T-G02	005	ter	500	127	C	3.9	20.4 10 P	1.5	DN20	27.4	1.06
TUR-T-S02	005	ter	500	127	A	3.9	20.4 10 P	2.5	DN20	22.1	0.90
TUR-T-S03	005	ter	500	127	B	3.9	20.4 10 P				

CIRCUITO	QO	TIPO	VA	V	FASE	ItA	DIG2	mm2	ELET.	L m	dV %	
ILU-T-GEP	Q06	Ilum	100	127	A	0.8	3/8 A 1P	1.5	DN20	25.1	0.30	
ILU-S-CR	Q05	Ilum	100	127	B	0.8	3/8 A 1P	1.5	DN20	9.3	0.13	
ILU-S-C2	Q05	Ilum	100	127	C	0.8	3/8 A 1P	1.5	DN20	16.3	0.23	

QO	NOME	CRC	VA	VA POR FASE A/B/C	DR	VIAS	+20 %	TEM	
QOG	Quadro geral 64 módulos	41	54550	20000 / 15000 / 10750	2	67	81	04	cabé
QOS	Quadro superior 48 módulos	22	25100	6950 / 10750 / 7800	1	37	45	48	cabé

- DR 30 mA para banhos, cocineta, lavanderia, garagem, área externa e chuveiros; DPS classe II no QDC

800.455.4600 (TOLL FREE)

60

de 75 REV REG