Weather Format

The following information was published at the "Building Simulation '99" conference in September 1999. The paper was entitled "Improving the Weather Information Available to Simulation Programs" by D. Crawley, J. Hand, and L. Lawrie.

INTRODUCTION

All building simulation programs employ some means of representing local climatic conditions relative to the building models. For example, Radiance (Ward 1996) needs a description of sky conditions and illuminance values to calculate solar distribution through a window and within a space. Three of the widely used energy simulation programs in the UK and US, ESP-r (ESRU 1999), BLAST (UI 1998), and DOE-2 (Winkelmann et al. 1993) also use weather conditions to simulate the response of a building. But even after 30 years of significant development advances in simulation capabilities, these programs use the same climate representations as in the past—a simple set of hourly temperature, humidity, wind speed and direction, and atmospheric pressure and solar radiation or cloud cover data. These data are often 'typical' data derived from hourly observations at a specific location by the national weather service or meteorological office. Examples of these typical data include TMY2 (NREL 1995) and WYEC2 (ASHRAE 1997) in the United States and Canada and TRY (CEC 1985) in Europe. The TMY2 and WYEC2 typical weather years contain more solar radiation and illumination data than older formats such as TMY (NCDC 1983), WYEC (ASHRAE 1985), and TRY (NCDC 1981) in the U.S. Crawley (1998) demonstrated that the methods used to select data for the TMY2 and TRY data sets better fit the long-term climate patterns.

Radiation and illumination data are becoming increasingly necessary in simulation programs. Anyone who has ever attempted to measure daylight factors will be familiar with the fluctuations in lighting levels under partly cloudy conditions. The expansion and contraction of lightweight building components also shares sensitivity to rapid fluctuations in solar radiation. Single-sided ventilation is dependant on wind pressure fluctuations and pedestrians in many cities are acquainted with the disarming tendency of the wind to guest and change direction. It is increasingly the case that design questions touch on such issues.

In a research context, the advent of tools such as LabVIEW (National Instruments Corporation 1999) have made it possible for increasing numbers of researchers to acquire and process test-cell data. The increasing use of building energy management systems (BEMS) has also provided high frequency information from which simulation could be used as a predictive tool for future control strategies. Other issues of control, particularly of advanced daylighting control require sub-hourly illumination data to ensure that possible control regimes are tested under realistic conditions. Janak (1997) observed that the differences between 5 minute and hourly illumination data could result in prediction variations approaching 40%.

Thus far, projects that mix empirical and simulation-based work have had to store and access such data via temporal database facilities (ESRU 1999). As the number of high quality datasets increases so does the need to encapsulate such information in a form that can be broadly distributed. The simulation community must also consider the uncertainty in high frequency performance predictions that are based on boundary conditions that have been sampled at one or two magnitudes less temporal resolution.

The simulation community must also consider practitioner demands and issues of quality assurance. Someone who is not a native of Copenhagen may not know that there are three or four recognizable patterns of winter weather that should be included in detailed assessments. A data set that lacks documentation or is dependent on separately held lists of assumptions can be effectively useless.

In the absence of data within the weather data format, the simulation programs must calculate these data often with older calculation methods. As the simulation programs have become more capable, data at hourly resolution is no longer enough—interpolating between hourly

observations does not accurately represent weather conditions that change much more frequently such as illumination.

We have developed a new, generalized weather data format for use by energy simulation programs has been developed and adopted by both ESP-r (in the UK) and EnergyPlus (in the US). Anticipating the need for data at time steps less than one hour, the format includes a minute field to facilitate the use of sub hourly data. The data include basic location identifiers such as location name, data source, latitude, longitude, time zone, elevation, peak design conditions, holidays, daylight savings period, typical and extreme periods, ground temperatures, period(s) covered by the data and space for descriptive comments. The time step data include dry bulb and dew point temperature, relative humidity, station pressure, solar radiation (global, extraterrestrial, horizontal infrared, direct, and diffuse), illuminance, wind direction and speed, sky cover, and current weather.

NEW WEATHER FORMAT FOR SIMULATION PROGRAMS

For these reasons, we developed a new generalized weather data format for use with two major simulation programs—ESP-r and EnergyPlus (Crawley et al. 1999). All the data are in SI units. The format is simple, text-based with comma-separated data. It is based on the data available within the TMY2 weather format but has been rearranged to facilitate visual inspection of the data. The TMY2 data are a strict, position-specific format—filling missing data with nines and zero values with zeroes. The new weather data format contains commas to facilitate data reading and analysis with spreadsheet programs. By eliminating redundant 'fill' values, the size of each file is only slightly larger than the original TMY2 format.

The traditional distribution of data source and uncertainty flags within the raw data fields carries with it not only the need for many field separators, it obfuscates the relationships between non-numerical data. In a set of minute data, which could easily require hundreds of thousands of records, the space penalty is considerable. In the E/E file format, all data source and uncertainty fields have been clumped together as a single field immediately following the day and time stamp. For applications where uncertainty is not an issue such data can be easily ignored. When it is important, a single text field is conceptually and computationally easy to parse.

Another difference between the EnergyPlus/ESP-r (E/E) format and TMY2 is the addition of two new data fields—minute and infrared sky. The minute field facilitates use of data observed at intervals of less than one hour such as measured data from a research study of energy efficiency for a particular building. This will allow easier and more accurate calibration of a simulation model to measured data than possible in the past. The infrared sky field allows the programs to calculate the effective sky temperature for re-radiation during nighttime.

The last difference is that a full year of data (such as 8760 hours) is not required—subsets of years are acceptable. Which periods are covered by the data is described in the files. Periods of typical weather patterns based on analysis of the data are also included within the format. A side-by-side comparison of data included in the E/E weather format with data previously used by ESP-r, DOE-2, and BLAST is shown in Table 1. A deficiency noted within ESP-r for example is the lack of correcting air volumes for elevation change—many of the users of ESP-r are in relatively low elevations. For DOE-2 and BLAST, neither program used illumination data in daylighting calculations or infrared sky temperatures—it was always recalculated at time of use.

By including the uncertainty and data source information found in TMY2, users now can evaluate the potential impact of weather variability on the performance of the building.

Table 1. Comparison of E/E with ESP-r,DOE-2, and BLAST Weather Data Formats

Data Element	DOE-2	BLAST	ESP-r	E/E
Location (name, latitude, longitude, elevation, time zone)	X	X	X	X
Data source				X
Commentary			X	X
Design conditions				X
Typical/extreme periods				X
Data periods				X
Holiday/Daylight Savings		X		X
Solar Angles/Equation of Time Hours		X		
Degree Days		X		X
Year	X	X	X	X
Month	X	X	X	X
Day	X	X	X	X
Hour	X	X	X	X
Minute				X
Data source and uncertainty flags				X
Dry bulb temperature	X	X	X	X
Wet bulb temperature	X	X		X
Dew point temperature	X			X
Atmospheric station pressure	X	X		X
Humidity ratio	X	X		X
Relative humidity			X	X
Enthalpy	X			
Density	X			
Wind Speed	X	X	X	X
Wind Direction	X	X	X	X
Infrared Sky Temperature		X		X
Solar Radiation (global, normal, diffuse)	X	X	X	X
Illuminance (global, normal, diffuse)				X
Sky cover (cloud amount)	X			X
Opaque sky cover				X
Visibility				X
Ceiling height				X
Clearness (monthly)	X			
Ground temperatures (monthly)	X			X
Present weather observation and codes (rain, snow)		X		X
Precipitable water				X
Aerosol optical depth				X
Snow depth				X
Days since last snowfall				X

McDonald and Strachan (1998) are introducing uncertainty analysis into ESP-r.

We use the EnergyPlus data dictionary format to describe the E/E weather data set. (See the end of this document). Each line in the format is preceded by a keyword such as LOCATION, DESIGN CONDITIONS, followed by a list of variables beginning either with A or N and a number. A stands for alphanumeric; N for numeric. The number following A/N is the sequence of that number in the keyword list. Commas separate data. (Refer to the IDD Conventions document in "Getting Started" for further explanation of the format). The header information consists of eight lines (keywords): LOCATION, DESIGN CONDITIONS, TYPICAL/EXTREME

PERIODS, GROUND TEMPERATURES, HOLIDAYS/DAYLIGHT SAVINGS, COMMENTS 1, COMMENTS 2, and DATA PERIODS. This is followed by the time step data.

The first eight lines or header within each E/E weather file define basic location information such as longitude, latitude, time zone, elevation, annual design conditions, monthly average ground temperatures, typical and extreme periods, holidays/daylight savings periods, and data periods included. There is also space for users to document any special features or information about the file such as sources of data. The data then follows—8760/8784 lines if hourly data for a year. The specific data elements in the E/E format include:

- Location (City, State Province Region, Country, Data Source, WMO Number, Latitude, Longitude, Time Zone, Elevation)
- Design Conditions (Annual Extreme Daily Mean, Mean Maximum Dry Bulb Temperature and Standard Deviation, Mean Minimum Dry Bulb Temperature and Standard Deviation, Heating Dry Bulb Temperature (99.6%, 99%, 98%), Cooling Dry Bulb Temperature/Mean Coincident Web Bulb Temp (0.4%, 1.0%, 2.0%), Cooling Dew Point Temperature, Mean Coincident Dry Bulb Temp (0.4%, 1.0%, 2.0%), Coincident Humidity Ratio and Relative Humidity (0.4%, 1.0%, 2.0%), Daily Range of Dry Bulb Temperature, Heating Degree Days Base Temperature, Heating Degree Days, Cooling Degree Days Base Temperature, Cooling Degree Days)
- Typical/Extreme Periods (Number of Typical/Extreme Periods (up to 8), Description of each Typical/Extreme Period, Start Month/Day, End Month/Day)
- Ground Temperatures (Number of Ground Temperature Depths (up to 3), Depth for each Ground Temperature set, Soil Conductivity, Soil Density, Soil Specific Heat, Monthly Average Ground Temperatures)
- Leap Year indicator, Daylight Savings Periods, Holidays
- Comments
- Time Step Data Periods, #Number, #Number Records/Intervals in an hour, Description, Start Day of Week, Start Month/Day, End Month/Day)
- Time Step Data (Year, Month, Day, Hour, Minute), Data Source and Uncertainty Flags,
- Time Step Data (Dry Bulb Temperature, Dew Point Temperature, Relative Humidity, Atmospheric Station Pressure, Radiation (Extraterrestrial Horizontal, Extraterrestrial Direct Normal, Horizontal Infrared Radiation from Sky, Global Horizontal, Direct Normal, Diffuse Horizontal), Illuminance (Global Horizontal, Direct Normal, Diffuse Horizontal, Zenith Luminance), Wind (Direction, Speed), Sky Cover (Total, Opaque, Visibility, Ceiling Height), Present Weather (Observation, Codes), Precipitable Water, Aerosol Optical Depth, Snow (Depth, Days Since Last Snowfall))

Tables 2, 3, 4, 5, and 6 describe the codes for the sixth field in the time step data—Data Source and Uncertainty Flags. Table 2 describes the flags in order they are presented within the sixth data field—each flag is a single letter or number. Tables 3, 4, 5 and 6 provide a description of each of the codes. An example header and first and last days of an E/E data file for Washington, DC (Dulles Airport, Sterling, Virginia) is shown following the IDD description at the end of this document.

The E/E Weather Utility automatically generates the Typical/Extreme periods. daylight savings periods and number of holidays and holiday dates are country- and site-specific. The number of holidays is variable and entered by the user. We included daylight savings and holidays in the format so that users will only have to find those data once, not each time they run the simulation program. In both EnergyPlus and ESP-r, these design conditions, holiday, daylight savings, other data are defaults and can be overridden by user input.

UTILITY

We developed a utility for the E/E format to read standard weather service file types such as TD1440 and DATSAV2 and newer 'typical year' weather files such as TMY2 and WYEC2.

The utility translates and extends typical weather data into the E/E format. The processor makes the calculations necessary for interpolating data (when data is missing) and calculates the illumination data—not typically currently an observed value reported by the meteorological offices through the world. The utility also prepares an interactive summary of the weather data set that the user can browse and save.

Table 2. Key to Data Source and Uncertainty Flags

Data Flag	Flag Values
Dry Bulb Temperature Data Source	A-F
Dry Bulb Temperature Data Uncertainty	0-9
Dew Point Temperature Data Source	A-F
Dew Point Temperature Data Uncertainty	0-9
Relative Humidity Data Source	A-F
Relative Humidity Data Uncertainty	0-9
Atmospheric Station Pressure Data Source	A-F
Atmospheric Station Pressure Data Uncertainty	0-9
Horizontal Infrared Radiation Data Source	A-H, ?
Horizontal Infrared Radiation Data Uncertainty	0-9
Global Horizontal Radiation Data Source	A-H, ?
Global Horizontal Radiation Data Uncertainty	0-9
Direct Normal Radiation Data Source	A-H, ?
Direct Normal Radiation Data Uncertainty	0-9
Diffuse Horizontal Radiation Data Source	A-H, ?
Diffuse Horizontal Radiation Data Uncertainty	0-9
Global Horizontal Illuminance Data Source	I, ?
Global Horizontal Illuminance Data Uncertainty	0-9
Direct Normal Illuminance Data Source	I, ?
Direct Normal Illuminance Data Uncertainty	0-9
Diffuse Horizontal Illuminance Data Source	I, ?
Diffuse Horizontal Illuminance Data Uncertainty	0-9
Zenith Luminance Data Source	I, ?
Zenith Luminance Data Uncertainty	0-9
Wind Direction Data Source	A-F
Wind Direction Data Uncertainty	0-9
Wind Speed Data Source	A-F
Wind Speed Data Uncertainty	0-9
Total Sky Cover Data Source	A-F
Total Sky Cover Data Uncertainty	0-9
Opaque Sky Cover Data Source	A-F
Opaque Sky Cover Data Uncertainty	0-9
Visibility Data Source	A-F, ?
Visibility Data Uncertainty	0-9
Ceiling Height Data Source	A-F, ?
Ceiling Height Data Uncertainty	0-9
Precipitable Water Data Source	A-F
Precipitable Water Data Uncertainty	0-9
Broadband Aerosol Optical Depth Data Source	A-F
Broadband Aerosol Optical Depth Data Uncertainty	0-9
Snow Depth Data Source	A-F, ?
Snow Cover Data Uncertainty	0-9
Days Since Last Snowfall Data Source	A-F, ?
Days Since Last Snowfall Data Uncertainty	0-9

Table 3. Solar Radiation and Illuminance Data Source Flag Codes

Flag Code	Definition
A	Post-1976 measured solar radiation data as received from NCDC or other sources
B	Same as "A" except the global horizontal data underwent a calibration correction
C	Pre-1976 measured global horizontal data (direct and diffuse were not measured before 1976), adjusted from solar to local time, usually with a calibration correction
D	Data derived from the other two elements of solar radiation using the relationship, global = diffuse + direct ´ cosine (zenith)
E	Modeled solar radiation data using inputs of observed sky cover (cloud amount) and aerosol optical depths derived from direct normal data collected at the same location
F	Modeled solar radiation data using interpolated sky cover and aerosol optical depths derived from direct normal data collected at the same location
G	Modeled solar radiation data using observed sky cover and aerosol optical depths estimated from geographical relationships
H	Modeled solar radiation data using interpolated sky cover and estimated aerosol optical depths
I	Modeled illuminance or luminance data derived from measured or modeled solar radiation data
?	Source does not fit any of the above categories. Used for nighttime values and missing data

Table 4. Solar Radiation and Illuminance Data Uncertainty Flag Codes

Flag	Uncertainty Range (%)
1	Not used
2	2 - 4
3	4 - 6
4	6 - 9
5	9 - 13
6	13 - 18
7	18 - 25
8	25 - 35
9	35 - 50
0	Not applicable

Table 5. Meteorological Data Source Flag Codes

Flag	Definition
A	Data as received from NCDC, converted to SI units
B	Linearly interpolated
C	Non-linearly interpolated to fill data gaps from 6 to 47 hours in length
D	Not used
E	Modeled or estimated, except: precipitable water, calculated from radiosonde data; dew point temperature calculated from dry bulb temperature and relative humidity; and relative humidity calculated from dry bulb temperature and dew point temperature
F	Precipitable water, calculated from surface vapor pressure; aerosol optical depth, estimated from geographic correlation
?	Source does not fit any of the above. Used mostly for missing data

Table 6. Meteorological Uncertainty Flag Codes

Flag	Definition
1- 6	Not used
7	Uncertainty consistent with NWS practices and the instrument or observation used to obtain the data
8	Greater uncertainty than 7 because values were interpolated or estimated
9	Greater uncertainty than 8 or unknown.
0	Not definable.

CONCLUSIONS

We have developed a generic weather format for use by EnergyPlus and ESP-r. The new data set covers data that are increasingly needed for simulations of complex building designs such as sub-hourly data and illumination data.   By extending the weather data available to developers of energy simulation models, we believe that the new format will also encourage developers to actually use the data available rather than forcing them to create data within their modules. Several advantages for this weather data format include:

- Measured data with time-steps of less than one hour can be easily translated into the format
- Data are easily shared among major energy simulation programs
- Specialized weather data sets, e.g., hot sunny, cold cloudy, high wind, etc—can be developed for the same location
- Uncertainty associated with global climate change can be evaluated

REFERENCES

ASHRAE. 1985. *Weather Year for Energy Calculations*. Atlanta: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ASHRAE. 1997. *WYEC2 Weather Year for Energy Calculations 2, Toolkit and Data*, Atlanta: ASHRAE.

Commission of the European Community. 1985. *Test Reference Years,* Weather data sets for computer simulations of solar energy systems and energy consumption in buildings, CEC, DG XII. Brussels,
Belgium: Commission of the European Community.

Crawley, Drury B., Linda K. Lawrie, Curtis O. Pedersen, Richard J. Liesen, Daniel E. Fisher, Richard K. Strand, Russell D. Taylor, Frederick C. Winkelmann, W.F. Buhl, A. Ender Erdem, and Y. Joe Huang. 1999. "EnergyPlus, A New-Generation Building Energy Simulation Program," in *Proceedings of Building Simulation '99*, Kyoto, Japan. IBPSA.

Crawley, Drury B. 1998. "Which Weather Data Should You Use for Energy Simulations of Commercial Buildings?," *ASHRAE Transactions*, 104 Pt. 2. Atlanta: ASHRAE.

Energy Simulation Research Unit. 1999.   http://www.strath.ac.uk/Departments/ESRU

Janak, M. 1997. "Coupling Building Energy and Lighting Simulation," in *Proceedings of Building Simulation 97*, September 1997, Volume II pp 313-319, Prague, Czech Republic, IBPSA.

National Instruments Corporation. 1999. *LabVIEW User Manual.* Austin, Texas: National Instruments Corporation.

McDonald, Iain, and Paul Strachan. 1998. "Practical Application of Uncertainty Analysis" in *Proceedings of EPIC 98: Second International Conference on Energy Performance and Indoor Climate in Buildings*, Lyon, France, 19-21 November 1998.

National Climatic Data Center (NCDC). 1976. *Test Reference Year (TRY)*, Tape Reference Manual, TD-9706, September 1976. Asheville, North Carolina: National Climatic Data Center, U.S. Department of Commerce.

NCDC. 1981. *Typical Meteorological Year User's Manual, TD-9734, Hourly Solar Radiation—Surface Meteorological Observations*, May 1981. Asheville, North Carolina: National Climatic Data Center, U.S. Department of Commerce.

NCDC. 1993. *Solar and Meteorological Surface Observation Network, 1961-1990, Version 1.0*, September 1993. Asheville, North Carolina: National Climatic Data Center, U.S. Department of Commerce.

National Renewable Energy Laboratory (NREL). 1995. *User's Manual for TMY2s (Typical Meteorological Years)*, NREL/SP-463-7668, and *TMY2s, Typical Meteorological Years Derived from the 1961-1990 National Solar Radiation Data Base*, June 1995, CD-ROM. Golden, Colorado: National Renewable Energy Laboratory.

University of Illinois. 1998. *BLAST User's Guide.* Building Systems Laboratory, University of Illinois. Urbana, Illinois: University of Illinois, Department of Industrial and Mechanical Engineering.

Ward. G. 1996. *Radiance.* Berkeley: Lawrence Berkeley National Laboratory.

Winkelmann, F.C., W.F. Buhl, B. Birdsall, A. E. Erdem, and K. Ellington. 1994. *DOE-2.1E Supplement*, DE-940-11218. Lawrence Berkeley Laboratory, Berkeley, California. Springfield, Virginia: NTIS.

WEB RESOURCES

Building Energy Tools Directory, a directory of information on more than 160 energy tools from around the world.

http://www.eren.doe.gov/buildings/tools_directory/

Energy Systems Research Unit, University of Strathclyde, authors of ESP-r, up-to-date information on ESP-r and other energy systems research and software development.

http://www.strath.ac.uk/Departments/ESRU

EnergyPlus, up-to-date information on the current status of EnergyPlus and working with the team, and documentation such as input data structure, output data structure, and licensing opportunities. A more detailed description of the EnergyPlus/ESP-r weather format is also included with sample weather files.

http://www.eren.doe.gov/buildings/energy_tools/energyplus.htm

!ESP-r/EnergyPlus Weather Format
!22 November 1999

LOCATION,
  A1, \field city
   \type alpha
  A2, \field State Province Region
   \type alpha
  A3, \field Country
   \type alpha
  A4, \field Source
   \type alpha
  N1, \field WMO
   \type integer
  N2 , \field Latitude
     \units deg
     \minimum -90.0
     \maximum +90.0
     \default 0.0
     \note + is North, - is South,
     \note degree minutes represented in decimal (i.e. 30 minutes is .5)
     \type real
  N3 , \field Longitude
     \units deg
     \minimum -180.0
     \maximum +180.0
     \default 0.0
     \note - is West, + is East,
     \note degree minutes represented in decimal (i.e. 30 minutes is .5)
     \type real
  N4 , \field TimeZone
     \units hr (decimal)
     \minimum -12.0
     \maximum +12.0
     \default 0.0
     \note Time relative to GMT.
     \type real
  N5 ; \field Elevation
     \units m
     \minimum -1000.0
     \maximum< +9999.9
     \default 0.0
     \type real

DESIGN CONDITIONS,
  N1, \field Annual Extreme Daily Mean Maximum Dry Bulb Temperature
     \units C
  N2 \field Annual Extreme Daily Mean Minimum Dry Bulb Temperature
     \units C
  N3, \field Annual Extreme Daily Standard Deviation Maximum Dry Bulb Temperature
     \units C
  N4, \field Annual Extreme Daily Standard Deviation Minimum Dry Bulb Temperature
     \units C
  N5 \field 99.6% Heating Dry Bulb Temperature
     \units C
  N6, \field 99% Heating Dry Bulb Temperature
     \units C
  N7, \field 98% Heating Dry Bulb Temperature
     \units C
  N8, \field 0.4% Cooling Dry Bulb Temperature
     \units C
  N9, \field 0.4% Mean Coincident Wet Bulb Temperature
     \units C

N10, \field 1.0% Cooling Dry Bulb Temperature
    \units C
N11, \field 1.0% Mean Coincident Wet Bulb Temperature
    \units C
N12, \field 2.0% Cooling Dry Bulb Temperature
    \units C
N13, \field 2.0% Mean Coincident Wet Bulb Temperature
    \units C
N14, \field 0.4% Cooling Dew Point Temperature
    \units C
N15, \field 0.4% Mean Coincident Dry Bulb Temperature
    \units C
N16, \field 0.4% Humidity Ratio {?}],
N17, \field 1.0% Cooling Dew Point Temperature
    \units C
N18, \field 1.0% Mean Coincident Dry Bulb Temperature
    \units C
N19, \field 1.0% Humidity Ratio
     \units {?}
N20, \field 2.0% Cooling Dew Point Temperature
    \units C
N21, \field 2.0% Mean Coincident Dry Bulb Temperature
    \units C
N22, \field 2.0% Humidity Ratio
     \units {?}
N23, \field Daily Range of Dry Bulb Temperature
    \units C
N23, \field Heating Degree Days Base Temperature
    \units C
N24, \field Heating Degree Days
N25, \field Cooling Degree Days Base Temperature
    \units C
N26; \field Cooling Degree Days

TYPICAL/EXTREME PERIODS,
    N1, \field Number of Typical/Extreme Periods
    A1, \field Typical/Extreme Period 1
    N2, \field Period 1 Start Date
    N3, \field Period 1 End Date
    A2, \field Typical/Extreme Period 2
    N4, \field Period 2 Start Date
    N5, \field Period 2 End Date
   --- etc ---

GROUND TEMPERATURES,
    N1, Number of Ground Temperature Depths
    N2, \field Ground Temperature Depth 1
       \units m
     N3, \field Depth 1 Soil Conductivity
       \units W/m-K,
     N4, \field Depth 1 Soil Density
       \units kg/m3
     N5, \field Depth 1 Soil Specific Heat
       \units J/kg-K,
     N6, \field Depth 1 January Average Ground Temperature
      \units C
     N7, \field Depth 1 February Average Ground Temperature
      \units C
     N8, \field Depth 1 March Average Ground Temperature
      \units C
     N9, \field Depth 1 April Average Ground Temperature
      \units C
     N10, \field Depth 1 May Average Ground Temperature
      \units C
     N11, \field Depth 1 June Average Ground Temperature
      \units C
     N12, \field Depth 1 July Average Ground Temperature

```
        \units C
    N13, \field Depth 1 August Average Ground Temperature
        \units C
    N14, \field Depth 1 September Average Ground Temperature
        \units C
    N15, \field Depth 1 October Average Ground Temperature
        \units C
    N16, \field Depth 1 November Average Ground Temperature
        \units C
    N17, \field Depth 1 December Average Ground Temperature
        \units C
 -- etc ---
```

HOLIDAYS/DAYLIGHT SAVINGS,
```
    A1, \field LeapYear Observed
     \type choice
     \key Yes
     \key No
     \note Yes if Leap Year will be observed for this file
     \note No if Leap Year days (29 Feb) should be ignored in this file
    N2, \field Daylight Savings Start Day
    N3, \field Daylight Savings End Day
    N4, \field Number of Holiday definitions following
    A2, \field Holiday 1 Name
    N5, \field Holiday 1 Date
  -- etc --
```

COMMENTS 1, A1; \field Comments 1]

COMMENTS 2, A1; \field Comments 2]

DATA PERIODS,
```
    N1, \field Number of Data Periods
    N2, \field Number of Records per hour
    A1, \field Data Period 1 Name/Description
    A2, \field Data Period 1 Start Day of Week
     \type choice
     \key  Sunday
     \key  Monday
     \key  Tuesday
     \key  Wednesday
     \key  Thursday
     \key  Friday
     \key  Saturday
    N3, \field Data Period 1 Start Date
    N4, \field Data Period 1 End Date
-- etc --
```

```
! Actual data does not have a keyword
    N1, \field Year
    N2, \field Month
    N3, \field Day
    N4, \field Hour
    N5, \field Minute
    A1, \field Data Source and Uncertainty Flags
    N6, \field Dry Bulb Temperature
     \units C
    N7, \field Dew Point Temperature
     \units C
    N8, \field Relative Humidity
    N9, \field Atmospheric Station Pressure
     \units Pa
    N10, \field Extraterrestrial Horizontal Radiation
     \units Wh/m2
    N11, \field Extraterrestrial Direct Normal Radiation
     \units Wh/m2
    N12, \field Horizontal Infrared Radiation from Sky
```

\units Wh/m2
N13, \field Global Horizontal Radiation
    \units Wh/m2
N14, \field Direct Normal Radiation
    \units Wh/m2
N15, \field Diffuse Horizontal Radiation
    \units Wh/m2
N16, \field Global Horizontal Illuminance
    \units lux
N17, \field Direct Normal Illuminance
    \units lux
N18, \field Diffuse Horizontal Illuminance
    \units lux
N19, \field Zenith Luminance
    \units Cd/m2
N20, \field Wind Direction
    \units degrees
N21, \field Wind Speed
    \units m/s
N22, \field Total Sky Cover
N23, \field Opaque Sky Cover
N24, \field Visibility
    \units km
N25, \field Ceiling Height
    \units m
N26, \field Present Weather Observation
N27, \field Present Weather Codes
N28, \field Precipitable Water
    \units mm
N29, \field Aerosol Optical Depth
    \units thousandths
N30, \field Snow Depth
    \units cm
N31; \field Days Since Last Snowfall

SAMPLE WEATHER FILE (first few lines)

```
LOCATION,Boulder,CO,United States,TMY2 94018,724699,40.02,-105.25,-7,1634
DESIGN CONDITIONS,header line 2 (design conditions)
TYPICAL/EXTREME PERIODS,0
GROUND TEMPERATURES,0
HOLIDAYS/DAYLIGHT SAVINGS,No,0,0,0
COMMENTS 1,Boulder CO weather data taken from TMY2 data
COMMENTS 2,
DATA PERIODS,1,1,TMY2 Year,Sunday,1,365
1970,01,01,01,60,B8E7B8B8?9?0?0?0?0?0?0B8B8B8B8?0?0F8F8A7E7,-7.0,-
8.5,88,83400,0,0,9999,0,0,0,0,0,0,0,230,1.5,10,8,9999,99999,0,999999999,3,0.034,3,0
1970,01,01,02,60,A7A7A7A7?9?0?0?0?0?0?0A7A7A7A7A7A7F8F8A7E7,-7.2,-
8.3,91,83400,0,0,9999,0,0,0,0,0,0,0,220,1.5,10,8,11.3,1128,0,999999999,3,0.034,3,0
1970,01,01,03,60,B8E7B8B8?9?0?0?0?0?0?0B8B8B8B8?0?0F8F8A7E7,-8.1,-
8.8,94,83400,0,0,9999,0,0,0,0,0,0,0,210,1.5,7,6,9999,99999,0,999999999,3,0.034,3,0
1970,01,01,04,60,B8E7B8B8?9?0?0?0?0?0?0B8B8B8B8?0?0F8F8A7E7,-9.1,-
9.4,97,83400,0,0,9999,0,0,0,0,0,0,0,210,1.5,5,4,9999,99999,0,999999999,3,0.034,3,0
1970,01,01,05,60,A7A7A7A7?9?0?0?0?0?0?0A7A7A7A7A7A7F8F8A7E7,-10.0,-
10.0,100,83300,0,0,9999,0,0,0,0,0,0,0,200,1.5,2,2,24.1,77777,0,999999999,3,0.034,3,0
```