

P4-T1 SB1 PACKER 70x147 C24 x L 2559 - 1 No.

TLS DETAIL - APPROVED BY THE ENGINEER







END SECTION 1:7.5

PIECE	P4-T1 - SB1 packer 70x147 C24
FIXES TO	SB1 - its E face against the steel
CUT FROM	75x147 x 2700; ripped 70 from 75
HOLES	8 No. - 14 through
COUNTERBORE	60 x 13 deep on the W face
FIXINGS	8 x M12x90 8.8 bolt set (timber)
PURPOSE	west face packer (ripped 70 from 75), 21.8 proud of the flange tips, for Acorn's MT1 truss hangers; stops 85 clear of the Detail C bolts each end; Ø14 holes at 215 + 300n from its S end, 73.5 below its top (mid-height), counterbored Ø60 x 13 on the west face

P4-T2 SB2 PACKER 66x147 C24 x L 2866 - 1 No.

TLS DETAIL - APPROVED BY THE ENGINEER







END SECTION 1:7.5

PIECE	P4-T2 - SB2 packer 66x147 C24
FIXES TO	SB2 - its W face against the steel
CUT FROM	75x147 x 3000; ripped 66 from 75
HOLES	9 No. - 14 through
COUNTERBORE	none
FIXINGS	9 x M12x130 8.8 bolt set (timber)
PURPOSE	east face packer (ripped 66 from 75), 2.25 proud of the flange tips; Ø14 holes at 215.7 + 300n from its S end, 73.5 below its top (mid-height)

P4-T3 SB2 BINDER 45x254 C24 x L 2709 - 1 No.

TLS DETAIL - APPROVED BY THE ENGINEER





END SECTION 1:12.5

PIECE	P4-T3 - SB2 binder 45x254 C24
FIXES TO	SB2 - its W face against the steel
CUT FROM	47x295 x 3000; ripped 45 from 47, ripped 254 from 295 (next stock size - joiner to confirm)
HOLES	9 No. - 14 through
COUNTERBORE	60 x 13 deep on the E face
FIXINGS	9 x M12x130 8.8 bolt set (timber)
PURPOSE	joist binder: the 5 family-room joists hang off its face (Acorn hangers); Ø14 holes at 53.7 + 300n from its S end, 151.5 below its top, counterbored Ø60 x 13 on the east face

P4-T1 HOLES

#	from N	up bottom	dn top	hole	c'bore	fixing
1	244	73.5	73.5	14 thru	60x13 W	M12 bolt
2	544	73.5	73.5	14 thru	60x13 W	M12 bolt
3	844	73.5	73.5	14 thru	60x13 W	M12 bolt
4	1144	73.5	73.5	14 thru	60x13 W	M12 bolt
5	1444	73.5	73.5	14 thru	60x13 W	M12 bolt
6	1744	73.5	73.5	14 thru	60x13 W	M12 bolt
7	2044	73.5	73.5	14 thru	60x13 W	M12 bolt
8	2344	73.5	73.5	14 thru	60x13 W	M12 bolt

P4-T2 HOLES

#	from S	up bottom	dn top	hole	c'bore	fixing
1	215.7	73.5	73.5	14 thru	-	M12 bolt
2	515.7	73.5	73.5	14 thru	-	M12 bolt
3	815.7	73.5	73.5	14 thru	-	M12 bolt
4	1115.7	73.5	73.5	14 thru	-	M12 bolt
5	1415.7	73.5	73.5	14 thru	-	M12 bolt
6	1715.7	73.5	73.5	14 thru	-	M12 bolt
7	2015.7	73.5	73.5	14 thru	-	M12 bolt
8	2315.7	73.5	73.5	14 thru	-	M12 bolt
9	2615.7	73.5	73.5	14 thru	-	M12 bolt

P4-T3 HOLES

#	from S	up bottom	dn top	hole	c'bore	fixing
1	53.7	101.5	151.5	14 thru	60x13 E	M12 bolt
2	353.7	101.5	151.5	14 thru	60x13 E	M12 bolt
3	653.7	101.5	151.5	14 thru	60x13 E	M12 bolt
4	953.7	101.5	151.5	14 thru	60x13 E	M12 bolt
5	1253.7	101.5	151.5	14 thru	60x13 E	M12 bolt
6	1553.7	101.5	151.5	14 thru	60x13 E	M12 bolt
7	1853.7	101.5	151.5	14 thru	60x13 E	M12 bolt
8	2153.7	101.5	151.5	14 thru	60x13 E	M12 bolt
9	2453.7	101.5	151.5	14 thru	60x13 E	M12 bolt

NOTES

1. **APPROVED FOR CONSTRUCTION - the engineer approved the steelwork and the TLS details on 13.10.26; fabricate to these drawings.**
2. ALL TIMBER SUBJECT TO SITE MEASURE AGAINST THE ERECTED STEEL BEFORE DRILLING.
3. Timber: strength-graded to BS EN 14081, C16 / C24 as scheduled, regularised; preservative treatment to the project specification (by others). Treat all cut ends and drilled holes.
4. Holes: bolts, rods and studs drilled d + 2 (M12 = 14), square to the face. Counterbores flat-bottomed (Forstner), concentric with the hole. Coach screws pre-drilled per EN 1995-1-1 8.7.
5. Running dimensions from the named reference end; across dimensions from the named edge. Dimensions in mm.
6. Bolt spacings checked against EN 1995-1-1 8.5 as set by the client: end 7d, edge 4d (M12: 84 / 48). Shortfalls are listed in red on STT-00.

REVISIONS

REV	DATE	DESCRIPTION
C03	11.10.26	Steel timber packing drawings - first issue
C04	13.10.26	Approved by the engineer 13.10.26 - issued for construction

TLS TIMBER FRAME
Design & Manufacture
Scan: 3D model + drawings

CLIENT	PROJECT
MP Adams	MP Adams Plot 4, Eckington

DRAWING TITLE

TIMBER PACKING - SB1 PACKER, SB2 PACKER, SB2 BINDER

SCALE	SIZE	DATE	DRAWN
AS SHOWN	A3	13.10.26	TS

STATUS	DRAWING No.	REV
CONSTRUCTION	P4-STT-01	C04

Do not scale. All dimensions in mm. Check all dimensions on site.