

Aqua Clean UF (Ultrafiltration System)

Advanced Pathogen and Suspended Solids Removal.

Ultrafiltration Plant

Technical Specifications

Parameter	Specification / Value
Approximately 0.01-0. diez um	Membrane pore size
0.5-2.5 bar for many industrial systems	Typical TMP
Approximately 40-80 LMH	Sustainable flux
85-95%	Recovery
Usually <0.2-0.5 NTU	Permeate turbidity
Approximately every 15-60 minutes	Backwash frequency
Daily to weekly, depending on fouling	Chemical-enhanced backwash
Acid, alkali, hypochlorite or proprietary cleaner	Cleaning chemicals
TSS and colloid reduction; SDI improvement	RO pretreatment role