

Effluent Treatment Plants (ETP)

Custom Engineered Solutions for Industrial Effluent Reclamation.

An industrial Effluent Treatment Plant should be configured according to the wastewater source.

Technical Specifications

Main design data	Unit process
10-25 mm opening	Coarse screen
1-6 mm opening	Fine screen
Normally 6-24 hours of average flow	Equalization tank
Typically pH 6.5-8.5 before biological treatment	pH correction
Approximately 1-5 minutes	Rapid mixing
Approximately 15-30 minutes	Flocculation
Approximately 1.5-2.5 hours detention time	Primary clarification
DO 2-3 mg/L	Aerobic biological reactor
Based on surface overflow rate, solids loading and SVI	Secondary clarification
Commonly 5-15 m/h filtration rate, subject to media and water quality	Tertiary sand filtration
Used for residual organics, colour, taste, odour or trace contaminants	Activated carbon
Chlorine, UV or ozonation, depending on reuse requirement	Disinfection
Thickening, dewatering and approved final disposal	Sludge handling