

Conventional Filtration Plant

Multi-Media, Activated Carbon, and Depth Sand Filtration Systems.

An industrial Effluent Treatment Plant should be configured according to the wastewater source.

Technical Specifications

Parameter	Specification / Value
1-5 min	Rapid mixing time
15-30 min	Flocculation time
5-10 m/h	Rapid gravity filtration rate
8-15 m/h	Pressure sand filtration rate
8-15 m/h	Multimedia filter loading
0.8-1.2 m	Filter bed depth
12-18 L/s·m2, media-dependent	Backwash rate
5-15 min	Backwash duration
Approximately 2-3 m	Filter terminal head loss
1-5 um	Cartridge filter rating before RO
Preferably <1 NTU before RO	Turbidity after filtration
<5 maximum; <3 preferred for demanding applications	RO feed SDI??