

BioKleen MBBR (Moving Bed Biofilm Reactor)

High-Efficiency Biological Wastewater Treatment.

An industrial Effluent Treatment Plant should be configured according to the wastewater source.

Technical Specifications

Unit Process	Main Design Data
Main design data	Coarse screen
10-25 mm opening	Fine screen
1-6 mm opening	Equalization tank
Normally 6-24 hours of average flow	pH correction
Typically pH 6.5-8.5 before biological treatment	Rapid mixing
Approximately 1-5 minutes	Flocculation
Approximately 15-30 minutes	Primary clarification
Approximately 1.5-2.5 hours detention time	Aerobic biological reactor
DO 2-3 mg/L	Secondary clarification
Based on surface overflow rate, solids loading and SVI	Tertiary sand filtration
Commonly 5-15 m/h filtration rate, subject to media and water quality	Activated carbon
Used for residual organics, colour, taste, odour or trace contaminants	Disinfection
Chlorine, UV or ozonation, depending on reuse requirement	Sludge handling
Thickening, dewatering and approved final disposal	