

Dixell XW270K — Parameter Reference

Source: XWEB EVO library · v9.5 · Generated from models/partab files

Note: EEPROM Word addresses are internal firmware offsets, not Modbus register addresses. Modbus base: ~0x0502 (register 1282). Exact Modbus addresses require the XW270K Modbus protocol manual or empirical scanning.

Regulation

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
0	HY	Differential	16	8	8	unsigned integer	R/W
1	LS	Minimum set point	50	0	16	unsigned integer	R/W
2	US	Maximum set point	51	0	16	unsigned integer	R/W
3	odS	Outputs delay at start up	40	8	8	unsigned integer	R/W
4	CCo	Compressors setup	12	2	2	bit flag	R/W
5	CC t	Fast freezing duration	40	0	8	unsigned (hours)	R/W
6	Con	Compressor ON time with faulty probe	17	0	8	unsigned integer	R/W
7	CoF	Compressor OFF time with faulty probe	18	8	8	unsigned integer	R/W
8	CH	Kind of action	10	8	1	enum (0=Cool, 1=Heat)	R/W
49	HES	Set point variation during Energy Saving	26	8	8	signed ×0.1 °C	R/W
50	odc	Open door control	12	8	2	bit flag	R/W
51	LMP	Light enabling with open door	10	0	1	bit flag	R/W
61	LdE	Time with light still active after deactivation	45	8	8	unsigned integer	R/W
62	oL t	Light output timer	27	8	8	unsigned integer	R/W
63	oAt	Output timer for auxiliary relay	27	0	8	unsigned integer	R/W
64	SAA	Set point for auxiliary relay	35	0	16	signed ×0.1 °C	R/W
65	SAH	Differential for auxiliary relay	36	0	16	unsigned ×0.1 °C	R/W
68	SE t	Set point	37	0	16	signed ×0.1 °C	R/W

Display

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
9	CF	Temperature measurement unit	10	10	1	enum (0=°C, 1=°F)	R/W
10	Lod	Probe displayed	11	8	2	bit flag	R/W
11	dLY	Display temperature delay	18	0	8	unsigned integer	R/W

Defrost

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
12	Pdn	Delay time before defrost	19	8	8	unsigned (min)	R/W
13	EdF	Defrost mode	11	10	2	enum (0=Temp, 1=Time, 2=Both)	R/W
14	SdF	Smart Defrost set point	19	0	8	signed ×0.1 °C	R/W
15	dtE	First defrost end temperature	29	0	16	signed ×0.1 °C	R/W
16	dtS	Second defrost end temperature	30	0	16	signed ×0.1 °C	R/W
17	IdF	Delay between defrost cycles	41	8	8	unsigned (hours)	R/W
18	MdF	First defrost maximum duration	20	8	8	unsigned (min)	R/W
19	MdS	Second defrost maximum duration	20	0	8	unsigned (min)	R/W
20	dFd	Visualization during defrost	13	12	4	bit flag	R/W
21	dAd	Temperature visualization delay after defrost	41	0	8	unsigned (min)	R/W
22	dSd	Defrost delay from call	21	8	8	unsigned (min)	R/W
23	dod	Time with defrost relay still active after defrost end	21	0	8	unsigned integer	R/W
24	Fdt	Dripping time	42	8	8	unsigned (min)	R/W
25	dPo	Defrost at power-on	10	15	1	bit flag	R/W
26	dAF	Defrost delay after fast freezing	42	0	8	unsigned integer	R/W
27	dFP	First defrost probe selection	12	10	2	bit flag	R/W
28	dSP	Second defrost probe selection	11	12	2	bit flag	R/W

Fan

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
29	Fnc	Fan operating mode	12	12	2	enum (0=F-C off, 1=F always, 2=F-C on)	R/W
30	Fnd	Fans delay after defrost	43	8	8	unsigned (min)	R/W
31	FS t	Fans stop temperature	31	0	16	signed ×0.1 °C	R/W
32	FAP	Probe selection for fan	11	14	2	bit flag	R/W
33	FSU	Kind of action of fan	11	0	2	bit flag	R/W

Alarm

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
34	dA0	Temperature alarm exclusion at power-on	43	0	8	unsigned integer	R/W

35	CSd	Condenser temperature alarm	34	0	16	signed ×0.1 °C	R/W
36	EdA	Temperature alarms exclusion after defrost	44	8	8	unsigned integer	R/W
37	do t	Temperature alarms exclusion after door alarm	44	0	8	unsigned integer	R/W
38	doA	Door alarm delay	24	8	8	unsigned (min)	R/W
66	OP2	Alarm relay polarity	10	13	1	bit flag	R/W

Probes

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
39	ot	First probe calibration	24	0	8	unsigned integer	R/W
40	oE	Second probe calibration	25	8	8	unsigned integer	R/W
41	o3	Third probe calibration	25	0	8	unsigned integer	R/W
42	o4	Fourth probe calibration	28	0	8	unsigned integer	R/W
43	P2P	Second probe presence	10	2	1	enum (0=Absent, 1=Present)	R/W
44	P3P	Third probe presence	10	3	1	enum (0=Absent, 1=Present)	R/W
45	P4P	Fourth probe presence	10	6	1	enum (0=Absent, 1=Present)	R/W
46	Pbr	Regulation probe selection	11	2	2	bit flag	R/W
47	HLP	Minimum/maximum temperature function probe selection	11	4	2	bit flag	R/W
48	ESP	Energy Saving probe selection	11	6	2	bit flag	R/W

Digital inputs

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
52	i1P	Digital input 1 polarity	10	4	1	enum (0=NC oP, 1=NO CL)	R/W
53	i2P	Digital input 2 polarity	10	5	1	enum (0=NC oP, 1=NO CL)	R/W
54	i2F	Digital input 2 function	13	0	4	bit flag	R/W
55	did	Digital input alarm delay	26	0	8	unsigned (min)	R/W

Configuration

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
56	oA1	AUX1 output configuration	14	8	4	bit flag	R/W
57	oA2	AUX2 output configuration	14	12	4	bit flag	R/W
58	oA3	AUX3 output configuration	14	0	4	bit flag	R/W
59	oA4	AUX4 output configuration	14	4	4	bit flag	R/W
60	oA5	AUX5 output configuration	15	8	4	bit flag	R/W

Other

#	Code	Description	EEPROM Word	Bit Off.	Width	Type / Unit	R/W
67	Ptb	Eeprom map	52	0	16	unsigned integer	R/W
69	.Tset	SET key pressing time to modify set point	8	0	2	bit flag	R/W
70	.Tdef	DEF key pressing time to active defrost	8	2	2	bit flag	R/W
71	.INV	Compressor/defrost reversal	8	4	1	bit flag	R/W
72	.LKE	Keyboard lock enabling	8	5	1	bit flag	R/W
73	.8KEY	Keyboard type selection	8	6	1	bit flag	R/W
74	.BLKBUZ	Buzzer blink enabling	8	7	1	bit flag	R/W
75	.ds0NF	ON/OFF key disabling	9	11	1	bit flag	R/W
76	.mAC1	AC1 measurement unit (seconds or minutes)	9	6	1	bit flag	R/W
77	.0NF	On Off state of the device	8	8	1	bit flag	R/W
78	.LOC	Keyboard lock	8	9	1	bit flag	R/W
79	.°tm	Minimum temerature	8	11	1	bit flag	R/W
80	.°tM	Maximum temperature	8	11	1	bit flag	R/W
81	.LUX	State Light Output	8	13	1	bit flag	R/W
82	.FHUM	Humidity fans function status	8	14	1	bit flag	R/W
83	.ES	State Energy Saving	8	15	1	bit flag	R/W