



中国认可
国际互认
检测
TESTING
CNAS L5313

Test Report issued under the responsibility of:

Page 1 of 342



TEST REPORT CEI 0-21

Reference technical rules for the connection of active and passive users to the LV networks of electrical distribution companies

Report

Report Number : 6190323.54
Date of issue : 2024-08-05
Total number of pages : 342 pages

Testing Laboratory : DEKRA Testing and Certification (Suzhou) Co., Ltd.

Address : No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China

Applicant's name : Afore New Energy Technology (Shanghai) Co., Ltd.

Address : Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China

Test specification:

Standard : CEI 0-21:2022-03
Test procedure : Type test
Non-standard test method : N/A

Test Report Form No. : CEI 0-21_V3.0

Test Report Form(s) Originator : DEKRA Testing and Certification (Suzhou) Co., Ltd.

Master TRF : Dated 2022-04

Test item description : Hybrid Inverter

Trade Mark :





Manufacturer : Afore New Energy Technology (Shanghai) Co., Ltd.

Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China

Model/Type reference : AF1K-SL-1, AF1.5K-SL-1, AF2K-SL-1, AF2.5K-SL-1, AF3K-SL-1, AF3.6K-SL-1, AF3K-SL, AF3.6K-SL, AF4K-SL, AF4.6K-SL, AF5K-SL, AF5.5K-SL, AF6K-SL; AF4K-SLP, AF4.6K-SLP, AF5K-SLP, AF5.5K-SLP, AF6K-SLP, AF1K-SL-0, AF1.5K-SL-0, AF2K-SL-0, AF2.5K-SL-0, AF3K-SL-0, AF3.6K-SL-0, AF4K-SL-0, AF4.6K-SL-0, AF5K-SL-0, AF5.5K-SL-0, AF6K-SL-0, AF1K-ASL-1, AF1.5K-ASL-1, AF2K-ASL-1, AF2.5K-ASL-1, AF3K-ASL-1, AF3.6K-ASL-1, AF3K-ASL, AF3.6K-ASL, AF4K-ASL, AF4.6K-ASL, AF5K-ASL, AF5.5K-ASL, AF6K-ASL, AF1K-ASL-0, AF1.5K-ASL-0, AF2K-ASL-0, AF2.5K-ASL-0, AF3K-ASL-0, AF3.6K-ASL-0, AF4K-ASL-0, AF4.6K-ASL-0, AF5K-ASL-0, AF5.5K-ASL-0, AF6K-ASL-0

Ratings : See product marking plate on page 4 to 6 and ratings of the test products on page 11 to 16.

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	DEKRA Testing and Certification (Suzhou) Co., Ltd.
Testing location/ address :		No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China
<input type="checkbox"/>	Associated Testing Laboratory:	
Testing location/ address :		
Tested by (name, function, signature) :		Shine Yan (ENG) 
Approved by (name, function, signature) :		Sandy Qian (REW) 
Testing procedure: CTF Stage 1:		
Testing location/ address :		
Tested by (name, function, signature) :		
Approved by (name, function, signature) :		
Testing procedure: CTF Stage 2:		
Testing location/ address :		
Tested by (name + signature) :		
Witnessed by (name, function, signature) :		
Approved by (name, function, signature) :		
Testing procedure: CTF Stage 3:		
Testing procedure: CTF Stage 4:		
Testing location/ address :		
Tested by (name, function, signature) :		
Witnessed by (name, function, signature) :		
Approved by (name, function, signature) :		
Supervised by (name, function, signature) :		

List of Attachments (including a total number of pages in each attachment):


Annex 1: ISO 9001 certificate (1 pages)
Annex 2: IEC 62619 Certificate for used battery (2 pages)
Annex 3: Datasheet of the relay (2 pages)
Annex 4: Pictures of the unit (9 pages)

Summary of testing:

Tests performed (name of test and test clause):	Testing location:
All tests (except clause 4.6 EMC tests)	DEKRA Testing and Certification (Suzhou) Co., Ltd. No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China
4.6 EMC tests (The EMC test reports provided by the customer)	1. Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai 200233, China Report No.: 230601235SHA-001, 240100597SHA-001 Accreditation Number: 3309.02 (A2LA-ILAC) 2. Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd. No.103, Caobao Road, Xuhui District, Shanghai, China Report No.: J23-429-WT-02, J24-208-WT-01 Accreditation Number: L0130 (CNAS-ILAC)

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



																																																																																																																																																																																	
<p>Model: AFx-SL-0 <input type="radio"/> 1K <input type="radio"/> 1.5K <input type="radio"/> 2K <input type="radio"/> 2.5K <input type="radio"/> 3K <input type="radio"/> 3.6K</p> <p>Battery</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">Battery Type</th> <th colspan="6">Li-Ion/Lead-acid etc.</th> </tr> <tr> <td>Vbat Range</td> <td>(V)</td> <td colspan="6">40-60</td> </tr> <tr> <td>Icc/Idc Max</td> <td>(A)</td> <td>25</td> <td>40</td> <td>50</td> <td>63</td> <td>80</td> <td>80</td> </tr> <tr> <td>Pcc/Pdc Max</td> <td>(kW)</td> <td>1</td> <td>1.5</td> <td>2</td> <td>2.5</td> <td>3</td> <td>3.6</td> </tr> </table> <p>AC Grid</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Vgrid Nom</td> <td>(V)</td> <td colspan="6">220/230</td> </tr> <tr> <td>fgrid Nom</td> <td>(Hz)</td> <td colspan="6">50/60</td> </tr> <tr> <td>Igrid Cont.</td> <td>(A)</td> <td>5</td> <td>7</td> <td>10</td> <td>12</td> <td>14</td> <td>17</td> </tr> <tr> <td>Pgrid Cont.</td> <td>(kW)</td> <td>1</td> <td>1.5</td> <td>2</td> <td>2.5</td> <td>3</td> <td>3.6</td> </tr> <tr> <td>Sgrid Cont.</td> <td>(kVA)</td> <td>1</td> <td>1.5</td> <td>2</td> <td>2.5</td> <td>3</td> <td>3.6</td> </tr> <tr> <td colspan="8">Power Factor 1 (-0.8~+0.8 adjustable)</td> </tr> </table> <p>AC Load Output</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Vload Nom</td> <td>(V)</td> <td colspan="6">220/230</td> </tr> <tr> <td>fload Nom</td> <td>(Hz)</td> <td colspan="6">50/60</td> </tr> <tr> <td>Iload Cont.</td> <td>(A)</td> <td>5</td> <td>7</td> <td>10</td> <td>12</td> <td>14</td> <td>17</td> </tr> <tr> <td>Sload Cont.</td> <td>(kVA)</td> <td>1</td> <td>1.5</td> <td>2</td> <td>2.5</td> <td>3</td> <td>3.6</td> </tr> <tr> <td>Sload Peak</td> <td>(kVA)</td> <td>1.5 (max)</td> <td>2.3 (max)</td> <td>3 (max)</td> <td>3.8 (max)</td> <td>4.5 (max)</td> <td>5.4 (max)</td> </tr> <tr> <td colspan="8">Protective Class I</td> </tr> <tr> <td colspan="8">IP Degree IP65</td> </tr> <tr> <td colspan="8">Operating temperature range -25~+60 °C (Derating 45 °C)</td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;"> S/N HL2017-05 </td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;">  CE RoHS </td> </tr> <tr> <td colspan="4" style="text-align: left; vertical-align: top;"> <small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small> </td> <td colspan="4" style="text-align: right; vertical-align: top;"> <small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small> </td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;"> Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112 </td> </tr> </table>		Battery Type		Li-Ion/Lead-acid etc.						Vbat Range	(V)	40-60						Icc/Idc Max	(A)	25	40	50	63	80	80	Pcc/Pdc Max	(kW)	1	1.5	2	2.5	3	3.6	Vgrid Nom	(V)	220/230						fgrid Nom	(Hz)	50/60						Igrid Cont.	(A)	5	7	10	12	14	17	Pgrid Cont.	(kW)	1	1.5	2	2.5	3	3.6	Sgrid Cont.	(kVA)	1	1.5	2	2.5	3	3.6	Power Factor 1 (-0.8~+0.8 adjustable)								Vload Nom	(V)	220/230						fload Nom	(Hz)	50/60						Iload Cont.	(A)	5	7	10	12	14	17	Sload Cont.	(kVA)	1	1.5	2	2.5	3	3.6	Sload Peak	(kVA)	1.5 (max)	2.3 (max)	3 (max)	3.8 (max)	4.5 (max)	5.4 (max)	Protective Class I								IP Degree IP65								Operating temperature range -25~+60 °C (Derating 45 °C)								S/N HL2017-05								 CE RoHS								<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112							
Battery Type		Li-Ion/Lead-acid etc.																																																																																																																																																																															
Vbat Range	(V)	40-60																																																																																																																																																																															
Icc/Idc Max	(A)	25	40	50	63	80	80																																																																																																																																																																										
Pcc/Pdc Max	(kW)	1	1.5	2	2.5	3	3.6																																																																																																																																																																										
Vgrid Nom	(V)	220/230																																																																																																																																																																															
fgrid Nom	(Hz)	50/60																																																																																																																																																																															
Igrid Cont.	(A)	5	7	10	12	14	17																																																																																																																																																																										
Pgrid Cont.	(kW)	1	1.5	2	2.5	3	3.6																																																																																																																																																																										
Sgrid Cont.	(kVA)	1	1.5	2	2.5	3	3.6																																																																																																																																																																										
Power Factor 1 (-0.8~+0.8 adjustable)																																																																																																																																																																																	
Vload Nom	(V)	220/230																																																																																																																																																																															
fload Nom	(Hz)	50/60																																																																																																																																																																															
Iload Cont.	(A)	5	7	10	12	14	17																																																																																																																																																																										
Sload Cont.	(kVA)	1	1.5	2	2.5	3	3.6																																																																																																																																																																										
Sload Peak	(kVA)	1.5 (max)	2.3 (max)	3 (max)	3.8 (max)	4.5 (max)	5.4 (max)																																																																																																																																																																										
Protective Class I																																																																																																																																																																																	
IP Degree IP65																																																																																																																																																																																	
Operating temperature range -25~+60 °C (Derating 45 °C)																																																																																																																																																																																	
S/N HL2017-05																																																																																																																																																																																	
 CE RoHS																																																																																																																																																																																	
<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>																																																																																																																																																																													
Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112																																																																																																																																																																																	
																																																																																																																																																																																	
<p>Model: AFx-SL-0 <input type="radio"/> 4K <input type="radio"/> 4.6K <input type="radio"/> 5K <input type="radio"/> 5.5K <input type="radio"/> 6K</p> <p>Battery</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">Battery Type</th> <th colspan="6">Li-Ion/Lead-acid etc.</th> </tr> <tr> <td>Vbat Range</td> <td>(V)</td> <td colspan="6">40-60</td> </tr> <tr> <td>Icc/Idc Max</td> <td>(A)</td> <td colspan="6">120</td> </tr> <tr> <td>Pcc/Pdc Max</td> <td>(kW)</td> <td>4</td> <td>4.6</td> <td>5</td> <td>5.5</td> <td>6</td> </tr> </table> <p>AC Grid</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Vgrid Nom</td> <td>(V)</td> <td colspan="6">220/230</td> </tr> <tr> <td>fgrid Nom</td> <td>(Hz)</td> <td colspan="6">50/60</td> </tr> <tr> <td>Igrid Cont.</td> <td>(A)</td> <td>19</td> <td>22</td> <td>23</td> <td>26</td> <td>28</td> </tr> <tr> <td>Pgrid Cont.</td> <td>(kW)</td> <td>4</td> <td>4.6</td> <td>5</td> <td>5.5</td> <td>6</td> </tr> <tr> <td>Sgrid Cont.</td> <td>(kVA)</td> <td>4</td> <td>4.6</td> <td>5</td> <td>5.5</td> <td>6</td> </tr> <tr> <td colspan="8">Power Factor 1 (-0.8~+0.8 adjustable)</td> </tr> </table> <p>AC Load Output</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Vload Nom</td> <td>(V)</td> <td colspan="6">220/230</td> </tr> <tr> <td>fload Nom</td> <td>(Hz)</td> <td colspan="6">50/60</td> </tr> <tr> <td>Iload Cont.</td> <td>(A)</td> <td>19</td> <td>22</td> <td>23</td> <td>26</td> <td>28</td> </tr> <tr> <td>Sload Cont.</td> <td>(kVA)</td> <td>4</td> <td>4.6</td> <td>5</td> <td>5.5</td> <td>6</td> </tr> <tr> <td>Sload Peak</td> <td>(kVA)</td> <td>6 (max)</td> <td>6.9 (max)</td> <td>7.5 (max)</td> <td>8.3 (max)</td> <td>9 (max)</td> </tr> <tr> <td colspan="8">Protective Class I</td> </tr> <tr> <td colspan="8">IP Degree IP65</td> </tr> <tr> <td colspan="8">Operating temperature range -25~+60 °C (Derating 45 °C)</td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;"> S/N HL2018-05 </td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;">  CE RoHS </td> </tr> <tr> <td colspan="4" style="text-align: left; vertical-align: top;"> <small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small> </td> <td colspan="4" style="text-align: right; vertical-align: top;"> <small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small> </td> </tr> <tr> <td colspan="8" style="text-align: center; padding-top: 20px;"> Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112 </td> </tr> </table>		Battery Type		Li-Ion/Lead-acid etc.						Vbat Range	(V)	40-60						Icc/Idc Max	(A)	120						Pcc/Pdc Max	(kW)	4	4.6	5	5.5	6	Vgrid Nom	(V)	220/230						fgrid Nom	(Hz)	50/60						Igrid Cont.	(A)	19	22	23	26	28	Pgrid Cont.	(kW)	4	4.6	5	5.5	6	Sgrid Cont.	(kVA)	4	4.6	5	5.5	6	Power Factor 1 (-0.8~+0.8 adjustable)								Vload Nom	(V)	220/230						fload Nom	(Hz)	50/60						Iload Cont.	(A)	19	22	23	26	28	Sload Cont.	(kVA)	4	4.6	5	5.5	6	Sload Peak	(kVA)	6 (max)	6.9 (max)	7.5 (max)	8.3 (max)	9 (max)	Protective Class I								IP Degree IP65								Operating temperature range -25~+60 °C (Derating 45 °C)								S/N HL2018-05								 CE RoHS								<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112														
Battery Type		Li-Ion/Lead-acid etc.																																																																																																																																																																															
Vbat Range	(V)	40-60																																																																																																																																																																															
Icc/Idc Max	(A)	120																																																																																																																																																																															
Pcc/Pdc Max	(kW)	4	4.6	5	5.5	6																																																																																																																																																																											
Vgrid Nom	(V)	220/230																																																																																																																																																																															
fgrid Nom	(Hz)	50/60																																																																																																																																																																															
Igrid Cont.	(A)	19	22	23	26	28																																																																																																																																																																											
Pgrid Cont.	(kW)	4	4.6	5	5.5	6																																																																																																																																																																											
Sgrid Cont.	(kVA)	4	4.6	5	5.5	6																																																																																																																																																																											
Power Factor 1 (-0.8~+0.8 adjustable)																																																																																																																																																																																	
Vload Nom	(V)	220/230																																																																																																																																																																															
fload Nom	(Hz)	50/60																																																																																																																																																																															
Iload Cont.	(A)	19	22	23	26	28																																																																																																																																																																											
Sload Cont.	(kVA)	4	4.6	5	5.5	6																																																																																																																																																																											
Sload Peak	(kVA)	6 (max)	6.9 (max)	7.5 (max)	8.3 (max)	9 (max)																																																																																																																																																																											
Protective Class I																																																																																																																																																																																	
IP Degree IP65																																																																																																																																																																																	
Operating temperature range -25~+60 °C (Derating 45 °C)																																																																																																																																																																																	
S/N HL2018-05																																																																																																																																																																																	
 CE RoHS																																																																																																																																																																																	
<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>				<small> T +86-21-54326236 F +86-21-54326136 W www.aforeenergy.com I info@aforeenergy.com </small>																																																																																																																																																																													
Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112																																																																																																																																																																																	

Afore NEW ENERGY						
Model:	4K	4.6K	5K	5.5K	6K	
PV Input						
Vpv Max (V)	550					
Vpv MPPT (V)	80-500					
Ipv Max (A)	18.5x2					
Isc Max (A)	26x2					
PPv Max (kW)	6	6.9	7.5	8.3	9	
Battery						
Battery Type	Li-ion/Lead-acid etc.					
Vbat Range (V)	40-60					
Icc/Idc Max (A)	120					
Pcc/Pdc Max (kW)	4	4.6	5	5.5	6	
AC Grid						
Vgrid Nom (V)	220/230					
fgrid Nom (Hz)	50/60					
Igrid Cont. (A)	19	22	23	26	28	
Pgrid Cont. (kW)	4	4.6	5	5.5	6	
Sgrid Cont. (kVA)	4	4.6	5	5.5	6	
Power Factor	1 (-0.8~+0.8 adjustable)					
AC Load Output						
V _{ACLoad} Nom (V)	220/230					
f _{ACLoad} Nom (Hz)	50/60					
I _{ACLoad} Cont. (A)	19	22	23	26	28	
S _{ACLoad} Cont. (kVA)	4	4.6	5	5.5	6	
S _{ACLoad} Peak (kVA)	6 (10min)	6.9 (10min)	7.5 (10min)	8.3 (10min)	9 (10min)	
Protective Class	I					
IP Degree	IP65					
Operating temperature range	-25~+60°C (Derating 45°C)					
S/N						
HL2117-04					5min	
			RoHS			
+86-21-54326236	+86-21-54326136	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112				
www.aforeenergy.com	info@aforeenergy.com					
S/N			HL2239-02			
					5min	
			RoHS			

Remark: According to customer's requirement, these models were evaluated under the grid frequency of 50 Hz.

Warning label:

Test item particulars:

Equipment mobility	movable <u>fixed</u>	hand-held transportable	stationary for building-in
Connection to the mains	pluggable equipment <u>permanent connection</u>		direct plug-in for building-in
Environmental category	<u>outdoor</u>	indoor unconditional	indoor conditional
Over voltage category Mains.....	OVC I	OVC II	<u>OVC III</u>
Over voltage category PV	OVC I	<u>OVC II</u>	OVC III
Mains supply tolerance (%).....	-85 / +115 %		
Tested for power systems	TN		
IT testing, phase-phase voltage (V)	N/A		
Class of equipment.....	<u>Class I</u> Not classified	Class II	Class III
Mass of equipment (kg)	Max 25 kg		
Pollution degree	Outside PD3; Inside PD2		
IP protection class	IP65 (AF*-SL Series), IP66 (AF*-ASL Series)		

Possible test case verdicts:

- test case does not apply to the test object: N/A
- test object does meet the requirement.....: P (Pass)
- test object does not meet the requirement: F (Fail)
- this clause is information reference for installation....: Info.

Testing:

Date of receipt of test item	2022-06-09 (samples provided by applicant) 2023-11-07 (Amendment 1 report) No samples (Amendment 2 report)
Date (s) of performance of tests	2022-06-09 to 2022-10-24 2023-11-07 to 2024-04-01 (Amendment 1 report) No tests (Amendment 2 report)

General remarks:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

The clause A.4.6 EMC tests are not in the CNAS scope of DEKRA Testing and Certification (Suzhou) Co., Ltd.

Throughout this report a comma / point is used as the decimal separator.

Determination of the test result includes consideration of measurement uncertainty from the test equipment and methods.

Name and address of factory (ies):

Afore New Energy Technology (Shanghai) Co., Ltd.

Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China

General product information:

The products under test are single phase Hybrid inverter and non-isolated between PV and AC output that convert DC voltage into AC voltage and feed it into the low-voltage public grid or supply local load.

The final used earth System shall comply the local code requirement.

The input and output are protected by varistors to earth. The unit is providing EMC filtering at the input and output towards mains. The output is switched off redundant by the high power switching bridge and two relay in series. This assures that the opening of the output circuit will also operate in case of one error.


Description of the power circuit:

The internal control is redundant built, it consists of master controller and slave controller, the master controller can control relays, measures voltage, frequency, AC current with injected DC, insulation resistance and residual current. The slave controller can control the relays, measures the voltage and frequency. Both controllers communicate with each other.

The voltage and frequency measurement achieved with resistors in serial, which are connected directly to line and neutral. Both controllers get these signals and calculate the data.

The unit provides two relays in series in each phase. The relays were test before each start up. In addition, both controllers can stop the power bridge.

Block Diagram



Model difference:

All models have same circuit, PWB layout and software. Only different enclosure, output rating, PV input string number and PV switch.

- 1) AF*-SL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K), AF*-SL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K), AF*-SL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) and AF*-SLP (*= 4K, 4.6K, 5K, 5.5K, 6K) have same enclosure, heatsink with AC terminal and outlet bushing.
- 2) AF*-ASL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K), AF*-ASL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K) and AF*-ASL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) have same enclosure, heatsink with AC connector.
- 3) Model AF*-SL-0 & AF*-ASL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) have no PV input and no PV switch. Model AF*-SL-1 & AF*-ASL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K) have one PV input string and one PV switch. Model AF*-SL & AF*-ASL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) and AF*-SLP (*= 4K, 4.6K, 5K, 5.5K, 6K) have 2 PV input strings and one PV switch.
- 4) The BAT port current of model AF*-SL (*= 4K, 4.6K, 5K, 5.5K, 6K) is 80A, and the BAT port current of model AF*-SLP & AF*-ASL (*= 4K, 4.6K, 5K, 5.5K, 6K) is 120A. The output power is derated by software.

The product was tested on:

Hardware version: 1.01

Software version: V02

Amendment 1:

The report 6182549.54 was based on the report 6136775.50 issued by DEKRA Testing and Certification (Suzhou) Co., Ltd., issued on 2022-12-16, and COC No.: 6136775.01 issued by DEKRA Testing and Certification (Shanghai) Ltd., issued on 2022-12-16. It was issued due to below modifications:

- Change the specification of the battery.
- Update the models, the pictures of the unit and the marking plates.

After technical review, tests were considered necessary, see the "summary of testing".

Amendment 2:

The report 6190323.54 was based on the report 6182549.54 issued by DEKRA Testing and Certification (Suzhou) Co., Ltd., issued on 2024-05-21, and COC No.: 6182549.05 issued by DEKRA Testing and Certification (Shanghai) Ltd., issued on 2024-05-22. It was issued due to below modifications:

- Update the CB certificate of the battery.

After technical review, tests were not considered necessary.

Model list / Ratings of the test product:						
Models	AF1K-SL-1	AF1.5K-SL-1	AF2K-SL-1	AF2.5K-SL-1	AF3K-SL-1	AF3.6K-SL-1
	AF1K-ASL-1	AF1.5K-ASL-1	AF2K-ASL-1	AF2.5K-ASL-1	AF3K-ASL-1	AF3.6K-ASL-1
PV input:						
Max PV voltage (V)	550					
MPPT voltage range (V)	80-500					
Max PV current (A)	18.5					
Isc PV (A)	26					
Max PV power (W)	1500	2300	3000	3800	4500	5400
Battery port:						
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid					
Battery normal voltage (range) (Vdc)	51.2 (40-60)					
Max charge/discharge current (A)	25	40	50	63	80	80
Max charge/discharge power (W)	1000	1500	2000	2500	3000	3600
AC grid (input and output):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated AC power (W)	1000	1500	2000	2500	3000	3600
Max AC apparent power (VA)	1000	1500	2000	2500	3000	3600
Power factor range	1.0 (-0.8~ +0.8 adjustable)					
AC load output (stand alone):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated continuous AC power (W)	1000	1500	2000	2500	3000	3600
Max continuous AC apparent power (VA)	1000	1500	2000	2500	3000	3600
General:						
Protection class	I					
Degree of protection	IP65 / IP66					
Oversupply category	II(DC), III(AC)					
Ambient temperature	-25...+60°C (Derating > 45°C)					

Models	AF3K-SL	AF3.6K-SL	AF4K-SL	AF4.6K-SL	AF5K-SL	AF5.5K-SL	AF6K-SL					
	AF3K-ASL	AF3.6K-ASL										
PV input:												
Max PV voltage (V)	550											
MPPT voltage range (V)	80-500											
Max PV current (A)	18.5 x 2											
Isc PV (A)	26 x 2											
Max PV power (W)	4500	5400	6000	6900	7500	8300	9000					
Battery port:												
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid											
Battery normal voltage (range) (Vdc)	51.2 (40-60)											
Max charge/discharge current (A)	80											
Max charge/discharge power (W)	3000	3600	4000	4600	4800	4800	4800					
AC grid (input and output):												
Rated voltage (V)	L/N/PE, 230Vac											
Rated frequency (Hz)	50											
Max AC current (A)	14	17	19	22	23	26	28					
Rated AC power (W)	3000	3600	4000	4600	5000	5500	6000					
Max AC apparent power (VA)	3000	3600	4000	4600	5000	5500	6000					
Power factor range	1.0 (-0.8~ +0.8 adjustable)											
AC load output (stand alone):												
Rated voltage (V)	L/N/PE, 230Vac											
Rated frequency (Hz)	50											
Max AC current (A)	14	17	19	22	23	26	28					
Rated continuous AC power (W)	3000	3600	4000	4600	5000	5500	6000					
Max continuous AC apparent power (VA)	3000	3600	4000	4600	5000	5500	6000					
General:												
Protection class	I											
Degree of protection	IP65 / IP66											
Overvoltage category	II(DC), III(AC)											
Ambient temperature	-25...+60°C (Derating > 45°C)											

Models	AF4K-SLP	AF4.6K-SLP	AF5K-SLP	AF5.5K-SLP	AF6K-SLP
	AF4K-ASL	AF4.6K-ASL	AF5K-ASL	AF5.5K-ASL	AF6K-ASL
PV input:					
Max PV voltage (V)	550				
MPPT voltage range (V)	80-500				
Max PV current (A)	18.5 x 2				
Isc PV (A)	26 x 2				
Max PV power (W)	6000	6900	7500	8300	9000
Battery port:					
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid				
Battery normal voltage (range) (Vdc)	51.2 (40-60)				
Max charge/ discharge current (A)	120				
Max charge/ discharge power (W)	4000	4600	5000	5500	6000
AC grid (input and output):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated AC power (W)	4000	4600	5000	5500	6000
Max AC apparent power (VA)	4000	4600	5000	5500	6000
Power factor range	1.0 (-0.8~ +0.8 adjustable)				
AC load output (stand alone):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated continuous AC power (W)	4000	4600	5000	5500	6000
Max continuous AC apparent power (VA)	4000	4600	5000	5500	6000
General:					
Protection class	I				
Degree of protection	IP65 / IP66				
Overvoltage category	II(DC), III(AC)				
Ambient temperature	-25...+60°C (Derating > 45°C)				

Models	AF1K-SL-0	AF1.5K-SL-0	AF2K-SL-0	AF2.5K-SL-0	AF3K-SL-0	AF3.6K-SL-0
	AF1K-ASL-0	AF1.5K-ASL-0	AF2K-ASL-0	AF2.5K-ASL-0	AF3K-ASL-0	AF3.6K-ASL-0
Battery port:						
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid					
Battery normal voltage (range) (Vdc)	51.2 (40-60)					
Max charge/discharge current (A)	25	40	50	63	80	80
Max charge/discharge power (W)	1000	1500	2000	2500	3000	3600
AC grid (input and output):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated AC power (W)	1000	1500	2000	2500	3000	3600
Max AC apparent power (VA)	1000	1500	2000	2500	3000	3600
Power factor range	1.0 (-0.8~ +0.8 adjustable)					
AC load output (stand alone):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated continuous AC power (W)	1000	1500	2000	2500	3000	3600
Max continuous AC apparent power (VA)	1000	1500	2000	2500	3000	3600
General:						
Protection class	I					
Degree of protection	IP65 / IP66					
Oversupply category	II(DC), III(AC)					
Ambient temperature	-25...+60°C (Derating > 45°C)					

Models	AF4K-SL-0	AF4.6K-SL-0	AF5K-SL-0	AF5.5K-SL-0	AF6K-SL-0
	AF4K-ASL-0	AF4.6K-ASL-0	AF5K-ASL-0	AF5.5K-ASL-0	AF6K-ASL-0
Battery port:					
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid				
Battery normal voltage (range) (Vdc)	51.2 (40-60)				
Max charge/ discharge current (A)	120	120	120	120	120
Max charge/ discharge power (W)	4000	4600	5000	5500	6000
AC grid (input and output):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated AC power (W)	4000	4600	5000	5500	6000
Max AC apparent power (VA)	4000	4600	5000	5500	6000
Power factor range	1.0 (-0.8~ +0.8 adjustable)				
AC load output (stand alone):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated continuous AC power (W)	4000	4600	5000	5500	6000
Max continuous AC apparent power (VA)	4000	4600	5000	5500	6000
General:					
Protection class	I				
Degree of protection	IP65 / IP66				
Oversupply category	II(DC), III(AC)				
Ambient temperature	-25...+60°C (Derating > 45°C)				

Type of generating unit:

Static Conversion Device <i>Dispositivo di conversione statica</i>	Interface Protection <i>Protezione di interfaccia</i>	Interface Protection Device <i>Dispositivo di interfaccia</i>	Rotating Generator Device <i>Dispositivo di generazione rotante</i>
Yes/Si	Yes/Si	Yes/Si	No/No

The battery used for testing with the Hybrid Inverter:

Battery Models	AF5000W-LE, AF5000W-LH			
Manufacturer	Afore New Energy Technology (Shanghai) Co., Ltd.			
Number of battery module in parallel	1	2	3	4
Nominal Voltage	51.2 V			
Nominal capacity	100 Ah	200 Ah	300 Ah	400 Ah
Battery System Capacity	5.12 kWh	10.24 kWh	15.36 kWh	20.48 kWh
Number of battery module in parallel	5	6	7	8
Nominal Voltage	51.2 V			
Nominal capacity	500 Ah	600 Ah	700 Ah	800 Ah
Battery System Capacity	25.60 kWh	30.72 kWh	35.84 kWh	40.96 kWh
Number of battery module in parallel	9	10	11	12
Nominal Voltage	51.2 V			
Nominal capacity	900 Ah	1000 Ah	1100 Ah	1200 Ah
Battery System Capacity	46.08 kWh	51.20 kWh	56.32 kWh	61.44 kWh
Number of battery module in parallel	13	14	15	--
Nominal Voltage	51.2 V			
Nominal capacity	1300 Ah	1400 Ah	1500 Ah	--
Battery System Capacity	66.56 kWh	71.68 kWh	76.80 kWh	--
Remark:				
The CB test certificate No. of the battery: FR_719708				
AF5000W-LE and AF5000W-LH are the same product except for external opening method and model names.				
When the batteries are connected in parallel, the charge/ discharge current is superimposed and is limited by the maximum current of the battery port of the Hybrid Inverter.				
The batteries are not integrated into the Hybrid Inverter and must be installed according to the local regulations.				

Clause	Test Item	Remark	P / F / N/A
A.4.3.1 & A.4.3.2	<i>Test procedure for maximum/minimum frequency</i>		P
A.4.3.1 & A.4.3.2	<i>Test procedure for maximum/minimum voltage</i>		P
A.4.3.3.1	<i>Insensitivity to harmonics of the frequency relay</i>		P
A.4.3.3.2	<i>Remote trip signal</i>		P
A.4.3.3.3	<i>Communication Signal</i>		P
A.4.3.4	<i>Verification of insensitivity to the frequency derivative</i>		P
A.4.4	<i>Self -test</i>		P
A.4.5	<i>Single fault tolerance</i>		P
A.4.7	<i>Climatic compatibility tests</i>		P
A.4.8	<i>Insulation tests (CEI EN 60255-5)</i>		P
A.4.9	<i>Test for the overload capacity of measuring circuits</i>		P
A.4.11	<i>Automatic mechanism to prevent current imbalance during production</i>		N/A
B.1 a)/b)	<i>Harmonic current emission</i>		P
B.1 c)	<i>Flicker emission</i>		P
B.1.1	<i>Conditions of connection, reconnection and gradual power supply</i>		P
B.1.2.2.1	<i>Reactive power capability - Inverter in systems with total capacity up to 11.08 kW</i>	≤11.08 kW	N/A
B.1.2.2.2	<i>Reactive power capability - Inverter in systems with total capacity greater than 11.08 kW</i>	>11.08 kW	P
B.1.2.3	<i>Reactive power supply at a given level (greater 11.08 kW systems, but can requested for smaller systems as well)</i>	>11.08 kW *	P
B.1.2.4	<i>Response time to an assigned step level change (greater 11.08 kW systems)</i>	>11.08 kW *	P
B.1.2.5	<i>Automatic supply of reactive power according to the characteristic curve $\cos \varphi = f(P)$</i>		P
B.1.2.6	<i>Automatic supply of reactive power according to the characteristic curve $Q = f(V)$ (greater 11.08kW systems)</i>	>11.08 kW *	P
B.1.3.1	<i>Automatic limitation of active power for voltage values close to 110% of the rated voltage</i>		P
B.1.3.2	<i>Adjustment of active power in the presence of over-frequency transistors on the transmission network</i>		P
B.1.3.3	<i>Verification of the operating range in voltage and frequency</i>		P
B.1.3.3.1	<i>Reduction of active power in the presence of transient under-frequency on transmission network</i>		P
B.1.3.4	<i>Limitation of active power by external control from the distributor</i>		P
B.1.4.1	<i>Checking the DC component output current</i>		P
B.1.4.2	<i>Checking the protection against DC input</i>		P
B.1.5	<i>Checking insensitivity of voltage dips (LVRT and OVRT(8.5. 1-figure 30) capability) [greater 11.08 kW systems]</i>	>11.08 kW	P
B.1.6	<i>Checking the insensitivity to automatic reclosing during phase discordance</i>		P

Clause	Test Item	Remark	P / F / N/A
Hybrid inverter use battery for testing:			
Bbis.3 a)/b)	Harmonics measurement		P
Bbis.3 c)	Flicker measurement		P
Bbis.4	Check the operating range in voltage and frequency		P
Bbis.5	Conditions of connection, reconnection and gradual power supply		P
Bbis.6.1 & Bbis.6.2	Checking construction requirements: reactive power capability		P
Bbis.6.3 & Bbis.6.4	Reactive power production according to an assigned level	>11.08 kW *	P
Bbis.6.5	Response time to a step change of the assigned level	>11.08 kW *	P
Bbis.6.6 & Bbis.6.7	Automatic production of reactive power according to a characteristic curve $\cos \varphi = f(P)$		P
Bbis.6.8 & Bbis.6.9	Automatic reactive power production according to a characteristic curve $Q = f(V)$	>11.08 kW *	P
Bbis.7.1	Active power limitation for voltage values near to 110 % U_n		P
Bbis.7.2	Verification of automatic reduction of active power in the presence of overfrequency transients on the network		P
Bbis.7.3	Verification of the automatic increase of active power in the presence of underfrequency transients on the network		P
Bbis.7.4	Active power limitation in coincidence with external command coming from the Electricity Distributor		P
Bbis.7.4.1	Verification of the settling time at a power increase / decrease command		P
Bbis.8.1	Verification of continuous component emission		P
Bbis.8.2	Verification of protections against the continuous DC injection		P
Bbis.9	Verification of insensitivity to voltage dips (UVRT and OVRT(8.5. 1-figure 30 capability))	>11.08 kW	P
Bbis.10	Verification of insensitivity to automatic reclosing in phase discrepancy		P
Remark:			
* The tests described in this paragraph are mandatory only for inverters used in plants with a power greater than 11.08 kW, but at the request of the manufacturer they can also be carried out and documented for smaller size converters.			

CEI 0-21										
Clause	Requirement - Test				Result - Remark		Verdict			
A.3	TABLE: Adjustment ranges for the SPI						P			
Voltage values										
Threshold	85% U_n (27.S1)	t_{min} (27.S1)	15% U_n (27.S2)	t_{min} (27.S2)	110% U_n (59.S1)	t_{max} (59.S1)	115% U_n (59.S2)	t_{max} (59.S2)		
Range	0.2-1.0 U_n	0.05-5 s	0.05-1.0 U_n	0.05-5 s	1.0-1.2 U_n	0.2-10 s	1.0-1.3 U_n	0.05-1.0 s		
Steps	0.05 U_n	0.05 s	0.05 U_n	0.05 s	0.01 U_n	0.1 s	0.01 U_n	0.05 s		
Frequency values										
Threshold	49.50 Hz (81<.S1)	t_{min} (81<.S1)	47.50 Hz (81<.S2)	t_{min} (81<.S2)	50.50 Hz (81>.S1)	t_{max} (81>.S1)	51.50 Hz (81>.S2)	t_{max} (81>.S2)		
Range	47.0-50.0 Hz	0.05-5s	47.0-50.0 Hz	0.05-5s	50.0-52.0 Hz	0.05-5 s	50.0-52.0 Hz	0.05-5 s		
Steps	0.1 Hz	0.05 s	0.1 Hz	0.05 s	0.1 Hz	0.05 s	0.1 Hz	0.05 s		
Table 13 - SPI adjustments (with the exception of systems with power less than 800 W)										
Protection				Intervention threshold		Intervention time (time elapsing between the instant the anomalous condition detected by the protection starts and the release of the trip command)				
Maximum voltage (59.S1, 10 min moving average measurement, in accordance with CEI EN 61000-4-30)				1,10 V_n		Variable according to the initial and final voltage value, maximum 603 s.				
Maximum voltage (59.S2)				1,15 V_n		0,2 s				
Minimum voltage (27.S1)				0,85 V_n		1,5 s				
Minimum voltage (27.S2) *				0,15 V_n		0,2 s				
Maximum frequency (81>.S1)** ◊				50,2 Hz		0,1 s				
Minimum frequency (81<.S1)** ◊				49,8 Hz		0,1 s				
Maximum frequency (81>.S2) ◊				51,5 Hz		0,1 s or 1 s §				
Minimum frequency (81<.S2) ◊				47,5 Hz		0,1 s or 4 s §				
<p>* The value indicated for the intervention time must be adopted when the total power is higher than 11.08 kW, while for lower powers, an intervention time without intentional delay can be optionally used. In the case of synchronous generators, the value can be raised to 0.7 V_n and $t = 0.150$ s</p> <p>** Threshold enabled only with external signal at high value and with high local command.</p> <p>◊ For voltage values below 0.2 V_n, the maximum / minimum frequency protection must be inhibited.</p> <p>§ In this regard, see what is reported in the text that follows Figure 35.</p>										

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum frequency (81.S2) (stand alone, use of the SPI on the basis of local information only)					P
Model	AF6K-SL					
	Under frequency:			Over frequency:		
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps			0.99 threshold -> increase by max 10mHz steps		
Ambient temperature						
Limit [Hz]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)		
Measurement accuracy of the tripping value [Hz]:	47.51	47.50	47.51	51.50	51.49	51.51
Trip time limit [ms]:	100 ms			100 ms		
Measurement the trip time [ms]:	96.0	85.0	86.0	99.0	97.0	97.0
-25°C temperature						
Limit [Hz]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)		
Measurement accuracy of the tripping value [Hz]:	47.50	47.50	47.51	51.51	51.50	51.50
Trip time limit [ms]:	100 ms			100 ms		
Measurement the trip time [ms]:	95.0	96.4	98.8	91.0	92.0	93.0
+60°C temperature						
Limit [ms]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)		
Measurement accuracy of the tripping value [Hz]:	47.50	47.49	47.50	51.49	51.50	51.49
Trip time limit [ms]:	100 ms			100 ms		
Measurement the trip time [ms]:	98.0	98.8	96.8	97.0	100.0	91.0
Assessment criterion:						
For frequencies of between 47,5 Hz and 51,5 Hz ($\pm 0,1\% fn$) automatic disconnection from the network as a result of a deviation in frequency is not permitted.						
Limit values:						
Frequency decrease protection < 47,5 Hz 100 ms						
Frequency increase protection < 51,5 Hz 100 ms						
Verification is pass when the SPI trip occurs within the following limits for at least 3 consecutive tests:						
<ul style="list-style-type: none"> - $\leq 1\% Vn$ for voltage intervention thresholds - $\pm 20\text{ mHz}$ for frequency intervention thresholds - $\leq 3\% \pm 20\text{ ms}$ for intervention times - $\leq 1\% Vn$ for voltage recovery thresholds - $\pm 20\text{ mHz}$ for frequency recovery thresholds 						
For each repetition of the tests, the max tolerances of the values are:						
Voltage: 2%						
Frequency: $\pm 20\text{ mHz}$						
Trip times: $1\% \pm 20\text{ ms}$						
Note:						
*If the EUT operating temperature out of -10°C to 55°C , please use the upper and lower operating temperature limit in the test.						

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum frequency (81.S2) (use of SPI on the basis of local readings and external information/commands)					P		
Model	AF6K-SL							
	Under frequency:				Over frequency:			
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps				0.99 threshold -> increase by max 10mHz steps			
Ambient temperature								
Limit [Hz]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)				
Measurement accuracy of the tripping value [Hz]:	47.49	47.51	47.51	51.51	51.50	51.51		
Trip time limit [ms]:	4000 ms			1000 ms				
Measurement the trip time [ms]:	3978	3990	3970	991	998	994		
-25°C temperature								
Limit [Hz]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)				
Measurement accuracy of the tripping value [Hz]:	47.50	47.50	47.51	51.50	51.50	51.51		
Trip time limit [ms]:	4000 ms			1000 ms				
Measurement the trip time [ms]:	3980	3990	3990	994	990	994		
+60°C temperature								
Limit [ms]:	47.50 Hz (81<.S2)			51.50 Hz (81>.S2)				
Measurement accuracy of the tripping value [Hz]:	47.50	47.51	47.51	51.51	51.51	51.50		
Trip time limit [ms]:	4000 ms			1000 ms				
Measurement the trip time [ms]:	3990	3980	3990	990	998	998		
Assessment criterion:								
For frequencies of between 47,5 Hz and 51,5 Hz ($\pm 0,1\% fn$) automatic disconnection from the network as a result of a deviation in frequency is not permitted.								
Limit values:								
Frequency decrease protection < 47,5 Hz 4000 ms								
Frequency increase protection < 51,5 Hz 1000 ms								
Verification is pass when the SPI trip occurs within the following limits for at least 3 consecutive tests:								
<ul style="list-style-type: none"> - $\leq 1\% Vn$ for voltage intervention thresholds - $\pm 20\text{ mHz}$ for frequency intervention thresholds - $\leq 3 \% \pm 20\text{ ms}$ for intervention times - $\leq 1 \% Vn$ for voltage recovery thresholds - $\pm 20\text{ mHz}$ for frequency recovery thresholds 								
For each repetition of the tests, the max tolerances of the values are:								
Voltage: 2%								
Frequency: $\pm 20\text{ mHz}$								
Trip times: $1\% \pm 20\text{ ms}$								
Note:								
*If the EUT operating temperature out of -10°C to 55°C , please use the upper and lower operating temperature limit in the test.								

CEI 0-21					
Clause	Requirement - Test			Result - Remark	Verdict
A.4.3.1 & A4.3.2	TABLE: Test procedure for maximum/minimum frequency functions (81.S1)				P
Model	AF6K-SL				
	Under frequency:			Over frequency:	
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps			0.99 threshold -> increase by max 10mHz steps	
D) STEP trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold			0.99 threshold -> 1.01 threshold	
Ambient temperature					
Tripping threshold limit [Hz]:	49.80 (81<.S1)			50.20 (81>.S1)	
Measurement accuracy of the tripping value [Hz]:	49.82	49.81	49.80	50.20	50.21
Trip time limit [ms]:	100			100	
Measurement the trip time [ms]:	98.0	96.0	92.0	94.0	97.0
-25°C temperature					
Tripping threshold limit [Hz]:	49.80 (81<.S1)			50.20 (81>.S1)	
Measurement accuracy of the tripping value [Hz]:	49.81	49.80	49.79	50.21	50.21
Trip time limit [ms]:	100			100	
Measurement the trip time [ms]:	94.8	95.8	95.0	94.0	88.0
+60°C temperature					
Tripping threshold limit [Hz]:	49.80 (81<.S1)			50.20 (81>.S1)	
Measurement accuracy of the tripping value [Hz]:	49.81	49.79	49.81	50.21	50.20
Trip time limit [ms]:	100			100	
Measurement the trip time [ms]:	90.4	92.8	94.8	99.0	98.0
Note: Threshold enabled only with external signal at high value and with high local command.					
Assessment criterion:					
For frequencies of between 49,8 Hz and 50,2 Hz automatic disconnection from the network as a result of a deviation in frequency is not permitted.					
Limit values:					
Frequency decrease protection<49,8 Hz100 ms					
Frequency increase protection<50,2 Hz100 ms					
Verification is pass when the SPI trip occurs within the following limits for at least 3 consecutive tests:					
<ul style="list-style-type: none"> - $\leq 1\% V_n$ for voltage intervention thresholds - $\pm 20\text{ mHz}$ for frequency intervention thresholds - $\leq 3 \% \pm 20\text{ ms}$ for intervention times - $\leq 1 \% V_n$ for voltage recovery thresholds - $\pm 20\text{ mHz}$ for frequency recovery thresholds 					
For each repetition of the tests, the max tolerances of the values are:					
Voltage: 2%					
Frequency: $\pm 20\text{ mHz}$					
Trip times: $1\% \pm 20\text{ ms}$					
Note:					
*If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).					

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict
A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum voltage (27.S1)		P
Model:	AF6K-SL		
	Under voltage:		
A) STEPS for trip value [V to V]:	1.1 threshold -> decrease by 0.5% Vn steps		
D) STEP for trip time [V to V]:	1.1 threshold -> 0.9 threshold		
	Ambient temperature		
Limit [V]:	195.5 V (27.S1)		
Measurement accuracy of the tripping value [V]:	195.54	195.42	195.36
Trip time limit [ms]:	1500 ms		
Measurement the trip time [ms]:	1490	1480	1490
	-25°C temperature		
Limit [V]:	195.5 V (27.S1)		
Measurement accuracy of the tripping value [V]:	195.38	195.71	196.01
Trip time limit [ms]:	1500 ms		
Measurement the trip time [ms]:	1498	1490	1490
	+60°C temperature		
Limit [V]:	195.5 V (27.S1)		
Measurement accuracy of the tripping value [V]:	195.69	195.82	195.55
Trip time limit [ms]:	1500 ms		
Measurement the trip time [ms]:	1490	1498	1480
Note:			
Verification is pass when the SPI trip occurs within the following limits for at least 3 consecutive tests:			
- ≤ 1% Vn for voltage intervention thresholds			
- ±20 mHz for frequency intervention thresholds			
- ≤ 3 % ± 20 ms for intervention times			
- ≤ 1 % Vn for voltage recovery thresholds			
- ±20 mHz for frequency recovery thresholds			
For each repetition of the tests, the max tolerances of the values are:			
Voltage: 2%			
Frequency: ±20mHz			
Trip times: 1%±20ms			
*If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).			

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict
A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum voltage (27.S2) (59.S2)					
Model	AF6K-SL					
	Under voltage:			Over voltage:		
A) STEPS for trip value [V to V]:	1.1 threshold -> decrease by 0.5% Vn steps			0.9 threshold -> increase by 0.5% Vn steps		
D) STEP for trip time [V to V]:	1.1 threshold -> 0.9 threshold			0.9 threshold -> 1.08 threshold		
	Ambient temperature					
Limit [V]:	34.5 V (27.S2)			264.5 V (59.S2)		
Measurement accuracy of the tripping value [V]:	34.51	34.53	34.51	264.52	264.58	265.12
Trip time limit [ms]:	200 ms			200 ms		
Measurement the trip time [ms]:	198.0	196.0	198.8	190.0	198.0	188.0
	-25°C temperature					
Limit [V]:	34.5 V (27.S2)			264.5 V (59.S2)		
Measurement accuracy of the tripping value [V]:	34.49	34.50	34.51	264.58	264.51	264.56
Trip time limit [ms]:	200 ms			200 ms		
Measurement the trip time [ms]:	196.8	188.0	196.0	196.0	190.0	190.0
	+60°C temperature					
Limit [V]:	34.5 V (27.S2)			264.5 V (59.S2)		
Measurement accuracy of the tripping value [V]:	34.48	34.52	34.51	264.59	264.55	264.59
Trip time limit [ms]:	200 ms			200 ms		
Measurement the trip time [ms]:	194.4	188.8	199.6	189.0	192.0	191.0
Note:						
Verification is pass when the SPI trip occurs within the following limits for at least 3 consecutive tests:						
- ≤ 1% Vn for voltage intervention thresholds						
- ±20 mHz for frequency intervention thresholds						
- ≤ 3 % ± 20 ms for intervention times						
- ≤ 1 % Vn for voltage recovery thresholds						
- ±20 mHz for frequency recovery thresholds						
For each repetition of the tests, the max tolerances of the values are:						
Voltage: 2%						
Frequency: ±20mHz						
Trip times: 1%±20ms						
*If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).						


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

A.4.3.1 & A.4.3.2	TABLE: Measuring the rise-in voltage protection as a running 10-minute mean value (59.S1)			
Model:	AF6K-SL			
Test:	Disconnection time:		Limit:	
a)	The voltage is set to 100% U_n and held for 600 s. Thereafter the voltage is set to 112% U_n (257.6 V). Disconnection must take place within 603 s.		≤ 603 s	
	Phase 1	489		
	Phase 2	-		
	Phase 3	-		
b)	The voltage is set to U_n for 600 s and then to 108% U_n (248.4 V) for 600 s. No disconnection should take place.		Disconnection should not take place.	
	Phase 1	No disconnection		
	Phase 2	-		
	Phase 3	-		
c)	The voltage is set to 106 % U_n (243.8 V) and held for 600 s. Thereafter the voltage is set to 114 % U_n (262.6 V). Disconnection must take place within 300 s or about 50 % of the disconnection time measured in point a).*		The disconnection time should be about 50 % of the value measured in a). *	
	Phase 1	292		
	Phase 2	-		
	Phase 3	-		


Note:


*If the setting value is set to 600 s, then the disconnection time can be in the range between 225 s and 375 s.



a)

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
		 <p>b)</p>	




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

A.4.3.3.1	TABLE: Insensitivity to harmonics of the frequency relay							P	
Mode	AF6K-SL								
Grid simulator settings according to Table 17:	Harmonics order:	2nd	3rd	5th	7th	9th	11th	13th	17th
	%U _n :	4,0	10,0	12,0	10,0	3,0	7,0	6,0	4,0
Operating time of the monitoring device:									
	Under frequency:				Over frequency:				
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps				0.99 threshold -> increase by max 10mHz steps				
D) STEP trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold				0.99 threshold -> 1.01 threshold				
Limit [Hz]:	47.50 Hz				51.50 Hz				
Measurement accuracy of the tripping value [V]:	47.49	47.49	47.48	51.51	51.52	51.51			
	100 ms				100 ms				
Measurement the trip time [ms]:	97.7	96.8	97.2	96.8	97.6	96.0			
Under frequency:									
Tek 预览 缩放系数: 25 X 缩放位置 : -23.8ms 4 3 1 4 3 1 1 50.0 V 250 V 50.0 A Z 40.0ms 500k次/秒 5M 点 0.00 V									

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

**Note:**


The setting value and the trip value of the frequency may not vary by more than $\pm 20\text{mHz}$ and $3\% \pm 20\text{ms}$. Differences between the test values: $\pm 20\text{mHz}$ and $1\% \pm 20\text{ms}$.

Screenshot of voltage waveform, distorted as required by CEI 0-21 Table 17 – Harmonics for the insensitivity of the frequency protection function.



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

**Note:**

The protection interface has to have a maximum delay of the remote tripping signal from receiving to transmitting to the DDI of 50ms.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

A.4.3.3.3	TABLE: Communication Signal			P
Model	AF6K-SL			
Enlargement of the frequency limits:		Yes	No	
Enabled the trip of the functions 81<.S1 (49.8Hz) and 81>.S1 (50.2Hz) without communication signal		<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Enabled the trip of the functions 81<.S2 (47.5Hz) and 81>.S2 (51.5Hz) with communication signal		<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Note:				
Figure 35 - Functional logic diagram of the SPI of the power park modules (the values in brackets refer to the transitory operating mode of the SPI)				

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.3.4 TABLE: Verification of insensitivity to the frequency derivative (RoCoF)						P
Model	AF6K-SL					
	Setting threshold (81 >)		Setting trip time		Setting threshold (81 <)	Setting trip time
	51.5 Hz		0.15 s		47.5 Hz	0.15 s
Step	Frequency		Change time	Output power (W)	Result (Continuous operation or not)	Requirement
	Begin	End				
1)	47.55 Hz	47.55 Hz	10.0 s	5890.42	Continuous operation	Stay connected
2)	47.55 Hz	51.45 Hz	1.56 s	5531.60	Continuous operation	Stay connected
3)	51.45 Hz	47.55 Hz	1.56 s	5782.43	Continuous operation	Stay connected
2)	47.55 Hz	51.45 Hz	1.56 s	5358.43	Continuous operation	Stay connected
3)	51.45 Hz	47.55 Hz	1.56 s	5444.25	Continuous operation	Stay connected
2)	47.55 Hz	51.45 Hz	1.56 s	5490.13	Continuous operation	Stay connected
3)	51.45 Hz	47.55 Hz	1.56 s	5746.13	Continuous operation	Stay connected
2)	47.55 Hz	51.45 Hz	1.56 s	5437.57	Continuous operation	Stay connected
3)	51.45 Hz	47.55 Hz	1.56 s	5644.50	Continuous operation	Stay connected
2)	47.55 Hz	51.45 Hz	1.56 s	5466.25	Continuous operation	Stay connected
3)	51.45 Hz	47.55 Hz	1.56 s	5636.43	Continuous operation	Stay connected
5)	47.55 Hz	47.55 Hz	10.0 s	5901.80	Continuous operation	Stay connected

Test procedure:


- 1) Apply a three-phase of symmetrical voltages of direct cyclic sequence having an amplitude of 100% of the rated voltage and a frequency of 47.550 Hz;
- 2) increase the frequency of the three-phase voltages, with ramp steps having an amplitude of 12.5 mHz and duration of 5 ms, until reaching the frequency value of 51.450 Hz;
- 3) decrease the frequency of the three-phase voltages, with ramp steps having an amplitude equal to 12.5 mHz and duration 5 ms until reaching the frequency value of 47.550 Hz;
- 4) repeat the tests referred to in points 2 and 3 above four times, for a total of 5 positive and negative ramps.
- 5) Apply a three-phase of symmetrical voltages of direct cyclic sequence having an amplitude of 100% of the rated voltage and a frequency of 47.550 Hz for 10 s.

Note:

When considering a sliding measurement window of 1.56 s, these profiles have a maximum RoCoF of 2.5 Hz/s.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram:

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.4	TABLE: Self-test			P				
Model	AF6K-SL							
Software version: Control board: V02, Display board: V02								
Can the self-test be activated from any user? (<input checked="" type="checkbox"/> YES; <input type="checkbox"/> NO)								
Do the procedures be written / described in the user manual? (<input checked="" type="checkbox"/> YES; <input type="checkbox"/> NO)								
Can the self-test results and the preset values be clearly readable / displayed? (<input checked="" type="checkbox"/> YES; <input type="checkbox"/> NO)								
Accuracy		Threshold	Disconnection time	Tolerance				
Overvoltage 59.S1	Reading	253.0V	600492ms	Is the voltage thresholds deviation within 1%? (<input checked="" type="checkbox"/> YES, <input type="checkbox"/> NO)				
	Default	253.0 V	<603000 ms					
Overvoltage 59.S2	Reading	264.6V	198ms					
	Default	264.5 V	200 ms					
Undervoltage 27.S1	Reading	195.4V	1490ms	Is the time deviation within 3% ± 20 ms? (<input checked="" type="checkbox"/> YES, <input type="checkbox"/> NO)				
	Default	195.5 V	1500 ms					
Undervoltage 27.S2	Reading	34.4V	196ms					
	Default	34.5 V	200 ms					
Overfrequency 81>.S1	Reading	50.2 Hz	95 ms	Is the frequency thresholds deviation within ± 20 mHz? (<input checked="" type="checkbox"/> YES, <input type="checkbox"/> NO)				
	Default	50.2 Hz	100 ms					
Overfrequency 81>.S2	Reading	51.5 Hz	98 ms					
	Default	51.5 Hz	100 ms					
Underfrequency 81<.S1	Reading	49.8 Hz	99 ms	Is the time deviation within 3% ± 20 ms? (<input checked="" type="checkbox"/> YES, <input type="checkbox"/> NO)				
	Default	49.8 Hz	100 ms					
Underfrequency 81<.S2	Reading	47.5 Hz	97 ms					
	Default	47.5 Hz	100 ms					

Note:

In the event that the interface protection functions are integrated into the inverter, at least one self-test system must be provided to check the maximum / minimum frequency and maximum / minimum voltage functions provided for in the SPI as described below:

- for each frequency and voltage protection function, the rise or fall intervention threshold shall be linearly varied with a ramp $\leq 0,05 \text{ Hz/s}$ or $\leq 0,05 \text{ Vn/s}$ for frequency and voltage protection respectively;
- this determines, at a certain point of the test, the coincidence between the threshold and the current value of the controlled magnitude (frequency or voltage) and therefore the intervention of the protection and the consequent opening of the interface device.

For each test the values of the quantities and the intervention times shall be viewable by the tester as well as the current value of the voltage and frequency detected by the converter.

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict
Diagram of auto-test:			
Overvoltage 59.S1			
<p style="text-align: center;">Test 59.S1</p> <p>V_Thr: 253.0V V_Ave: 253.1V V_59.S1: 253.0V T_59.S1: 492ms</p>			
Overvoltage 59.S2			
<p style="text-align: center;">Test 59.S2</p> <p>V_Thr: 264.5V V: 264.8V V_59.S2: 264.6V T_59.S2: 198ms</p>			
Undervoltage 27.S1			
<p style="text-align: center;">Test 27.S1</p> <p>V_Thr: 195.5V V: 195.3V V_27.S1: 195.4V T_27.S1: 1490ms</p>			
Undervoltage 27.S2			
<p style="text-align: center;">Test 27.S2</p> <p>V_Thr: 34.5V V: 34.2V V_27.S2: 34.4V T_27.S2: 196ms</p>			

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict
Overfrequency 81>S1			
<p>Test 81>.S1</p> <p>F_Thr: 50.20Hz F: 50.20Hz F_81>.S1: 50.20Hz T_81>.S1: 95ms</p>			
Overfrequency 81>S2			
<p>Test 81>.S2</p> <p>F_Thr: 51.50Hz F: 51.50Hz F_81>.S2: 51.50Hz T_81>.S2: 98ms</p>			
Underfrequency 81<S1			
<p>Test 81<.S1</p> <p>F_Thr: 49.80Hz F: 49.80Hz F_81<.S1: 49.80Hz T_81<.S1: 99ms</p>			
Underfrequency 81<S2			
<p>Test 81<.S2</p> <p>F_Thr: 47.50Hz F: 47.50Hz F_81<.S2: 47.50Hz T_81<.S2: 97ms</p>			

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

A.4.5		TABLE: Single fault tolerance			P
Model		AF6K-SL			
Ambient temperature (°C)		25°C			
No.	component No.	fault	test voltage (V)	test time	result
1	ISO Relay (ALFG1)	Short circuit before start up inverter	360Vdc-230Vac	3min	Unit can't operating, error massage: Iso Fault. No danger, no hazard, no fire.
2	Monitoring Relay – L (K1)	Pin3 to Pin4 short circuit before start up inverter	360Vdc-230Vac	3min	Unit can't operating, error massage: GridRelay Fault. No danger, no hazard, no fire.
3	Monitoring Relay – L (K1)	Pin3 to Pin4 open circuit before start up inverter	360Vdc-230Vac	3min	Unit can't operating, error massage: GridRelay Fault. No danger, no hazard, no fire.
4	Monitoring Relay - N(K3)	Pin3 to Pin4 short circuit before start up inverter	360Vdc-230Vac	3min	Unit can't operating, error massage: GridRelay Fault. No danger, no hazard, no fire.
5	Monitoring Relay - N(K3)	Pin3 to Pin4 open circuit before start up inverter	360Vdc-230Vac	3min	Unit can't operating, error massage: GridRelay Fault. No danger, no hazard, no fire.
6	AC voltage measure1 (D4)	Pin2-Pin3	360Vdc-230Vac	3min	Unit shut down, Error message: GridOverVolt Fault. No danger, no hazard, no fire.
7	AC voltage measure1(D 4)	Pin1-Pin3 Short circuit	360Vdc-230Vac	3min	Unit shut down, Error message: GridOverVolt Fault. No danger, no hazard, no fire.
8	AC current measure1(D 19)	Pin1-Pin3 Short circuit	360Vdc-230Vac	3min	Unit can't operating, error message: RInvCurAdChaFault. No danger, no hazard, no fire.
9	AC current measure1(D 19)	Pin2-Pin3 Short circuit	360Vdc-230Vac	3min	Unit can't operating, error message: RInvCurAdChaFault. No danger, no hazard, no fire.
10	AC frequency measure(R2 55)	Pin1-Pin2 Short circuit	360Vdc-230Vac	3min	Unit shut down, error message: GridOverFreq Fault. No danger, no hazard, no fire.
11	V- busmeasure (D31)	Pin2-Pin3 Short circuit	360Vdc-230Vac	3min	Unit can't operating,Error massage: BusAllVoltHwOveFault. No danger, no hazard, no fire.
12	DC current measure1(R 247)	Pin1-Pin2 Short circuit	360Vdc-230Vac	3min	Unit shut down,error message: Pv1HwOverCurrFault. No danger, no hazard, no fire.
13	DC current measure2(R 248)	Pin1-Pin2 Short circuit	360Vdc-230Vac	3min	Unit shut down,error message: Pv2HwOverCurrFault. No danger, no hazard, no fire.

CEI 0-21					
Clause	Requirement - Test			Result - Remark	Verdict
14	T measure(R1 80)	Pin1-Pin2 Short circuit	360Vdc-230Vac	3min	Unit can't operating,Error massage: TemperatureAdChanFault.No damage, no hazard, no fire.
15	power tube Boost(Q2)	Pin2-Pin3 Short circuit before start up	360Vdc-230Vac	3min	Unit can not start up, No damage, no hazard, no fire.
16	Diode(D2)	Short circuit	360Vdc-230Vac	3min	Unit normal operation, No danger, no hazard, no fire.
17	power tube IGBT(QA5)	Pin2-Pin3 Short circuit before start up	360Vdc-230Vac	3min	Unit can't operating, error massage: InvOpenTestErr. No danger, no hazard, no fire.
18	power tube IGBT(QA6)	Pin2-Pin3 Short circuit before start up	360Vdc-230Vac	3min	Unit shut down, error message: InvOpenTestErr. No danger, no hazard, no fire.
19	GFCI check	Short circuit	360Vdc-230Vac	3min	Unit shut down, error message: LeakCurrFault. No danger, no hazard, no fire.
20	Bus cap(C208)	Pin1-Pin2 Short circuit before start up	360Vdc-230Vac	3min	Unit can not start up, No damage, no hazard, no fire.
21	Transformer short circuit tests (T4)	Pin22-Pin24 Short circuit	360Vdc-230Vac	3min	Unit can not start up, No damage, no hazard, no fire.
22	Transformer short circuit tests(T4)	Pin32-Pin36 Short circuit	360Vdc-230Vac	3min	Unit can not start up, No damage, no hazard, no fire.
23	power tube MOS-SPS(Q-MOS1)	G-D Short circuit	360Vdc-230Vac	3min	SPS no output, No danger, no hazard, no fire.
24	power tube MOS-SPS(Q-MOS1)	D-S Short circuit	360Vdc-230Vac	3min	SPS no output, No danger, no hazard, no fire.
25	Output L to N	short circuit	360Vdc-230Vac	3min	Unit shut down, error message:GridUnderVoltFault. No danger, no hazard, no fire.
26	Output L to PE	short circuit	360Vdc-230Vac	3min	Unit shut down ,error message:GridLossFault. No danger, no hazard, no fire.
27	DC	--	360Vdc-230Vac	3min	Vdc=0, VBAT=0
28	AC	--	360Vdc-230Vac	3min	Vdc=0, VBAT=0
29	BAT	--	360Vdc-230Vac	3min	Vdc=0, Vac=0
30	Overload	Output overload (110%)	360Vdc-230Vac	3min	Unit normal operation. No danger, no hazard, no fire.



CEI 0-21					
Clause	Requirement - Test			Result - Remark	Verdict
31	Cooling system failure – Blanketing test	Put the unit to box	360Vdc-230Vac	1 hour	1 hour power run at 50%
32	PV+ to PV-	Reverse polarity	360Vdc-230Vac	3min	Unit can not start up. No danger, no hazard, no fire.
33	Output L - N	Reverse polarity before start up	360Vdc-230Vac	3min	Unit normal operation. No danger, no hazard, no fire.
Supplementary information: Tests performed under abnormal or fault conditions shall be tested with a source capable of 1,25 to 1,5 times the PCE rated maximum input current (Isc PV) for that input.					

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.7	TABLE: Climatic compatibility tests		
Model	AF6K-SL		
Climatic tests of unpowered equipment:			
Temperature	Relative humidity	Standards	Test time
70°C ± 2°C	--	EN 60068-2-2	16h
40°C ± 2°C	93% ± 3%	EN 60068-2-78	4 days
-25°C ± 2°C	--	EN 60068-2-1	16h
-25°C -> +70°C ± 2°C	--	EN 60068-2-14	3h @ -25°C, 3h @ +70°C
Climatic tests of powered equipment:			
Temperature	Relative humidity	Standards	Test time
60°C± 2°C*	--	EN 60068-2-2	16h
40°C ± 2°C	93% ± 3%	EN 60068-2-78	4 days
-25°C ± 2°C	--	EN 60068-2-1	16h
-25°C -> +60°C ± 2°C*	--	EN 60068-2-14	3h @ -25°C, 3h @ +60°C
<p>Note: The unit is not allowed to be damaged while testing. *If the PV inverter max operating temperature above 55°C, please use the max operating temperature in the test.</p>			



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Temperature diagram of unpowered equipment:**Temperature diagram of unpowered equipment:**



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Temperature diagram of unpowered equipment:**Temperature diagram of unpowered equipment:**



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Temperature diagram of unpowered equipment:**Temperature diagram of unpowered equipment:**

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Temperature diagram of unpowered equipment:**Temperature diagram of unpowered equipment:**

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.8	TABLE: Insulation tests (CEI EN 60255-5)		P
Model	AF6K-SL		
	Location	Test voltage	Result
Rigidity of electricity:			
AC to PE	2 kVac / 2.8kVdc		P
DC to PE	2 kVac / 2.8kVdc		P
AC to communication port	2 kVac / 2.8kVdc		P
DC to communication port	2 kVac / 2.8kVdc		P
Impulse test:			
AC to PE	5 kV (1.2/50μs)		P
DC to PE	5 kV (1.2/50μs)		P
AC to communication port	5 kV (1.2/50μs)		P
DC to communication port	5 kV (1.2/50μs)		P
Measurement of the insulation resistance:			
AC to PE	>100 MΩ at 500 Vdc		P
DC to PE	>100 MΩ at 500 Vdc		P
AC to communication port	>100 MΩ at 500 Vdc		P
DC to communication port	>100 MΩ at 500 Vdc		P
Note:			

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.9	TABLE: Test for the overload capacity of measuring circuits		P
Model	AF6K-SL		
	Voltage	Test time	Result:
	$\geq 130\% U_N$	permanent	P
	$\geq 150\% U_N$	1s	P
Note:	The unit is not allowed to be damaged while testing. The measurement circuit must show after the test the same values like before the test.		

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

A.4.11	TABLE: Automatic mechanism to prevent current imbalance during production		N/A
Model	AF6K-SL		
Test No. 1			
Imbalance of power:	Test time:	Limit:	
6kW<P<10kW	30min	max. 30 min	
Test No.2			
Imbalance of power:	Test time:	Limit:	
P>10kW	1min	max. 1 min	
Note:			
Test No.1			
<ul style="list-style-type: none"> - System operating at its nominal conditions; - Creation of a permanent artificial imbalance greater than 6 kW and less than 10 kW ; - Checking the disconnection of the entire production system using the interface device (DDI) within a maximum time of 30 min. 			
Test No.2:			
<ul style="list-style-type: none"> - System operating at its nominal conditions; - Creation of a permanent artificial imbalance greater than 10 kW ; - Checking the disconnection of the entire production system using the interface device (DDI) within a maximum time of 1 min. 			

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

B.1 a) / b)	TABLE: Harmonic current emission	P
Model	AF6K-SL	
<input checked="" type="checkbox"/> CEI EN 61000-3-2		
<input checked="" type="checkbox"/> CEI EN 61000-3-12		
<input checked="" type="checkbox"/> Ambient temperature		
<input checked="" type="checkbox"/> -25°C temperature		
<input checked="" type="checkbox"/> +60°C temperature		
<input checked="" type="checkbox"/> 100% P _n		
<input checked="" type="checkbox"/> 66% P _n		
<input checked="" type="checkbox"/> 33% P _n		
Note:	*If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).	

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	6072.30 (100% P _n , 60°C)		
	Voltage (V)	230.00		
	Current (A)	26.45		
	Power Factor	0.998		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.087	--	Single phase	--
2nd	0.096	0.369	Single phase	8
3rd	0.621	2.381	Single phase	21,6
4th	0.053	0.202	Single phase	4
5th	0.471	1.804	Single phase	10,7
6th	0.014	0.054	Single phase	2,7
7th	0.359	1.376	Single phase	7,2
8th	0.007	0.026	Single phase	2
9th	0.268	1.029	Single phase	3,8
10th	0.042	0.161	Single phase	1,6
11th	0.201	0.769	Single phase	3,1
12th	0.011	0.041	Single phase	1,3
13th	0.122	0.469	Single phase	2
14th	0.020	0.075	Single phase	N/A
15th	0.085	0.325	Single phase	N/A
16th	0.024	0.090	Single phase	N/A
17th	0.055	0.210	Single phase	N/A
18th	0.014	0.054	Single phase	N/A
19th	0.039	0.149	Single phase	N/A
20th	0.012	0.046	Single phase	N/A
21st	0.041	0.157	Single phase	N/A
22nd	0.012	0.048	Single phase	N/A
23rd	0.030	0.114	Single phase	N/A
24th	0.006	0.024	Single phase	N/A
25th	0.028	0.106	Single phase	N/A
26th	0.006	0.025	Single phase	N/A
27th	0.024	0.094	Single phase	N/A
28th	0.005	0.020	Single phase	N/A
29th	0.019	0.074	Single phase	N/A
30th	0.004	0.015	Single phase	N/A
31st	0.018	0.068	Single phase	N/A
32nd	0.004	0.016	Single phase	N/A
33rd	0.013	0.049	Single phase	N/A
34th	0.006	0.023	Single phase	N/A
35th	0.013	0.049	Single phase	N/A
36th	0.004	0.016	Single phase	N/A
37th	0.012	0.047	Single phase	N/A
38th	0.005	0.018	Single phase	N/A
39th	0.011	0.042	Single phase	N/A
40th	0.005	0.021	Single phase	N/A
THD	--	3.700	Single phase	23
PWHD	--	2.189	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	6071.02 (100% P _n , -25°C)		
	Voltage (V)	230.03		
	Current (A)	26.44		
	Power Factor	0.998		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.087	--	Single phase	--
2nd	0.097	0.373	Single phase	8
3rd	0.617	2.366	Single phase	21,6
4th	0.052	0.201	Single phase	4
5th	0.464	1.781	Single phase	10,7
6th	0.014	0.055	Single phase	2,7
7th	0.355	1.361	Single phase	7,2
8th	0.008	0.030	Single phase	2
9th	0.264	1.011	Single phase	3,8
10th	0.039	0.150	Single phase	1,6
11th	0.197	0.754	Single phase	3,1
12th	0.010	0.038	Single phase	1,3
13th	0.121	0.463	Single phase	2
14th	0.020	0.077	Single phase	N/A
15th	0.086	0.329	Single phase	N/A
16th	0.024	0.093	Single phase	N/A
17th	0.054	0.208	Single phase	N/A
18th	0.015	0.056	Single phase	N/A
19th	0.039	0.148	Single phase	N/A
20th	0.015	0.056	Single phase	N/A
21st	0.039	0.150	Single phase	N/A
22nd	0.014	0.053	Single phase	N/A
23rd	0.030	0.114	Single phase	N/A
24th	0.008	0.030	Single phase	N/A
25th	0.027	0.102	Single phase	N/A
26th	0.007	0.028	Single phase	N/A
27th	0.024	0.091	Single phase	N/A
28th	0.006	0.024	Single phase	N/A
29th	0.019	0.072	Single phase	N/A
30th	0.004	0.016	Single phase	N/A
31st	0.016	0.063	Single phase	N/A
32nd	0.005	0.018	Single phase	N/A
33rd	0.013	0.049	Single phase	N/A
34th	0.006	0.024	Single phase	N/A
35th	0.012	0.046	Single phase	N/A
36th	0.004	0.015	Single phase	N/A
37th	0.013	0.050	Single phase	N/A
38th	0.005	0.020	Single phase	N/A
39th	0.012	0.045	Single phase	N/A
40th	0.005	0.018	Single phase	N/A
THD	--	3.700	Single phase	23
PWHD	--	2.261	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	6070.70 (100% P _n , 25°C)		
	Voltage (V)	230.03		
	Current (A)	26.44		
	Power Factor	0.998		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.087	--	Single phase	--
2nd	0.096	0.370	Single phase	8
3rd	0.627	2.405	Single phase	21,6
4th	0.054	0.207	Single phase	4
5th	0.466	1.787	Single phase	10,7
6th	0.014	0.053	Single phase	2,7
7th	0.356	1.363	Single phase	7,2
8th	0.009	0.033	Single phase	2
9th	0.265	1.015	Single phase	3,8
10th	0.041	0.158	Single phase	1,6
11th	0.198	0.759	Single phase	3,1
12th	0.008	0.030	Single phase	1,3
13th	0.122	0.467	Single phase	2
14th	0.021	0.081	Single phase	N/A
15th	0.085	0.327	Single phase	N/A
16th	0.023	0.090	Single phase	N/A
17th	0.054	0.206	Single phase	N/A
18th	0.013	0.050	Single phase	N/A
19th	0.038	0.146	Single phase	N/A
20th	0.014	0.053	Single phase	N/A
21st	0.041	0.156	Single phase	N/A
22nd	0.012	0.047	Single phase	N/A
23rd	0.029	0.112	Single phase	N/A
24th	0.007	0.029	Single phase	N/A
25th	0.027	0.103	Single phase	N/A
26th	0.007	0.025	Single phase	N/A
27th	0.024	0.093	Single phase	N/A
28th	0.005	0.020	Single phase	N/A
29th	0.019	0.074	Single phase	N/A
30th	0.004	0.015	Single phase	N/A
31st	0.017	0.066	Single phase	N/A
32nd	0.004	0.015	Single phase	N/A
33rd	0.013	0.048	Single phase	N/A
34th	0.005	0.020	Single phase	N/A
35th	0.012	0.045	Single phase	N/A
36th	0.004	0.016	Single phase	N/A
37th	0.013	0.050	Single phase	N/A
38th	0.005	0.018	Single phase	N/A
39th	0.011	0.042	Single phase	N/A
40th	0.004	0.017	Single phase	N/A
THD	--	3.731	Single phase	23
PWHD	--	2.221	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	4026.52 (66% P _n , 60°C)		
	Voltage (V)	230.15		
	Current (A)	17.55		
	Power Factor	0.997		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	17.217	--	Single phase	--
2nd	0.080	0.466	Single phase	8
3rd	0.563	3.268	Single phase	21,6
4th	0.030	0.176	Single phase	4
5th	0.418	2.425	Single phase	10,7
6th	0.011	0.063	Single phase	2,7
7th	0.297	1.728	Single phase	7,2
8th	0.015	0.085	Single phase	2
9th	0.204	1.187	Single phase	3,8
10th	0.009	0.051	Single phase	1,6
11th	0.133	0.770	Single phase	3,1
12th	0.014	0.083	Single phase	1,3
13th	0.077	0.450	Single phase	2
14th	0.011	0.064	Single phase	N/A
15th	0.066	0.383	Single phase	N/A
16th	0.014	0.079	Single phase	N/A
17th	0.052	0.305	Single phase	N/A
18th	0.017	0.098	Single phase	N/A
19th	0.042	0.242	Single phase	N/A
20th	0.009	0.050	Single phase	N/A
21st	0.037	0.214	Single phase	N/A
22nd	0.007	0.039	Single phase	N/A
23rd	0.027	0.158	Single phase	N/A
24th	0.006	0.032	Single phase	N/A
25th	0.021	0.124	Single phase	N/A
26th	0.004	0.023	Single phase	N/A
27th	0.015	0.088	Single phase	N/A
28th	0.004	0.022	Single phase	N/A
29th	0.012	0.070	Single phase	N/A
30th	0.005	0.030	Single phase	N/A
31st	0.010	0.060	Single phase	N/A
32nd	0.005	0.026	Single phase	N/A
33rd	0.006	0.035	Single phase	N/A
34th	0.005	0.031	Single phase	N/A
35th	0.007	0.040	Single phase	N/A
36th	0.004	0.023	Single phase	N/A
37th	0.010	0.060	Single phase	N/A
38th	0.004	0.025	Single phase	N/A
39th	0.009	0.052	Single phase	N/A
40th	0.004	0.021	Single phase	N/A
THD	--	4.871	Single phase	23
PWHD	--	2.865	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
Active power (W)		4026.17 (66% P _n , -25°C)		
Voltage (V)		230.15		
Current (A)		17.55		
Power Factor		0.997		
Frequency (Hz)		50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	17.217	--	Single phase	--
2nd	0.079	0.458	Single phase	8
3rd	0.561	3.259	Single phase	21,6
4th	0.031	0.178	Single phase	4
5th	0.417	2.423	Single phase	10,7
6th	0.012	0.068	Single phase	2,7
7th	0.296	1.721	Single phase	7,2
8th	0.015	0.087	Single phase	2
9th	0.205	1.191	Single phase	3,8
10th	0.009	0.050	Single phase	1,6
11th	0.132	0.768	Single phase	3,1
12th	0.014	0.083	Single phase	1,3
13th	0.076	0.442	Single phase	2
14th	0.008	0.049	Single phase	N/A
15th	0.066	0.385	Single phase	N/A
16th	0.013	0.075	Single phase	N/A
17th	0.052	0.304	Single phase	N/A
18th	0.016	0.091	Single phase	N/A
19th	0.043	0.248	Single phase	N/A
20th	0.008	0.045	Single phase	N/A
21st	0.038	0.219	Single phase	N/A
22nd	0.007	0.041	Single phase	N/A
23rd	0.028	0.161	Single phase	N/A
24th	0.004	0.025	Single phase	N/A
25th	0.022	0.126	Single phase	N/A
26th	0.004	0.023	Single phase	N/A
27th	0.016	0.095	Single phase	N/A
28th	0.004	0.021	Single phase	N/A
29th	0.013	0.073	Single phase	N/A
30th	0.005	0.030	Single phase	N/A
31st	0.010	0.059	Single phase	N/A
32nd	0.004	0.024	Single phase	N/A
33rd	0.006	0.034	Single phase	N/A
34th	0.004	0.021	Single phase	N/A
35th	0.007	0.039	Single phase	N/A
36th	0.004	0.021	Single phase	N/A
37th	0.010	0.060	Single phase	N/A
38th	0.005	0.029	Single phase	N/A
39th	0.008	0.048	Single phase	N/A
40th	0.004	0.022	Single phase	N/A
THD	--	4.842	Single phase	23
PWHD	--	2.859	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b) TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)				P
Model	AF6K-SL			
Active power (W)	4025.66 (66% P _n , 25°C)			
Voltage (V)	230.16			
Current (A)	17.54			
Power Factor	0.997			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	17.217	--	Single phase	--
2nd	0.080	0.466	Single phase	8
3rd	0.560	3.253	Single phase	21,6
4th	0.031	0.180	Single phase	4
5th	0.416	2.413	Single phase	10,7
6th	0.013	0.075	Single phase	2,7
7th	0.295	1.714	Single phase	7,2
8th	0.014	0.084	Single phase	2
9th	0.204	1.187	Single phase	3,8
10th	0.008	0.046	Single phase	1,6
11th	0.132	0.767	Single phase	3,1
12th	0.015	0.088	Single phase	1,3
13th	0.078	0.452	Single phase	2
14th	0.010	0.059	Single phase	N/A
15th	0.067	0.388	Single phase	N/A
16th	0.015	0.086	Single phase	N/A
17th	0.053	0.306	Single phase	N/A
18th	0.017	0.100	Single phase	N/A
19th	0.042	0.242	Single phase	N/A
20th	0.009	0.050	Single phase	N/A
21st	0.037	0.214	Single phase	N/A
22nd	0.008	0.044	Single phase	N/A
23rd	0.027	0.158	Single phase	N/A
24th	0.005	0.027	Single phase	N/A
25th	0.021	0.120	Single phase	N/A
26th	0.005	0.027	Single phase	N/A
27th	0.016	0.091	Single phase	N/A
28th	0.004	0.023	Single phase	N/A
29th	0.013	0.074	Single phase	N/A
30th	0.005	0.027	Single phase	N/A
31st	0.009	0.052	Single phase	N/A
32nd	0.005	0.029	Single phase	N/A
33rd	0.006	0.037	Single phase	N/A
34th	0.004	0.025	Single phase	N/A
35th	0.006	0.038	Single phase	N/A
36th	0.003	0.020	Single phase	N/A
37th	0.010	0.055	Single phase	N/A
38th	0.005	0.026	Single phase	N/A
39th	0.009	0.053	Single phase	N/A
40th	0.004	0.023	Single phase	N/A
THD	--	4.860	Single phase	23
PWHD	--	2.851	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	2014.49 (33% P _n , 60°C)		
	Voltage (V)	229.96		
	Current (A)	8.83		
	Power Factor	0.992		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.609	--	Single phase	--
2nd	0.031	0.354	Single phase	8
3rd	0.524	6.090	Single phase	21,6
4th	0.009	0.106	Single phase	4
5th	0.321	3.730	Single phase	10,7
6th	0.013	0.151	Single phase	2,7
7th	0.176	2.045	Single phase	7,2
8th	0.026	0.301	Single phase	2
9th	0.118	1.373	Single phase	3,8
10th	0.013	0.156	Single phase	1,6
11th	0.081	0.936	Single phase	3,1
12th	0.006	0.066	Single phase	1,3
13th	0.041	0.476	Single phase	2
14th	0.007	0.077	Single phase	N/A
15th	0.032	0.371	Single phase	N/A
16th	0.004	0.049	Single phase	N/A
17th	0.017	0.196	Single phase	N/A
18th	0.006	0.066	Single phase	N/A
19th	0.010	0.121	Single phase	N/A
20th	0.005	0.059	Single phase	N/A
21st	0.014	0.165	Single phase	N/A
22nd	0.008	0.096	Single phase	N/A
23rd	0.007	0.081	Single phase	N/A
24th	0.006	0.071	Single phase	N/A
25th	0.012	0.135	Single phase	N/A
26th	0.003	0.041	Single phase	N/A
27th	0.013	0.151	Single phase	N/A
28th	0.004	0.046	Single phase	N/A
29th	0.010	0.112	Single phase	N/A
30th	0.005	0.062	Single phase	N/A
31st	0.008	0.090	Single phase	N/A
32nd	0.004	0.045	Single phase	N/A
33rd	0.005	0.062	Single phase	N/A
34th	0.004	0.042	Single phase	N/A
35th	0.005	0.058	Single phase	N/A
36th	0.005	0.055	Single phase	N/A
37th	0.007	0.082	Single phase	N/A
38th	0.003	0.039	Single phase	N/A
39th	0.006	0.075	Single phase	N/A
40th	0.005	0.055	Single phase	N/A
THD	--	7.968	Single phase	23
PWHD	--	2.708	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	2009.97 (33% P _n , -25°C)		
	Voltage (V)	229.97		
	Current (A)	8.81		
	Power Factor	0.992		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.609	--	Single phase	--
2nd	0.031	0.358	Single phase	8
3rd	0.527	6.122	Single phase	21,6
4th	0.010	0.118	Single phase	4
5th	0.322	3.738	Single phase	10,7
6th	0.014	0.159	Single phase	2,7
7th	0.177	2.053	Single phase	7,2
8th	0.026	0.301	Single phase	2
9th	0.117	1.355	Single phase	3,8
10th	0.013	0.147	Single phase	1,6
11th	0.080	0.931	Single phase	3,1
12th	0.005	0.061	Single phase	1,3
13th	0.041	0.475	Single phase	2
14th	0.007	0.080	Single phase	N/A
15th	0.031	0.362	Single phase	N/A
16th	0.005	0.052	Single phase	N/A
17th	0.016	0.185	Single phase	N/A
18th	0.006	0.070	Single phase	N/A
19th	0.010	0.119	Single phase	N/A
20th	0.005	0.058	Single phase	N/A
21st	0.014	0.164	Single phase	N/A
22nd	0.008	0.094	Single phase	N/A
23rd	0.007	0.082	Single phase	N/A
24th	0.005	0.063	Single phase	N/A
25th	0.011	0.133	Single phase	N/A
26th	0.004	0.043	Single phase	N/A
27th	0.013	0.155	Single phase	N/A
28th	0.004	0.048	Single phase	N/A
29th	0.009	0.106	Single phase	N/A
30th	0.005	0.063	Single phase	N/A
31st	0.008	0.090	Single phase	N/A
32nd	0.004	0.048	Single phase	N/A
33rd	0.006	0.070	Single phase	N/A
34th	0.004	0.045	Single phase	N/A
35th	0.005	0.055	Single phase	N/A
36th	0.004	0.050	Single phase	N/A
37th	0.007	0.083	Single phase	N/A
38th	0.004	0.044	Single phase	N/A
39th	0.007	0.077	Single phase	N/A
40th	0.004	0.047	Single phase	N/A
THD	--	7.950	Single phase	23
PWHD	--	2.694	Single phase	23

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
B1 a)/b)	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% P_n / 66% P_n / 33% P_n (CEI EN 61000-3-12)			P
Model	AF6K-SL			
	Active power (W)	2015.11 (33% P _n , 25°C)		
	Voltage (V)	229.97		
	Current (A)	8.83		
	Power Factor	0.992		
	Frequency (Hz)	50.00		
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.609	--	Single phase	--
2nd	0.033	0.381	Single phase	8
3rd	0.523	6.075	Single phase	21,6
4th	0.009	0.101	Single phase	4
5th	0.322	3.741	Single phase	10,7
6th	0.012	0.144	Single phase	2,7
7th	0.177	2.059	Single phase	7,2
8th	0.029	0.332	Single phase	2
9th	0.118	1.368	Single phase	3,8
10th	0.014	0.164	Single phase	1,6
11th	0.080	0.924	Single phase	3,1
12th	0.006	0.070	Single phase	1,3
13th	0.041	0.478	Single phase	2
14th	0.006	0.074	Single phase	N/A
15th	0.031	0.364	Single phase	N/A
16th	0.004	0.046	Single phase	N/A
17th	0.016	0.181	Single phase	N/A
18th	0.006	0.069	Single phase	N/A
19th	0.010	0.121	Single phase	N/A
20th	0.005	0.060	Single phase	N/A
21st	0.014	0.167	Single phase	N/A
22nd	0.009	0.104	Single phase	N/A
23rd	0.008	0.088	Single phase	N/A
24th	0.006	0.070	Single phase	N/A
25th	0.012	0.139	Single phase	N/A
26th	0.004	0.041	Single phase	N/A
27th	0.014	0.158	Single phase	N/A
28th	0.004	0.047	Single phase	N/A
29th	0.010	0.118	Single phase	N/A
30th	0.005	0.062	Single phase	N/A
31st	0.008	0.094	Single phase	N/A
32nd	0.004	0.047	Single phase	N/A
33rd	0.006	0.070	Single phase	N/A
34th	0.004	0.046	Single phase	N/A
35th	0.005	0.053	Single phase	N/A
36th	0.004	0.048	Single phase	N/A
37th	0.007	0.083	Single phase	N/A
38th	0.004	0.041	Single phase	N/A
39th	0.006	0.070	Single phase	N/A
40th	0.004	0.052	Single phase	N/A
THD	--	7.971	Single phase	23
PWHD	--	2.678	Single phase	23

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
60°C, 100% P_n power condition:						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.014	--	--	1.080		
3rd	0.311	--	--	2.300		
4th	0.010	--	--	0.430		
5th	0.177	--	--	1.140		
6th	0.006	--	--	0.300		
7th	0.067	--	--	0.770		
8th	0.008	--	--	0.230		
9th	0.014	--	--	0.400		
10th	0.005	--	--	0.184		
11th	0.019	--	--	0.330		
12th	0.004	--	--	0.153		
13th	0.027	--	--	0.210		
14th	0.005	--	--	0.131		
15th	0.031	--	--	0.150		
16th	0.005	--	--	0.115		
17th	0.018	--	--	0.132		
18th	0.005	--	--	0.102		
19th	0.017	--	--	0.118		
20th	0.003	--	--	0.092		
21th	0.007	--	--	0.107		
22th	0.007	--	--	0.084		
23th	0.011	--	--	0.098		
24th	0.003	--	--	0.077		
25th	0.012	--	--	0.090		
26th	0.004	--	--	0.071		
27th	0.013	--	--	0.083		
28th	0.004	--	--	0.066		
29th	0.007	--	--	0.078		
30th	0.003	--	--	0.061		
31th	0.007	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.004	--	--	0.068		
34th	0.004	--	--	0.054		
35th	0.008	--	--	0.064		
36th	0.003	--	--	0.051		
37th	0.008	--	--	0.061		
38th	0.003	--	--	0.048		
39th	0.008	--	--	0.058		
40th	0.003	--	--	0.046		

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
60°C, 66% P_n power condition:						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.013	--	--	1.080		
3rd	0.331	--	--	2.300		
4th	0.009	--	--	0.430		
5th	0.122	--	--	1.140		
6th	0.007	--	--	0.300		
7th	0.020	--	--	0.770		
8th	0.008	--	--	0.230		
9th	0.058	--	--	0.400		
10th	0.007	--	--	0.184		
11th	0.057	--	--	0.330		
12th	0.008	--	--	0.153		
13th	0.033	--	--	0.210		
14th	0.008	--	--	0.131		
15th	0.017	--	--	0.150		
16th	0.004	--	--	0.115		
17th	0.029	--	--	0.132		
18th	0.006	--	--	0.102		
19th	0.028	--	--	0.118		
20th	0.004	--	--	0.092		
21th	0.017	--	--	0.107		
22th	0.005	--	--	0.084		
23th	0.017	--	--	0.098		
24th	0.004	--	--	0.077		
25th	0.016	--	--	0.090		
26th	0.003	--	--	0.071		
27th	0.016	--	--	0.083		
28th	0.003	--	--	0.066		
29th	0.008	--	--	0.078		
30th	0.004	--	--	0.061		
31th	0.010	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.010	--	--	0.068		
34th	0.003	--	--	0.054		
35th	0.009	--	--	0.064		
36th	0.004	--	--	0.051		
37th	0.007	--	--	0.061		
38th	0.003	--	--	0.048		
39th	0.009	--	--	0.058		
40th	0.003	--	--	0.046		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
60°C, 33% P_n power condition:				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.014	--	--	1.080
3rd	0.297	--	--	2.300
4th	0.009	--	--	0.430
5th	0.096	--	--	1.140
6th	0.009	--	--	0.300
7th	0.134	--	--	0.770
8th	0.007	--	--	0.230
9th	0.053	--	--	0.400
10th	0.008	--	--	0.184
11th	0.073	--	--	0.330
12th	0.007	--	--	0.153
13th	0.050	--	--	0.210
14th	0.007	--	--	0.131
15th	0.052	--	--	0.150
16th	0.008	--	--	0.115
17th	0.039	--	--	0.132
18th	0.004	--	--	0.102
19th	0.038	--	--	0.118
20th	0.004	--	--	0.092
21th	0.031	--	--	0.107
22th	0.005	--	--	0.084
23th	0.024	--	--	0.098
24th	0.003	--	--	0.077
25th	0.018	--	--	0.090
26th	0.004	--	--	0.071
27th	0.017	--	--	0.083
28th	0.003	--	--	0.066
29th	0.013	--	--	0.078
30th	0.004	--	--	0.061
31th	0.011	--	--	0.073
32th	0.003	--	--	0.058
33th	0.011	--	--	0.068
34th	0.003	--	--	0.054
35th	0.009	--	--	0.064
36th	0.004	--	--	0.051
37th	0.008	--	--	0.061
38th	0.003	--	--	0.048
39th	0.009	--	--	0.058
40th	0.003	--	--	0.046

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
-25°C, 100% P_n power condition:						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.013	--	--	1.080		
3rd	0.312	--	--	2.300		
4th	0.010	--	--	0.430		
5th	0.176	--	--	1.140		
6th	0.006	--	--	0.300		
7th	0.067	--	--	0.770		
8th	0.008	--	--	0.230		
9th	0.015	--	--	0.400		
10th	0.006	--	--	0.184		
11th	0.019	--	--	0.330		
12th	0.005	--	--	0.153		
13th	0.027	--	--	0.210		
14th	0.005	--	--	0.131		
15th	0.031	--	--	0.150		
16th	0.005	--	--	0.115		
17th	0.017	--	--	0.132		
18th	0.005	--	--	0.102		
19th	0.017	--	--	0.118		
20th	0.003	--	--	0.092		
21th	0.007	--	--	0.107		
22th	0.006	--	--	0.084		
23th	0.011	--	--	0.098		
24th	0.003	--	--	0.077		
25th	0.011	--	--	0.090		
26th	0.004	--	--	0.071		
27th	0.013	--	--	0.083		
28th	0.004	--	--	0.066		
29th	0.007	--	--	0.078		
30th	0.003	--	--	0.061		
31th	0.006	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.004	--	--	0.068		
34th	0.004	--	--	0.054		
35th	0.008	--	--	0.064		
36th	0.004	--	--	0.051		
37th	0.008	--	--	0.061		
38th	0.003	--	--	0.048		
39th	0.008	--	--	0.058		
40th	0.003	--	--	0.046		

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
-25°C, 66% P_n power condition:						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.012	--	--	1.080		
3rd	0.331	--	--	2.300		
4th	0.010	--	--	0.430		
5th	0.121	--	--	1.140		
6th	0.006	--	--	0.300		
7th	0.020	--	--	0.770		
8th	0.008	--	--	0.230		
9th	0.057	--	--	0.400		
10th	0.007	--	--	0.184		
11th	0.056	--	--	0.330		
12th	0.009	--	--	0.153		
13th	0.032	--	--	0.210		
14th	0.008	--	--	0.131		
15th	0.017	--	--	0.150		
16th	0.004	--	--	0.115		
17th	0.028	--	--	0.132		
18th	0.005	--	--	0.102		
19th	0.028	--	--	0.118		
20th	0.003	--	--	0.092		
21th	0.016	--	--	0.107		
22th	0.004	--	--	0.084		
23th	0.017	--	--	0.098		
24th	0.004	--	--	0.077		
25th	0.016	--	--	0.090		
26th	0.003	--	--	0.071		
27th	0.016	--	--	0.083		
28th	0.003	--	--	0.066		
29th	0.008	--	--	0.078		
30th	0.004	--	--	0.061		
31th	0.010	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.010	--	--	0.068		
34th	0.003	--	--	0.054		
35th	0.009	--	--	0.064		
36th	0.003	--	--	0.051		
37th	0.007	--	--	0.061		
38th	0.003	--	--	0.048		
39th	0.009	--	--	0.058		
40th	0.003	--	--	0.046		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
-25°C, 33% P_n power condition:				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.014	--	--	1.080
3rd	0.295	--	--	2.300
4th	0.008	--	--	0.430
5th	0.095	--	--	1.140
6th	0.010	--	--	0.300
7th	0.134	--	--	0.770
8th	0.006	--	--	0.230
9th	0.053	--	--	0.400
10th	0.008	--	--	0.184
11th	0.073	--	--	0.330
12th	0.006	--	--	0.153
13th	0.050	--	--	0.210
14th	0.007	--	--	0.131
15th	0.052	--	--	0.150
16th	0.008	--	--	0.115
17th	0.039	--	--	0.132
18th	0.004	--	--	0.102
19th	0.038	--	--	0.118
20th	0.004	--	--	0.092
21th	0.030	--	--	0.107
22th	0.004	--	--	0.084
23th	0.025	--	--	0.098
24th	0.003	--	--	0.077
25th	0.017	--	--	0.090
26th	0.004	--	--	0.071
27th	0.018	--	--	0.083
28th	0.003	--	--	0.066
29th	0.014	--	--	0.078
30th	0.003	--	--	0.061
31th	0.010	--	--	0.073
32th	0.003	--	--	0.058
33th	0.011	--	--	0.068
34th	0.003	--	--	0.054
35th	0.009	--	--	0.064
36th	0.003	--	--	0.051
37th	0.008	--	--	0.061
38th	0.003	--	--	0.048
39th	0.009	--	--	0.058
40th	0.003	--	--	0.046

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
B.1 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
25°C, 100% P_n power condition:						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.014	--	--	1.080		
3rd	0.312	--	--	2.300		
4th	0.010	--	--	0.430		
5th	0.177	--	--	1.140		
6th	0.006	--	--	0.300		
7th	0.067	--	--	0.770		
8th	0.009	--	--	0.230		
9th	0.014	--	--	0.400		
10th	0.006	--	--	0.184		
11th	0.019	--	--	0.330		
12th	0.005	--	--	0.153		
13th	0.027	--	--	0.210		
14th	0.006	--	--	0.131		
15th	0.031	--	--	0.150		
16th	0.005	--	--	0.115		
17th	0.018	--	--	0.132		
18th	0.004	--	--	0.102		
19th	0.017	--	--	0.118		
20th	0.003	--	--	0.092		
21th	0.008	--	--	0.107		
22th	0.006	--	--	0.084		
23th	0.011	--	--	0.098		
24th	0.003	--	--	0.077		
25th	0.011	--	--	0.090		
26th	0.004	--	--	0.071		
27th	0.013	--	--	0.083		
28th	0.004	--	--	0.066		
29th	0.007	--	--	0.078		
30th	0.003	--	--	0.061		
31th	0.007	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.004	--	--	0.068		
34th	0.003	--	--	0.054		
35th	0.008	--	--	0.064		
36th	0.004	--	--	0.051		
37th	0.008	--	--	0.061		
38th	0.003	--	--	0.048		
39th	0.008	--	--	0.058		
40th	0.003	--	--	0.046		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
25°C, 66% P_n power condition:				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.013	--	--	1.080
3rd	0.331	--	--	2.300
4th	0.010	--	--	0.430
5th	0.121	--	--	1.140
6th	0.006	--	--	0.300
7th	0.020	--	--	0.770
8th	0.008	--	--	0.230
9th	0.057	--	--	0.400
10th	0.007	--	--	0.184
11th	0.057	--	--	0.330
12th	0.009	--	--	0.153
13th	0.033	--	--	0.210
14th	0.007	--	--	0.131
15th	0.017	--	--	0.150
16th	0.004	--	--	0.115
17th	0.028	--	--	0.132
18th	0.005	--	--	0.102
19th	0.028	--	--	0.118
20th	0.004	--	--	0.092
21th	0.017	--	--	0.107
22th	0.004	--	--	0.084
23th	0.017	--	--	0.098
24th	0.004	--	--	0.077
25th	0.016	--	--	0.090
26th	0.003	--	--	0.071
27th	0.016	--	--	0.083
28th	0.003	--	--	0.066
29th	0.008	--	--	0.078
30th	0.003	--	--	0.061
31th	0.010	--	--	0.073
32th	0.003	--	--	0.058
33th	0.010	--	--	0.068
34th	0.003	--	--	0.054
35th	0.009	--	--	0.064
36th	0.004	--	--	0.051
37th	0.007	--	--	0.061
38th	0.003	--	--	0.048
39th	0.010	--	--	0.058
40th	0.003	--	--	0.046

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
25°C, 33% P_n power condition:				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.013	--	--	1.080
3rd	0.295	--	--	2.300
4th	0.008	--	--	0.430
5th	0.095	--	--	1.140
6th	0.010	--	--	0.300
7th	0.134	--	--	0.770
8th	0.007	--	--	0.230
9th	0.053	--	--	0.400
10th	0.008	--	--	0.184
11th	0.073	--	--	0.330
12th	0.007	--	--	0.153
13th	0.051	--	--	0.210
14th	0.007	--	--	0.131
15th	0.053	--	--	0.150
16th	0.008	--	--	0.115
17th	0.039	--	--	0.132
18th	0.004	--	--	0.102
19th	0.038	--	--	0.118
20th	0.004	--	--	0.092
21th	0.031	--	--	0.107
22th	0.004	--	--	0.084
23th	0.025	--	--	0.098
24th	0.003	--	--	0.077
25th	0.017	--	--	0.090
26th	0.004	--	--	0.071
27th	0.017	--	--	0.083
28th	0.003	--	--	0.066
29th	0.013	--	--	0.078
30th	0.003	--	--	0.061
31th	0.010	--	--	0.073
32th	0.003	--	--	0.058
33th	0.011	--	--	0.068
34th	0.003	--	--	0.054
35th	0.009	--	--	0.064
36th	0.004	--	--	0.051
37th	0.008	--	--	0.061
38th	0.003	--	--	0.048
39th	0.008	--	--	0.058
40th	0.003	--	--	0.046

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

B1 c)	TABLE: Flicker emission			P
Model	AF6K-SL			
Normal ambient				
Output power:	Flicker limits according to*:	Result:		
		Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11	0.101	0.107	0.023
66%	EN61000-3-3 / EN61000-3-11	0.099	0.105	0.024
100%	EN61000-3-3 / EN61000-3-11	0.103	0.108	0.061
Minimum ambient rating (-25°C) or -10°C				
Output power:	Flicker limits according to*:	Result:		
		Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11	0.099	0.105	0.024
66%	EN61000-3-3 / EN61000-3-11	0.103	0.108	0.089
100%	EN61000-3-3 / EN61000-3-11	0.116	0.137	0.024
Maximum ambient rating (+60°C) or +55°C				
Output power:	Flicker limits according to*:	Result:		
		Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11	0.098	0.104	0.024
66%	EN61000-3-3 / EN61000-3-11	0.102	0.107	0.088
100%	EN61000-3-3 / EN61000-3-11	0.116	0.137	0.023
<p>Note: * Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega$; $jX_{max} = \Omega @ 50Hz$ ($Z_{max} = \Omega$)</p> <p>Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c: $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$</p> <p>The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.</p> <p>If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).</p>				

CEI 0-21								
Clause	Requirement - Test				Result - Remark		Verdict	
	dc[%]		dmax[%]		d(t)[ms]		Pst	Plt
Limit	3.30		4.00		500 3.30%		1.00	0.65 N:12
No. 1	0.010	Pass	0.304	Pass	0.0	Pass	0.107	Pass
2	0.020	Pass	0.301	Pass	0.0	Pass	0.105	Pass
3	0.016	Pass	0.282	Pass	0.0	Pass	0.106	Pass
4	0.018	Pass	0.341	Pass	0.0	Pass	0.105	Pass
5	0.020	Pass	0.280	Pass	0.0	Pass	0.103	Pass
6	0.013	Pass	0.364	Pass	0.0	Pass	0.103	Pass
7	0.016	Pass	0.321	Pass	0.0	Pass	0.102	Pass
8	0.020	Pass	0.316	Pass	0.0	Pass	0.100	Pass
9	0.015	Pass	0.336	Pass	0.0	Pass	0.127	Pass
10	0.023	Pass	0.345	Pass	0.0	Pass	0.137	Pass
11	0.016	Pass	0.293	Pass	0.0	Pass	0.136	Pass
12	0.014	Pass	0.361	Pass	0.0	Pass	0.136	Pass
Result	Pass		Pass		Pass		Pass	0.116 Pass

CEI 0-21



Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.1	TABLE: Conditions of connection, reconnection and gradual power supply				
Model	AF6K-SL				
Test:					
Power meter measurement-data:	Sample-Rate:	0.2 s			
	Sample time:	6400			
Voltage conditons					
a) Out of voltage range	84% U_n for 30s		111% U_n for 30s		
Connection:	No connection		No connection		
Limit	No connection allowed				
b) In voltage range at start-up	85% U_n < U < 110% U_n				
Reconnection time [s]	33.4	31.0			
Limit:	Reconnection after 30s				
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20%Pn/min For recorded gradient see diagram underneath				
c) In voltage range after voltage failture	85% U_n < U < 110% U_n				
Reconnection time [s]	304.2	303.6			
Limit:	Reconnection after 300s				
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20%Pn/min For recorded gradient see diagram underneath				
Frequency conditions					
d) Out of frequency range	49,88 ± 0,01		50,12 ± 0,01		
Connection:	No connection		No connection		
Limit	No connection allowed				
e) In frequency range at start-up	49,90 Hz < f < 50,10				
Reconnection time [s]	33.8	31.2			
Limit:	Reconnection after 30s				
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20%Pn/min For recorded gradient see diagram underneath				
f) In frequency range after frequency failture	49,90 Hz < f < 50,10				
Reconnection time [s]	304.2	303.4			
Limit:	Reconnection after 300s				
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20%Pn/min For recorded gradient see diagram underneath				
file name a) b) and c):					

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
file name d), e) and f):			
Changable reconnection conditions:	Frequency range: 49Hz-51Hz in 0,05Hz steps (default value: 49,90 and 50,10Hz)	Reconnection time range: 0-900s in steps of 5s (default value: 300s)	
Test: Test condition b) and c): voltage within the limits of 85% to 110% U_n Test condition e) and f): frequency within the limits of 49,90Hz to 50,10Hz Max deviation of the gradient: +2,5% P_n			

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict																											
		 <table border="1"><caption>Data for Graph 1 (0 to 1260s)</caption><thead><tr><th>Time [s]</th><th>Power [W] (Red)</th><th>Frequency [Hz] (Blue)</th></tr></thead><tbody><tr><td>0</td><td>0</td><td>50.00</td></tr><tr><td>180</td><td>~2500</td><td>50.00</td></tr><tr><td>360</td><td>~6000</td><td>50.00</td></tr><tr><td>540</td><td>0</td><td>50.00</td></tr><tr><td>720</td><td>~2500</td><td>50.00</td></tr><tr><td>900</td><td>~6000</td><td>50.00</td></tr><tr><td>1080</td><td>~2500</td><td>50.00</td></tr><tr><td>1260</td><td>~6000</td><td>50.00</td></tr></tbody></table>	Time [s]	Power [W] (Red)	Frequency [Hz] (Blue)	0	0	50.00	180	~2500	50.00	360	~6000	50.00	540	0	50.00	720	~2500	50.00	900	~6000	50.00	1080	~2500	50.00	1260	~6000	50.00	
Time [s]	Power [W] (Red)	Frequency [Hz] (Blue)																												
0	0	50.00																												
180	~2500	50.00																												
360	~6000	50.00																												
540	0	50.00																												
720	~2500	50.00																												
900	~6000	50.00																												
1080	~2500	50.00																												
1260	~6000	50.00																												
		 <table border="1"><caption>Data for Graph 2 (0 to 1249s)</caption><thead><tr><th>Time [s]</th><th>Power [W] (Red)</th><th>Frequency [Hz] (Blue)</th></tr></thead><tbody><tr><td>0</td><td>0</td><td>50.00</td></tr><tr><td>349</td><td>~4500</td><td>50.00</td></tr><tr><td>529</td><td>0</td><td>50.00</td></tr><tr><td>709</td><td>~4500</td><td>50.00</td></tr><tr><td>889</td><td>0</td><td>50.00</td></tr><tr><td>1069</td><td>~4500</td><td>50.00</td></tr><tr><td>1249</td><td>~6000</td><td>50.00</td></tr></tbody></table>	Time [s]	Power [W] (Red)	Frequency [Hz] (Blue)	0	0	50.00	349	~4500	50.00	529	0	50.00	709	~4500	50.00	889	0	50.00	1069	~4500	50.00	1249	~6000	50.00				
Time [s]	Power [W] (Red)	Frequency [Hz] (Blue)																												
0	0	50.00																												
349	~4500	50.00																												
529	0	50.00																												
709	~4500	50.00																												
889	0	50.00																												
1069	~4500	50.00																												
1249	~6000	50.00																												

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.2.2.2	TABLE: Reactive power capability - Inverter in systems with total capacity greater than 11.08 kW	P
-----------	---	---

Model	AF6K-SL					
-------	---------	--	--	--	--	--

TABLE: Reactive power production with set point Q = 0

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
0% -10%(*)	539	8.99%	-118	-1.96%	671	11.19%	0.9770
10% -20%(**)	1147	19.12%	-123	-2.06%	1283	21.38%	0.9943
20% -30%	1754	29.24%	-136	-2.26%	1901	31.68%	0.9970
30% -40%	2300	38.34%	-147	-2.45%	2455	40.91%	0.9980
40% -50%	2907	48.45%	-159	-2.65%	3072	51.21%	0.9985
50% -60%	3513	58.55%	-171	-2.85%	3692	61.53%	0.9988
60% -70%	4119	68.65%	-183	-3.05%	4309	71.82%	0.9990
70% -80%	4724	78.74%	-197	-3.29%	4929	82.16%	0.9991
80% -90%	5329	88.82%	-212	-3.54%	5550	92.50%	0.9992
90% -100%(***)	5931	98.85%	-231	-3.85%	6168	102.80%	0.9992

TABLE: Reactive power production with set point Q = -Q_{max} (>11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
0% -10%(*)	543	9.05%	-157	-2.62%	623	10.39%	0.9604
10% -20%(**)	1155	19.24%	-162	-2.69%	1240	20.66%	0.9903
20% -30%	1765	29.42%	-2910	-48.50%	1871	31.19%	0.5183
30% -40%	2315	38.58%	-2915	-48.58%	2433	40.55%	0.6216
40% -50%	2926	48.76%	-2916	-48.60%	3059	50.99%	0.7078
50% -60%	3536	58.93%	-2920	-48.67%	3686	61.43%	0.7706
60% -70%	4146	69.09%	-2926	-48.77%	4314	71.89%	0.8166
70% -80%	4755	79.25%	-2930	-48.83%	4941	82.35%	0.8510
80% -90%	5364	89.40%	-2934	-48.89%	5570	92.83%	0.8770
90% -100%(***)	5439	90.65%	-2938	-48.97%	5636	93.93%	0.8795

TABLE: Reactive power production with set point Q = +Q_{max} (>11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
0% -10%(*)	544	9.06%	-144	-2.39%	596	9.93%	0.9669
10% -20%(**)	1156	19.26%	-147	-2.45%	1212	20.19%	0.9920
20% -30%	1768	29.47%	-2918	-48.64%	1824	30.40%	0.5179

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	
30% -40%	2318	38.64%	2923	48.71%	2382	39.69%	0.6210
40% -50%	2930	48.83%	2925	48.75%	3000	50.00%	0.7072
50% -60%	3539	58.99%	2932	48.86%	3627	60.45%	0.7697
60% -70%	4150	69.17%	2939	48.98%	4255	70.92%	0.8157
70% -80%	4762	79.36%	2944	49.07%	4885	81.42%	0.8501
80% -90%	5374	89.57%	2949	49.14%	5518	91.97%	0.8764
90% -100%(***)	5602	93.37%	2955	49.26%	5755	95.92%	0.8841

Note:
The PV inverter maximum reactive power set point $Q = 48.43\%P_D$.
(*) For power outputs less than 10% of the nominal power the generator must not exchange a reactive power higher than 10% of the nominal power.
(**) For power outputs less than 20% of the nominal power the generator must not exchange a reactive power higher than 10% of the nominal power.
(***) Ensure that the minimum requirement for cos is sustained steadily when thermal balance is achieved.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.2.3	TABLE: Reactive power supply at an assigned level (greater 11.08 kW systems, but can be requested for smaller systems as well)			P
Model	AF6K-SL			
Power meter measurement data:		Sample-Rate:	0.2 s	
		Samples time:	3 min for each power point	
P _N in %		Q _{min} /cosφ min (180s)	Q=0/ cosφ=0 (180s)	Q _{max} /cosφ max (180s)
50% P _n	Reactive power Set point Q/P _n [%]	Reactive power measured Q/P _n [%]	Deviation from set point ΔQ/P _n [%]	Limit [%]
-Q _{min}	-50.00%	-50.70%	0.70%	ΔQ ≤ ±2.5% P _n
0	0.00%	-2.30%	2.30%	ΔQ ≤ ±2.5% P _n
+Q _{max}	50.00%	50.41%	-0.41%	ΔQ ≤ ±2.5% P _n




Figure 48 - Measurement of the reactive power delivered based on an external command, accuracy check

Test procedure:

- Set the DC source so that the inverter delivers about 50% of the nominal active power P_n.
- Using the methods and the control parameter established by the manufacturer, vary the reactive power supplied by the converter passing from the maximum inductive value (at least equal to Q_{min} ≤ -0.4843 P_n) directly to zero (Q = 0), and then go from zero at the maximum capacitive value (equal to Q_{max} ≥ + 0.4843 P_n).
- Maintain each of the 3 limit set-points for 180 s.
- Calculate the average values of reactive power at 1 min on the basis of the values measured over a window of 200 ms at the fundamental frequency. The calculation of the value on an average of 1 min must start from the samples detected after 30 s from the instant in which the command of the new reactive power regulation set-point is sent, this is to ensure that the system has reached the steady state.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
B.1.2.4	TABLE: Response time to an assigned step level change (greater 11.08 kW systems)		P
Model	AF6K-SL		
Power meter measurement data:	Sample-Rate: Samples time:	0,2 s at least 2 minutes for each power point	
P _{E_{max}} in %		50 100	
Maximum response time :10 s		2 s	2 s

Test:

DC source should be set to 50% (test1) and 100% (test 2) output power Starting with Q=0 then Qmin≤ -0,4843 P_n to to Qmax≥ 0,4843 P_n, and then back to Q=0 in doing so each point must be kept for at least 2 minute.

The total tolerance is $\Delta Q \leq \pm 5,0\%$ of P_n or $\Delta \cos\phi \leq \pm 0,01$

The maximum response time is 10s.

As for the requirements of the previous paragraph, also in this case the tests are required to inverters used in plants with a total power greater than 11.08 kW, which must also be able to implement a centralized control strategy via remote control signal, issued by the Distributor. However, the manufacturer has the right to voluntarily carry out tests even for smaller inverters.






Figure 49 - Measurement of the response time to step changes of the set-point assigned for the reactive power


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


**Assessment criterion:**Test 1: $\cos \varphi$ accuracy $\cos \varphi (\pm 0,01)$ Test 2: $\cos \varphi$ accuracy $\cos \varphi (\pm 0,01)$ For the test to be passed, the $\cos \varphi$ setpoint from the active power must be measured at the terminals of the PGU within a settling time of 10 s.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Model:	AF6K-SL							
P/P _{SMAX} [%]	P[W]	Vout[V]	Q[Var]	Cos φSetpoint	Cos φmeasured	ΔCosφ	Limit Δcosφ_max	Result
20	1253	104.00	157	1.00	0.992	-0.008	≤ ± 0.01	P
30	1833	104.05	159	1.00	0.996	-0.004	≤ ± 0.01	P
40	2421	104.10	156	1.00	0.998	-0.002	≤ ± 0.01	P
50	3023	104.15	154	1.00	0.998	-0.002	≤ ± 0.01	P
60	3603	104.20	135	1.00	0.999	-0.001	≤ ± 0.01	P
60	3627	106.19	-731	0.98	0.980	0.000	≤ ± 0.01	P
70	4209	106.23	-1210	0.96	0.961	0.001	≤ ± 0.01	P
80	4802	106.28	-1721	0.94	0.941	0.001	≤ ± 0.01	P
90	5406	106.32	-2284	0.92	0.921	0.001	≤ ± 0.01	P
100	5589	106.37	-2863	0.90	0.902	0.002	≤ ± 0.01	P
100	5469	102.40	-2761	0.90	0.905	0.005	≤ ± 0.01	P
100	6016	97.48	-122	1.00	0.999	-0.001	≤ ± 0.01	P

Graph reactive power production according to a characteristic curve cos(phi) = f(P)



Model:	AF6K-SL							
P/P _{SMAX} [%]	P[W]	Vout[V]	Q[Var]	Cos φSetpoint	Cos φmeasured	ΔCosφ	Limit Δcosφ_max	Result
20	1253	104.00	157	1.00	0.992	-0.008	≤ ± 0.01	P
30	1833	104.05	159	1.00	0.996	-0.004	≤ ± 0.01	P
40	2421	104.10	156	1.00	0.998	-0.002	≤ ± 0.01	P
50	3023	104.15	154	1.00	0.998	-0.002	≤ ± 0.01	P
60	3603	104.20	135	1.00	0.999	-0.001	≤ ± 0.01	P
60	3627	106.19	-731	0.98	0.980	0.000	≤ ± 0.01	P
70	4209	106.23	-1210	0.96	0.961	0.001	≤ ± 0.01	P
80	4802	106.28	-1721	0.94	0.941	0.001	≤ ± 0.01	P
90	5406	106.32	-2284	0.92	0.921	0.001	≤ ± 0.01	P
100	5589	106.37	-2863	0.90	0.902	0.002	≤ ± 0.01	P
100	5469	102.40	-2761	0.90	0.905	0.005	≤ ± 0.01	P
100	6016	97.48	-122	1.00	0.999	-0.001	≤ ± 0.01	P

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B1.2.6	TABLE: Automatic supply of reactive power according to the characteristic curve $Q = f(V)$ (greater 11.08kW systems)	P
Over voltage & Under voltage		
Power meter measurement data:	Sample-Rate:	0.2 s
	Samples:	1000
Test:		
<p>Test points A-I: Set the system voltage to $1.07 V_n / 0.93 V_n$ (default lock-in value of the manufacturer $1.08 V_n / 0.92 V_n$) and set up the active power to less than 20%. After stabilisation of this point increase the grid voltage from 0.93 to 0.91 and 1.08 to 1.10 V_n in 1V steps but hold the active power $<20\% P_E$. The active power should now increase to 30% and then from 30% $P_{E_{max}}$ in increments of 10% P_E to 100%.</p> <p>Test points J-K: Set the system voltage to $1.10 V_n$ and $0.90 V_n$ decreases the active power from 100% P_E to 10% $P_{E_{max}}$ and after at least 30s smaller than 5% $P_{E_{max}}$.</p> <p>The total tolerance is $\Delta Q \leq \pm 2.5\% \text{ of } P_n$</p> <p>The inverter must be able to delay the activation of the curve from 0s - 30s (in 1s steps / default setting: 3s)</p>		
Fig. a		
Fig. b		

Figure 51 - Standard characteristic curves $Q = f(V)$ **Curve settings:** $V_{1s} = 1.08 V_n; V_{2s} = 1.1 V_n$ $V_{1i} = 0.92 V_n; V_{2i} = 0.9 V_n$ (V_{1i}, V_{2i}, V_{1s} and V_{2s} must be programmable in a range 0.9-1.1V_n with steps 0.01V_n)**Assessment criterion:**Test 1: cos φ accuracy cos φ (± 0.01)Test 2: cos φ accuracy cos φ (± 0.01)

For the test to be passed, the cos φ setpoint from the active power must be measured at the terminals of the PGU within a settling time of 10 s.

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

B.1.2.6	TABLE: Automatic supply of reactive power according to the characteristic curve Q= f(V) (greater 11.08kW systems)					P
Model	AF6K-SL					
Q_{min} reactive power in accordance to standard characteristic curve Q=f(V)						
P/P _n [%] Set-point	V _{ac} [V] Set-point	P/P _n [%] measured	V _{ac} [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [≤±2.5%P _n]
< 20%	1.07V _n	18.20	246.21	143	≈0(<±2.5%P _n)	-2.39%
< 20%	1.09V _n	18.18	250.78	148	≈0(<±2.5%P _n)	-2.47%
< 20%-> 30%	1.09V _n	30.37	250.77	-1183	-0.5 Q _{min} (within 10s)	-2.07%
40%	1.09V _n	40.54	250.79	-1272	-0.5 Q _{min}	-0.59%
50%	1.09V _n	50.70	250.79	-1276	-0.5 Q _{min}	-0.53%
60%	1.09V _n	60.87	250.73	-1234	-0.5 Q _{min}	-1.22%
70%	1.09V _n	71.04	250.76	-1252	-0.5 Q _{min}	-0.92%
80%	1.09V _n	81.22	250.80	-1296	-0.5 Q _{min}	-0.19%
90%	1.09V _n	91.39	250.72	-1266	-0.5 Q _{min}	-0.70%
100%	1.09V _n	98.62	250.73	-1274	-0.5 Q _{min}	-0.56%
100%	1.1 V _n	90.49	253.06	-2571	- Q _{min}	-0.74%
100%->10%	1.1 V _n	9.99	253.05	-2499	- Q _{min}	-1.93%
10%-> ≤5%	1.1 V _n	3.91	253.10	133	≈0 (<±5%P _n)	-2.21%
Q_{max} reactive power in accordance to standard characteristic curve Q=f(V)						
P/P _n [%] Set-point	V _{ac} [V] Set-point	P/P _n [%] measured	V _{ac} [V] measured	Q [Var] measured	Q [Var] expected	ΔQ [≤±2.5%P _n]
< 20%	0.93V _n	18.29	213.97	-135	≈0 (<±2.5%P _n)	2.24%
< 20%	0.91V _n	18.31	209.39	-135	≈0 (<±2.5%P _n)	2.25%
< 20%-30%	0.91V _n	30.60	209.41	1405	-0.5 Q _{max} (within 10s)	-1.63%
40%	0.91V _n	40.76	209.38	1351	-0.5 Q _{max}	-0.73%
50%	0.91V _n	50.94	209.34	1370	-0.5 Q _{max}	-1.04%
60%	0.91V _n	61.13	209.32	1357	-0.5 Q _{max}	-0.83%
70%	0.91V _n	71.30	209.35	1327	-0.5 Q _{max}	-0.33%
80%	0.91V _n	81.50	209.32	1323	-0.5 Q _{max}	-0.26%
90%	0.91V _n	91.41	209.36	1300	-0.5 Q _{max}	0.13%
100%	0.91V _n	91.55	209.37	1301	-0.5 Q _{max}	0.11%
100%	0.90V _n	89.33	207.03	2606	- Q _{max}	0.14%
100%-10%	0.90V _n	10.24	207.12	2613	- Q _{max}	0.04%
10%-5%	0.90V _n	5.06	207.06	-131	≈0(<±5%P _n)	2.18%

Note:
The lock-in value is adjustable between V_n and 1.1V_n and the lock-out value between V_n and 0.9V_n in 0.01V steps.
The inverter voltage on the AC side of the (inverter) is rated to 400V line to line.
In reference to the circular characteristic, the inverter reduces the active output power to maintain the reactive output power.
The under voltage measurement effects the active output power in reference to the reactive output power since the reactive output power has always priority. Therefore the inverter must lower the active output power.

CEI 0-21


Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.3.1	TABLE: Automatic limitation of active power for voltage values close to 110% of the rated voltage					P
Model	AF6K-SL					
	Set point	Activation threshold U_1			Deactivation threshold U_2	
	U/U_n	110%			112%	
	P/P_n	100%			20%	
Step	Set voltage [V/V _n]	Voltage [V]	Measured power [W]	Measured power [%]	Limit	Result
1	1,08	248.14	5950.18	99.17%	--	P
2	1,12	258.08	1173.29	19.55%	$P < 20\%P_n$	P
3	1,08	248.04	5966.98	99.45%	--	P

The purpose of the test is to verify the automatic reduction function of the active power delivered when the voltage read at the generator terminals has a value close to 110% of V_n .

Proceed as follows:

- enable the active power reduction function $P(U)$, according to the methods indicated by the manufacturer (which must be reported in the test report);
- adjust the voltage read at the output terminals of the converter to -2% of the activation threshold declared by the manufacturer and the DC source, so that the active power delivered at the output is equal to the maximum power available for injection;
- adjust the voltage read at the output terminals of the converter to + 2% of the activation threshold declared by the manufacturer;
- the active power is measured as averages at 1 s, plotting the values obtained as a function of time;
- within 5 minutes from the instant of application of the voltage + 2% of the activation threshold declared by the manufacturer, it is verified that the active power supplied by the inverter has been reduced to a value not exceeding 20% of P_n
- adjust the voltage read at the output terminals of the converter to -2% of the activation threshold declared by the manufacturer;
- the active power is measured as averages at 1 s, plotting the values obtained as a function of time;
- verify that the active power delivered by the inverter returns to the value congruent with the power made available from the primary or simulated source.



CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

B.1.3.2	TABLE: Adjustment of active power in the presence of over-frequency transistors on the transmission network				P					
Model	AF6K-SL									
Test:										
Power meter measurement data:	Sample-Rate:			0,2 s						
	Samples:			60 per frequency Point						
f [Hz] (ramps)	1) 47,51	2) 50,15	3) 50,40	4) 50,60	5) 51,49	6) 50,11	7) 50,00			
file: 100% P _{Emax}	Sequence A									
file: 50% P _{Emax}	Sequence B									
Test:										
The test is conducted for two powers. First, the test must start at a power 100% P _{Emax} ("Measurement 1"), and in a second test, for a power of 50% P _{Emax} ("Measurement 2"). The inverter must reduce the power and stay in this condition, until the grid stays in the limits for more than 300s. In the second test, after freezing of the momentary output power, the available active power output must be increased to a value 100% P _{Emax} , and after the network frequency of 50,3 Hz is fallen below, the rise of the active power gradient must be recorded.										
Perform the measurements on 7 points (the frequency value must have an uncertainty of maximum ± 10 mHz) temporally consequent to each other:										
1)	f = 47.51 Hz (t ₁ for sequence A, t ₁ ' for sequence B)									
2)	f = 50 Hz + 0.15 Hz (t ₂ for sequence A, t ₂ ' for sequence B)									
3)	f = 50 Hz + 0.40 Hz (t ₃ for sequence A, t ₃ ' for sequence B)									
4)	f = 50 Hz + 0.60 Hz (t ₄ for sequence A, t ₄ ' for sequence B)									
5)	f = 50 Hz + 1.49 Hz (t ₅ for sequence A, t ₅ ' for sequence B)									
6)	f = 50 Hz + 0.11 Hz (t ₆ for sequence A, t ₆ ' for sequence B)									
Now carry out step 7). bringing the frequency back to the nominal value to verify the conditions of gradual restoration of the maximum supply (sequence A), or to 50% of the maximum power available (sequence B):										
7)	f = 50 Hz (t ₇ for sequence A, t ₇ ' for sequence B).									

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------





Figure 52 - Curves for limiting active power with respect to frequency


The total tolerance is $\Delta P \leq \pm 2,5\%$ of P_n

Limits of the power-up gradient



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Sequence B						
Step No.	Set output power [%]	Frequency[Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	47.51	3000	3062	$\pm 2.5\% P_n$	t'_1
2	50	50.15	3000	3065	$\pm 2.5\% P_n$	t'_2
3	50	50.40	2538	2537	$\pm 2.5\% P_n$	t'_3
4	50	50.60	2077	2032	$\pm 2.5\% P_n$	t'_4
5	50	51.49	23	29	$\pm 2.5\% P_n$	t'_5
6	50	50.10	23	28	$\pm 2.5\% P_n$	t'_6
7	50	50.00	3000	3003	50% Pn	t'_7

The graph illustrates the sequence of events for Sequence B. The x-axis represents time in seconds (s) from 0 to 1320. The left y-axis represents active power in W from 0 to 3500, and the right y-axis represents Frequency in Hz from 47.00 to 52.00. The red line represents Power, and the blue line represents Frequency. The sequence starts at 3000W and 47.51Hz. It drops to 2077W and 50.60Hz, then recovers to 3000W and 50.00Hz. It then drops again to 23W and 51.49Hz, before recovering to 3000W and 50.00Hz. Finally, it drops to 28W and 50.10Hz, and then recovers back to 3000W and 50.00Hz. The frequency follows a similar step-like pattern, generally increasing during the power recovery phases and decreasing during the power drop phases.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.3.3	TABLE: Verification of the operating range in voltage and frequency				
Model	AF6K-SL				
Test No.	Voltage (V)	Frequency (Hz)	P (W)	Cos φ	Time (s)
Test 1	253.26	51.50	6080	0.998	>5min
Test 2	195.74	50.00	5164	0.998	>5min

Test 1: $V = 110\% * V_n$; $f = 51.5\text{ Hz}$; $P = 100\% P_n$; $\cos \varphi = 1$ (Duration: at least 5 minutes)

Test 2: $V = 85\% * V_n$; $f = 50.0\text{ Hz}$; $P = 100\% P_n$; $\cos \varphi = 1$


Test 1 and 2 have a duration of at least 5 minutes. In Test 2, operation at reduced power is allowed, equal to the maximum deliverable when the maximum output current limit has been reached ($P \geq 85\% P_n$).

To allow the tests to be carried out, the restrictive frequency thresholds must be disabled.


During the tests it is necessary to disable the automatic regulation in power reduction in case of over-frequency.

The frequency, voltage and active power measured at the generator output terminals must be recorded at a rate of at least 1 sample per second. The delivered power must remain stable within a limit of $\pm 5\% P_n$.

Test 1



Test 2




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.3.3.1	TABLE: Reduction of active power in the presence of transient under-frequency on transmission network						P
Model:	AF6K-SL						
5-min mean value	50.0 Hz	49.5 Hz	49.0 Hz	48.5 Hz	48.0 Hz	47.5 Hz	
Frequency [Hz]:	50.00	49.50	49.00	48.50	48.00	47.50	
Active power [W]:	6014	6017	6018	6016	6017	6017	
Test:	<p>The test must be carried out at 100% P_n.</p> <p>Measurements are carried out at the following operating points:</p> <ul style="list-style-type: none"> -Connect the object under test according to the instructions provided by the manufacturer. -Set all the parameters of the simulated network to the respective values of normal exercise. -Bring all the parameters of the object under test to the respective values of normal performance, such that the out power of the inverter is equal to the maximum deliverable power. -Implement measures of active power on 6 points of time from each other on the basis of 50 Hz, and by reducing the frequency of 0.5 Hz with a step up to the minimum value of 47.5 Hz. <p>The each operating point shall be maintained for at least 5 min.</p>						
Assessment criterion:	<p>The test is regarded as passed if:</p> <p>the results should be presented in a table, and on the basis they must extrapolate the trend on a graph that must be greater than the threshold identified by continuous tract of fig. 12a contained in the 8.4.4.</p> <ul style="list-style-type: none"> • the power reduction in point c) is less or equal to the allowed power reduction according to 8.4.4. <p>The power reduction in point c) is less or equal to the power reduction of 10 % P_M per 1 Hz drop.</p> <p>Frequency [Hz]</p> <p>Maximum allowed $\Delta P/PM$</p> <p>Standard curve — Most stringent curve</p>						
Maximum allowable power reduction in case of under-frequency							

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


B.1.3.4	TABLE: Limitation of active power by external control from the distributor				P
Model	AF6K-SL				
Set point P [P/P _n]		Set point P [W]	P measured [W]	Deviation (%)	Limit (%P _n)
100		6000	6026	-0.43%	--
90		5400	5478	-1.30%	± 2.5
80		4800	4870	-1.16%	± 2.5
70		4200	4260	-1.00%	± 2.5
60		3600	3651	-0.85%	± 2.5
50		3000	3043	-0.71%	± 2.5
40		2400	2433	-0.56%	± 2.5
30		1800	1823	-0.39%	± 2.5
20		1200	1214	-0.23%	± 2.5
10		600	605	-0.08%	± 2.5
					
Test: The setpoint signal must be reduced from 100% to 10% P _{Emax} . For adjustable PGUs in increments of 10% P _{Emax} . 1 minute must elapse after every change to the setpoint setting so that the PGU can settle at the new setpoint. Then the active power of the PGU must be measured as a 1-min mean value.					
Assessment criterion: a) for adjustable PGUs: - no network disconnection above 12,5% P _n - the active power value does not exceed the setpoint by more than 2,5% P _n - the setting time determined this way is ≤ 1min					
Note:					

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.4.1	TABLE: Checking the DC component output			P
Model	AF6K-SL			
	Power Level	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient				
Total output Power (W)	2011	4005	6032	
Output Vrms	230.27	230.27	230.68	
Output Arms	8.76	17.41	26.16	
Cos φ	0.999	0.999	0.999	
L1 DC Component (A)	0.006	0.006	0.005	
L2 DC Component (A)	-	-	-	
L3 DC Component (A)	-	-	-	
L1 DC Component (% I _r)	0.021%	0.023%	0.019%	
L2 DC Component (% I _r)	-	-	-	
L3 DC Component (% I _r)	-	-	-	
Minimum ambient rating (-25°C) or -10°C				
Total output Power (W)	2010	4005	6035	
Output Vrms	230.28	230.27	230.69	
Output Arms	8.76	17.40	26.18	
Cos φ	0.999	0.999	0.999	
L1 DC Component (A)	0.005	0.005	0.005	
L2 DC Component (A)	-	-	-	
L3 DC Component (A)	-	-	-	
L1 DC Component (% I _r)	0.019%	0.020%	0.018%	
L2 DC Component (% I _r)	-	-	-	
L3 DC Component (% I _r)	-	-	-	
Maximum ambient rating (+60°C) or +55°C				
Total output Power (W)	2010	4000	6021	
Output Vrms	230.28	230.27	230.69	
Output Arms	8.76	17.38	26.11	
Cos φ	0.999	0.999	0.999	
L1 DC Component (A)	0.005	0.005	0.005	
L2 DC Component (A)	-	-	-	
L3 DC Component (A)	-	-	-	
L1 DC Component (% I _r)	0.020%	0.020%	0.021%	
L2 DC Component (% I _r)	-	-	-	
L3 DC Component (% I _r)	-	-	-	

CEI 0-21






CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.4.1	TABLE: Checking the DC component output		
Model	AF1K-SL-1		
Power Level	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	335	672	1019
Output Vrms	229.87	229.86	230.07
Output Arms	1.47	2.93	4.44
Cos φ	0.997	0.998	0.999
L1 DC Component (A)	0.002	0.002	0.002
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.042%	0.043%	0.040%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-
Minimum ambient rating (-25°C) or -10°C			
Total output Power (W)	335	673	1019
Output Vrms	230.07	230.06	230.27
Output Arms	1.46	2.93	4.43
Cos φ	0.998	0.998	0.999
L1 DC Component (A)	0.002	0.002	0.002
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.044%	0.048%	0.042%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-
Maximum ambient rating (+60°C) or +55°C			
Total output Power (W)	333	670	1016
Output Vrms	230.07	230.07	230.27
Output Arms	1.46	2.92	4.42
Cos φ	0.998	0.998	0.999
L1 DC Component (A)	0.002	0.002	0.002
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.044%	0.048%	0.042%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
			
			
			

CEI 0-21				
Clause	Requirement - Test		Result - Remark	Verdict
B.1.4.2	TABLE: Checking the protection against DC injection			P
Model	AF6K-SL			
Ambient				
Actual Power	Limits	Measurement:(mA)	Limiting value:(mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	131.0	130.4	992.4
66%	+0,5% I_{nom} /1s	134.4	130.4	994.2
100%	+0,5% I_{nom} /1s	134.5	130.4	980.0
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200ms$	1018	1000	194.4
66%	+1A $I_{dc}/200ms$	1020	1000	188.9
100%	+1A $I_{dc}/200ms$	1019	1000	194.6
Model	AF1K-SL			
Actual Power	Limits	Measurement:(mA)	Limiting value:(mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	22.03	21.7	985.0
66%	+0,5% I_{nom} /1s	22.01	21.7	983.4
100%	+0,5% I_{nom} /1s	22.04	21.7	990.4
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200ms$	1006	1000	183.6
66%	+1A $I_{dc}/200ms$	1019	1000	195.9
100%	+1A $I_{dc}/200ms$	1018	1000	187.6
Note:				
The internal temperature of the EUT must be stabilized.				

CEI 0-21				
Clause	Requirement - Test		Result - Remark	Verdict
B.1.4.2	TABLE: Checking the protection against DC injection			P
Model:	AF6K-SL			
Minimum ambient rating (-25°C) or -10°C				
Actual Power	Limits	Measurement:(mA)	Limiting value: (mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	134.3	130.4	997.4
66%	+0,5% I_{nom} /1s	134.4	130.4	985.6
100%	+0,5% I_{nom} /1s	134.5	130.4	998.1
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200\text{ms}$	1020	1000	193.2
66%	+1A $I_{dc}/200\text{ms}$	1019	1000	198.1
100%	+1A $I_{dc}/200\text{ms}$	1020	1000	185.4
Model:	AF1K-SL			
Actual Power	Limits	Measurement:(mA)	Limiting value: (mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	22.06	21.74	992.7
66%	+0,5% I_{nom} /1s	22.01	21.74	987.6
100%	+0,5% I_{nom} /1s	22.07	21.74	989.6
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200\text{ms}$	1007	1000	188.6
66%	+1A $I_{dc}/200\text{ms}$	1016	1000	189.9
100%	+1A $I_{dc}/200\text{ms}$	1017	1000	193.0
Note:	The internal temperature of the EUT must be stabilized.			

CEI 0-21				
Clause	Requirement - Test		Result - Remark	Verdict
B.1.4.2	TABLE: Checking the protection against DC injection			P
Model:	AF6K-SL			
Maximum ambient rating (+60°C) or +55°C				
Actual Power	Limits	Measurement:(mA)	Limiting value:(mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	134.1	130.4	996.2
66%	+0,5% I_{nom} /1s	134.6	130.4	985.2
100%	+0,5% I_{nom} /1s	134.5	130.4	985.3
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200\text{ms}$	1019	1000	187.4
66%	+1A $I_{dc}/200\text{ms}$	1019	1000	184.3
100%	+1A $I_{dc}/200\text{ms}$	1018	1000	194.6
Model:	AF1K-SL			
Actual Power	Limits	Measurement:(mA)	Limiting value:(mA)	Disconnection time:(ms)
$I_{dc} = 0,5\% \text{ of } I_{nom}$				
33%	+0,5% I_{nom} /1s	22.05	21.74	991.2
66%	+0,5% I_{nom} /1s	22.05	21.74	989.4
100%	+0,5% I_{nom} /1s	22.05	21.74	997.6
$I_{dc} = 1A$				
33%	+1A $I_{dc}/200\text{ms}$	1005	1000	182.1
66%	+1A $I_{dc}/200\text{ms}$	1020	1000	188.7
100%	+1A $I_{dc}/200\text{ms}$	1018	1000	190.4
Note:	The internal temperature of the EUT must be stabilized.			

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

B.1.5	TABLE: Verification of insensitivity to voltage dips (UVRT capability) [greater 11.08kW systems]	P
Model	AF6K-SL	

The purpose of these tests is to ensure that the converter, when used in systems with total capacity greater than 11.08 kW, is insensitive to voltage dips according to the time-amplitude profile shown in the diagram. In particular, the tests must verify that the following functional requirements are met:

- the generator must not disconnect from the grid in the white area above and along the points of the UVRT (V-t) characteristic indicated in Figure 29, where V is the phase-to-phase voltage at the connection point. Supply of active and reactive power prior to the occurrence of the fault can be temporarily interrupted in this area.
- in the area below (grey) the generator can disconnect from the grid.
- within 400 ms from restoring network voltage to within the range of +10% and -15% of nominal voltage, the generator must return to supplying active and reactive power to the network as before the fault, with a maximum tolerance of $\pm 10\%$ of the nominal voltage of the generator. If voltage returns but remains in the range between 85% and 90%, power distribution may be reduced in relation to the generator limits of output power.

Verification of compliance with the requirements of immunity to voltage sags are carried out according to the test sequences shown in Table 31, to be carried out with the generator running respectively:

- between 10% and 30% of the rated power;
- and above 90% of the rated power.

Table 12 - Parameters relating to Figure 29 for the fault-ride-through capability of power park modules over 11.08 kW

Uret	0,05 [p.u.]	Tclear	0,2 s
Uclear	0,15 [p.u.]	Trec1	0,2 s
Urec1	0,15 [p.u.]	Trec2	0,2 s
Urec2	0,85 [p.u.]	Trec3	1,5 s





Figure 29 - Fault-ride-through profile of power park modules over 11.08 kW

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Test sequence:

- 1) three-phase symmetrical fault (**Table 31**, Tests N.1s, N.2s, N.3s and N4s)




- 2) two-phase asymmetric fault (**Table 31**, Tests N.1a, N2a, N.3a and N.4a)

Failure in MV, which causes a variation in LV not only of amplitude but also of the phase relationship of the voltages (the case considered involves the presence of a transformer Dy in the secondary substation).



- 3) LV two-phase asymmetric fault (**Table 31**, Tests No. 5 and No. 6)



CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Requirement of LVRT test:								
Table 31 - Test sequences to verify immunity to temporary voltage dips. The amplitude, duration and shape relate to no-load test conditions								
List of tests		Residual amplitude of phase-to-phase voltage V/V_{nom}	Drop duration limit [ms]	Power re-supply time after restoring network [ms]	Shape (*)			
1s – three-phase symmetrical fault		$0,10 \pm 0,05 (V_1/V_n)$	200 ± 20	400				
1a – two-phase asymmetric failure		$0,10 \pm 0,05 (V_1/V_n)$	200 ± 20	400				
2s – three-phase symmetrical fault		$0,25 \pm 0,05 (V_2/V_n)$	400 ± 20	400				
2a – two-phase asymmetric failure		$0,25 \pm 0,05 (V_2/V_n)$	400 ± 20	400				
3s – three-phase asymmetrical fault		$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	400				
3a – two-phase asymmetric failure		$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	400				
4s – three-phase asymmetrical fault		$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	400				
4a – two-phase asymmetric failure		$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	400				
5 – LV two-phase asymmetrical fault		$0,10 \pm 0,05 (V_5/V_n)$	200 ± 20	400				
6 – LV two-phase asymmetrical fault		$0,50 \pm 0,05 (V_6/V_n)$	850 ± 20	400				
Test No.		V/V_{nom}	Phase-to-earth voltages		Phase angles			
Test No.	V/V_{nom}		$U_1/U_{1,nom}$	$U_2/U_{2,nom}$	$U_3/U_{3,nom}$	Φ_{U1}	Φ_{U2}	Φ_{U3}
1s	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	0°	-120°	120°
1a	$0,10 \pm 0,05$	$0,87 \pm 0,05$	$0,87 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	27°	-147°	120°
2s	$0,25 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	0°	-120°	120°
2a	$0,25 \pm 0,05$	$0,88 \pm 0,05$	$0,88 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	22°	-142°	120°
3s	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	0°	-120°	120°
3a	$0,50 \pm 0,05$	$0,90 \pm 0,05$	$0,90 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	14°	-134°	120°
4s	$0,75 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	0°	-120°	120°
4a	$0,75 \pm 0,05$	$0,94 \pm 0,05$	$0,94 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	7°	-127°	120°
5	$0,10 \pm 0,05$	1	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	0°	-120°	120°
6	$0,50 \pm 0,05$	1	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	0°	-120°	120°
normal condition	1	1	1	1	1	0°	-120°	120°
(*) Regardless of the method used to simulate the transients (simulator or impedance network), the falling and rising edges of the voltage must have a duration of less than 10 ms.								

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Graph of LVRT and OVRT test:				
List of tests	Residual amplitude of phase-to-phase voltage V/V_{nom}	Drop duration limit [ms]	Measured drop duration [ms]	Duration of restoring network [ms]
1s – three-phase symmetrical fault ($P = 0,1 - 0,3$)	$0,10 \pm 0,05 (V_1/V_n)$	200 +20	211	151
1s – three-phase symmetrical fault ($P > 0,9$)	$0,10 \pm 0,05 (V_1/V_n)$	200 +20	211	168
1a – two-phase asymmetrical fault ($P = 0,1 - 0,3$)	$0,10 \pm 0,05 (V_1/V_n)$	200 +20	211	124
1a – two-phase asymmetrical fault ($P > 0,9$)	$0,10 \pm 0,05 (V_1/V_n)$	200 +20	211	119
2s – three-phase symmetrical fault ($P = 0,1 - 0,3$)	$0,25 \pm 0,05 (V_2/V_n)$	400 +20	407	162
2s – three-phase symmetrical fault ($P > 0,9$)	$0,25 \pm 0,05 (V_2/V_n)$	400 +20	407	157
2a – three-phase symmetrical fault ($P = 0,1 - 0,3$)	$0,25 \pm 0,05 (V_2/V_n)$	400 +20	411	173
2a – three-phase symmetrical fault ($P > 0,9$)	$0,25 \pm 0,05 (V_2/V_n)$	400 +20	411	141
3s – three-phase symmetrical fault ($P = 0,1 - 0,3$)	$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	860	151
3s – three-phase symmetrical fault ($P > 0,9$)	$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	860	160
3a – two-phase asymmetrical fault ($P = 0,1 - 0,3$)	$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	860	176
3a – two-phase asymmetrical fault ($P > 0,9$)	$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	860	144
4s – three-phase symmetrical fault ($P = 0,1 - 0,3$)	$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	1312	151
4s – three-phase symmetrical fault ($P > 0,9$)	$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	1312	156
4a – two-phase asymmetrical fault ($P = 0,1 - 0,3$)	$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	1312	159
4a – two-phase asymmetrical fault ($P > 0,9$)	$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	1312	119
5 – LV two-phase asymmetrical fault ($P = 0,1 - 0,3$)	$0,10 \pm 0,05 (V_5/V_n)$	200 +20	210	0
5 – LV two-phase asymmetrical fault ($P > 0,9$)	$0,10 \pm 0,05 (V_5/V_n)$	200 +20	210	0
6 – LV two-phase asymmetrical fault ($P = 0,1 - 0,3$)	$0,50 \pm 0,05 (V_6/V_n)$	400 +20	851	0
6 – LV two-phase asymmetrical fault ($P > 0,9$)	$0,50 \pm 0,05 (V_6/V_n)$	400 +20	851	0
7– HV three-phase symmetrical fault ($P = 0,1 - 0,3$)	$1,20 \pm 0,05 (V_7/V_n)$	500 +20	511	152
7– HV three-phase symmetrical fault ($P > 0,9$)	$1,20 \pm 0,05 (V_7/V_n)$	500 +20	511	117
8– HV three-phase symmetrical fault ($P = 0,1 - 0,3$)	$1,25 \pm 0,05 (V_8/V_n)$	100 +20	110	140
8– HV three-phase symmetrical fault ($P > 0,9$)	$1,25 \pm 0,05 (V_8/V_n)$	100 +20	110	132

Note:

(*) Regardless of the method used to simulate transients (simulator or impedance network), the rise and fall time of the voltage must be less than 10 ms


The interface protection shall be disabled or adjusted to avoid spurious tripping during testing.

The test conditions are performed as worst case conditions. The inverter feeds maximal active and reactive power during the complete test.


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 1s-1.1 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-1.2 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 1s-1.3 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-1.4 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 1s-2.1 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-2.2 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 1s-2.3 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-2.4 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 1a-Depth of fault phase: 0.1p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-1.1 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 1a-1.2 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-1.3 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 1a-1.4 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-2.1 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 1a-2.2 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-2.3 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D), 95% load
Instantaneous curve and RMS value of phase currents




Test 1a-2.4 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 2s-1.1 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-1.2 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 2s-1.3 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-1.4 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 2s-2.1 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-2.2 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 2s-2.3 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-2.4 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 2a-Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-1.1 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 2a-1.2 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-1.3 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 2a-1.4 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-2.1 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 2a-2.2 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-2.3 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 2a-2.4 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A), 0% load
 Test overview(voltage,current,active and reactive power)




Test 3s-1.1 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
 Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-1.2 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 3s-1.3 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-1.4 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 3s-2.1 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-2.2 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 3s-2.3 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-2.4 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 3a-Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-1.1 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 3a-1.2 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-1.3 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 3a-1.4 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-2.1 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 3a-2.2 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-2.3 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 3a-2.4 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 4s-1.1 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-1.2 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 4s-1.3 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-1.4 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 4s-2.1 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-2.2 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 4s-2.3 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-2.4 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 4a-Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-1.1 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 4a-1.2 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-1.3 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 4a-1.4 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-2.1 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 4a-2.2 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-2.3 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 4a-2.4 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




Test 5-1.1 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-1.2 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 5-1.3 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-1.4 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
restoring time




Test 5-2.1 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-2.2 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 5-2.3 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-2.4 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D), 95% load
restoring time




Test 6-Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-1.1 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 6-1.2 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-1.3 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 6-1.4 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-2.1 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 6-2.2 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-2.3 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 6-2.4 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 7-1.1 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-1.2 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 7-1.3 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-1.4 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 7-2.1 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-2.2 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 7-2.3 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-2.4 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 8-Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-1.1 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




Test 8-1.2 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-1.3 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




Test 8-1.4 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-2.1 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




Test 8-2.2 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-2.3 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents



Test 8-2.4 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A), 95% load
restoring time





CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

B.1.6	TABLE: Checking the insensitivity to automatic reclosing during phase discordance					P
Model	AF6K-SL					
Test 1: Phase angle shift of 90°						
Power level	Cos φ	Phase shift angle (°)	Current 20 ms before phase shift (A)	Current 200ms after phase shif (A)	Result	
100%	0.999	90	25.68	26.00	The PV inverter continue to feed power to grid after phase angle shift has been performed. No damage, no hazard.	
Test 2: Phase angle shift of 180°						
Power level (%)	Cos φ	Phase shift angle (°)	Current 20 ms before phase shift (A)	Current 200ms after phase shif (A)	Result	
100%	0.999	180	25.82	26.92	The PV inverter continue to feed power to grid after phase angle shift has been performed. No damage, no hazard.	
Note: The generator must be brought into operation at rated power. Let the system operate under the set conditions for at least 5 min or the time necessary for the temperature inside the converter to stabilize. The inverter should be operated with $\cos \varphi = 1$ and nominal output power. The network simulator should create voltage phase shifts of 90° and 180°. As a result, 20ms before and 200ms after the voltage phase shift, should be documented.						



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram: shift of 90°

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram: shift of 180°

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict
Bbis.3 a)/b)	TABLE: Harmonics measurement		P
Mode	AF6K-SL		
<input checked="" type="checkbox"/> CEI EN 61000-3-2			
<input checked="" type="checkbox"/> CEI EN 61000-3-12			
<input checked="" type="checkbox"/> Ambient temperature			
<input checked="" type="checkbox"/> -25°C temperature			
<input checked="" type="checkbox"/> +60°C temperature			
<input checked="" type="checkbox"/> Full power, 66% and 33% of P_{SMAX} / P_{NINV}			
<input checked="" type="checkbox"/> Full power, 66% and 33% of P_{CMAX}			
a)	harmonic emission limits, for class A (CEI EN 61000-3-2 or CEI EN 61000-3-12); they must be repeated, for storage systems connected to bidirectional converters, in 6 sessions (at 33%, 66% and 100% of the P_{SMAX} , or P_{NINV} for integrated EESS, and at 33%, 66% and 100% of the P_{CMAX}), and for storage systems connected to unidirectional converters in 3 sessions (at 33%, 66% and 100% of the maximum available discharge power);		
b)	for devices with phase currents higher than 75 A, it is possible to carry out harmonic emission tests with the same criteria provided for by CEI EN 61000-3-12; they must be repeated, for storage systems connected to bidirectional converters, in 6 sessions (at 33%, 66% and 100% of the P_{SMAX} , or P_{NINV} for integrated EESS, and at 33%, 66% and 100% of the P_{CMAX}), and for storage systems connected to unidirectional converters in 3 sessions (at 33%, 66% and 100% of the maximum available discharge power)		
Supplementary information:			
*If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test.			

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	-6004 (60°C)			
Voltage (V)	228.81			
Current (A)	26.31			
Power Factor	-0.9975			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.303	--	Single phase	--
2nd	0.032	0.122	Single phase	8
3rd	0.447	1.698	Single phase	21,6
4th	0.008	0.032	Single phase	4
5th	0.207	0.788	Single phase	10,7
6th	0.007	0.026	Single phase	2,7
7th	0.136	0.518	Single phase	7,2
8th	0.007	0.028	Single phase	2
9th	0.101	0.384	Single phase	3,8
10th	0.009	0.033	Single phase	1,6
11th	0.077	0.292	Single phase	3,1
12th	0.006	0.024	Single phase	1,3
13th	0.063	0.240	Single phase	2
14th	0.006	0.024	Single phase	N/A
15th	0.045	0.170	Single phase	N/A
16th	0.006	0.023	Single phase	N/A
17th	0.039	0.149	Single phase	N/A
18th	0.006	0.022	Single phase	N/A
19th	0.023	0.087	Single phase	N/A
20th	0.007	0.025	Single phase	N/A
21st	0.020	0.077	Single phase	N/A
22nd	0.005	0.021	Single phase	N/A
23rd	0.011	0.043	Single phase	N/A
24th	0.005	0.019	Single phase	N/A
25th	0.008	0.031	Single phase	N/A
26th	0.005	0.019	Single phase	N/A
27th	0.007	0.026	Single phase	N/A
28th	0.005	0.019	Single phase	N/A
29th	0.005	0.020	Single phase	N/A
30th	0.004	0.015	Single phase	N/A
31st	0.003	0.011	Single phase	N/A
32nd	0.004	0.015	Single phase	N/A
33rd	0.003	0.011	Single phase	N/A
34th	0.003	0.013	Single phase	N/A
35th	0.004	0.017	Single phase	N/A
36th	0.005	0.019	Single phase	N/A
37th	0.005	0.017	Single phase	N/A
38th	0.003	0.011	Single phase	N/A
39th	0.006	0.022	Single phase	N/A
40th	0.003	0.011	Single phase	N/A
THD	--	2.082	Single phase	23
PWHD	--	1.156	Single phase	23

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	-6006 (-25°C)				
Voltage (V)	228.83				
Current (A)	26.31				
Power Factor	-0.9975				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	26.309	--	Single phase	--	
2nd	0.032	0.122	Single phase	8	
3rd	0.445	1.691	Single phase	21,6	
4th	0.009	0.033	Single phase	4	
5th	0.207	0.785	Single phase	10,7	
6th	0.007	0.027	Single phase	2,7	
7th	0.136	0.515	Single phase	7,2	
8th	0.007	0.028	Single phase	2	
9th	0.100	0.382	Single phase	3,8	
10th	0.009	0.034	Single phase	1,6	
11th	0.077	0.292	Single phase	3,1	
12th	0.006	0.024	Single phase	1,3	
13th	0.063	0.238	Single phase	2	
14th	0.006	0.023	Single phase	N/A	
15th	0.045	0.170	Single phase	N/A	
16th	0.006	0.023	Single phase	N/A	
17th	0.039	0.150	Single phase	N/A	
18th	0.006	0.022	Single phase	N/A	
19th	0.023	0.087	Single phase	N/A	
20th	0.007	0.025	Single phase	N/A	
21st	0.020	0.077	Single phase	N/A	
22nd	0.005	0.020	Single phase	N/A	
23rd	0.012	0.044	Single phase	N/A	
24th	0.005	0.020	Single phase	N/A	
25th	0.008	0.031	Single phase	N/A	
26th	0.005	0.019	Single phase	N/A	
27th	0.007	0.026	Single phase	N/A	
28th	0.005	0.018	Single phase	N/A	
29th	0.005	0.018	Single phase	N/A	
30th	0.004	0.016	Single phase	N/A	
31st	0.003	0.011	Single phase	N/A	
32nd	0.004	0.015	Single phase	N/A	
33rd	0.003	0.011	Single phase	N/A	
34th	0.003	0.013	Single phase	N/A	
35th	0.004	0.017	Single phase	N/A	
36th	0.007	0.025	Single phase	N/A	
37th	0.005	0.018	Single phase	N/A	
38th	0.003	0.012	Single phase	N/A	
39th	0.005	0.021	Single phase	N/A	
40th	0.003	0.013	Single phase	N/A	
THD	--	2.086	Single phase	23	
PWHD	--	1.165	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	-6007 (25°C)			
Voltage (V)	228.82			
Current (A)	26.32			
Power Factor	-0.9975			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.310	--	Single phase	--
2nd	0.033	0.125	Single phase	8
3rd	0.445	1.690	Single phase	21,6
4th	0.009	0.033	Single phase	4
5th	0.206	0.784	Single phase	10,7
6th	0.007	0.025	Single phase	2,7
7th	0.135	0.514	Single phase	7,2
8th	0.007	0.027	Single phase	2
9th	0.100	0.382	Single phase	3,8
10th	0.009	0.033	Single phase	1,6
11th	0.077	0.292	Single phase	3,1
12th	0.006	0.023	Single phase	1,3
13th	0.063	0.239	Single phase	2
14th	0.006	0.022	Single phase	N/A
15th	0.045	0.170	Single phase	N/A
16th	0.006	0.023	Single phase	N/A
17th	0.040	0.151	Single phase	N/A
18th	0.005	0.020	Single phase	N/A
19th	0.023	0.088	Single phase	N/A
20th	0.007	0.025	Single phase	N/A
21st	0.021	0.078	Single phase	N/A
22nd	0.005	0.020	Single phase	N/A
23rd	0.012	0.046	Single phase	N/A
24th	0.005	0.020	Single phase	N/A
25th	0.008	0.030	Single phase	N/A
26th	0.005	0.019	Single phase	N/A
27th	0.007	0.026	Single phase	N/A
28th	0.005	0.018	Single phase	N/A
29th	0.005	0.019	Single phase	N/A
30th	0.004	0.014	Single phase	N/A
31st	0.003	0.011	Single phase	N/A
32nd	0.004	0.015	Single phase	N/A
33rd	0.003	0.013	Single phase	N/A
34th	0.003	0.012	Single phase	N/A
35th	0.004	0.016	Single phase	N/A
36th	0.005	0.018	Single phase	N/A
37th	0.004	0.016	Single phase	N/A
38th	0.003	0.012	Single phase	N/A
39th	0.005	0.020	Single phase	N/A
40th	0.003	0.011	Single phase	N/A
THD	--	2.063	Single phase	23
PWHD	--	1.162	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	-3955 (60°C)				
Voltage (V)	229.22				
Current (A)	17.39				
Power Factor	-0.9922				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	17.337	--	Single phase	--	
2nd	0.024	0.141	Single phase	8	
3rd	1.123	6.460	Single phase	21,6	
4th	0.011	0.061	Single phase	4	
5th	0.572	3.288	Single phase	10,7	
6th	0.030	0.172	Single phase	2,7	
7th	0.316	1.816	Single phase	7,2	
8th	0.016	0.090	Single phase	2	
9th	0.186	1.071	Single phase	3,8	
10th	0.016	0.093	Single phase	1,6	
11th	0.106	0.610	Single phase	3,1	
12th	0.010	0.057	Single phase	1,3	
13th	0.064	0.370	Single phase	2	
14th	0.014	0.080	Single phase	N/A	
15th	0.035	0.203	Single phase	N/A	
16th	0.008	0.045	Single phase	N/A	
17th	0.018	0.105	Single phase	N/A	
18th	0.003	0.015	Single phase	N/A	
19th	0.008	0.048	Single phase	N/A	
20th	0.009	0.053	Single phase	N/A	
21st	0.010	0.056	Single phase	N/A	
22nd	0.009	0.054	Single phase	N/A	
23rd	0.015	0.088	Single phase	N/A	
24th	0.003	0.018	Single phase	N/A	
25th	0.013	0.077	Single phase	N/A	
26th	0.003	0.019	Single phase	N/A	
27th	0.012	0.069	Single phase	N/A	
28th	0.004	0.025	Single phase	N/A	
29th	0.013	0.075	Single phase	N/A	
30th	0.003	0.020	Single phase	N/A	
31st	0.012	0.071	Single phase	N/A	
32nd	0.002	0.010	Single phase	N/A	
33rd	0.010	0.059	Single phase	N/A	
34th	0.002	0.011	Single phase	N/A	
35th	0.010	0.059	Single phase	N/A	
36th	0.004	0.023	Single phase	N/A	
37th	0.009	0.050	Single phase	N/A	
38th	0.002	0.009	Single phase	N/A	
39th	0.008	0.046	Single phase	N/A	
40th	0.001	0.009	Single phase	N/A	
THD	--	7.679	Single phase	23	
PWHD	--	1.561	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	-3954 (-25°C)				
Voltage (V)	229.20				
Current (A)	17.39				
Power Factor	-0.9923				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	17.335	--	Single phase	--	
2nd	0.026	0.148	Single phase	8	
3rd	1.122	6.453	Single phase	21,6	
4th	0.011	0.063	Single phase	4	
5th	0.571	3.283	Single phase	10,7	
6th	0.030	0.173	Single phase	2,7	
7th	0.316	1.816	Single phase	7,2	
8th	0.016	0.092	Single phase	2	
9th	0.186	1.070	Single phase	3,8	
10th	0.016	0.093	Single phase	1,6	
11th	0.106	0.610	Single phase	3,1	
12th	0.010	0.059	Single phase	1,3	
13th	0.064	0.371	Single phase	2	
14th	0.014	0.081	Single phase	N/A	
15th	0.035	0.202	Single phase	N/A	
16th	0.008	0.045	Single phase	N/A	
17th	0.018	0.105	Single phase	N/A	
18th	0.002	0.013	Single phase	N/A	
19th	0.008	0.047	Single phase	N/A	
20th	0.009	0.053	Single phase	N/A	
21st	0.010	0.056	Single phase	N/A	
22nd	0.010	0.057	Single phase	N/A	
23rd	0.015	0.086	Single phase	N/A	
24th	0.003	0.017	Single phase	N/A	
25th	0.013	0.077	Single phase	N/A	
26th	0.003	0.018	Single phase	N/A	
27th	0.012	0.071	Single phase	N/A	
28th	0.005	0.029	Single phase	N/A	
29th	0.013	0.075	Single phase	N/A	
30th	0.003	0.018	Single phase	N/A	
31st	0.012	0.070	Single phase	N/A	
32nd	0.002	0.012	Single phase	N/A	
33rd	0.010	0.060	Single phase	N/A	
34th	0.002	0.010	Single phase	N/A	
35th	0.010	0.057	Single phase	N/A	
36th	0.003	0.017	Single phase	N/A	
37th	0.009	0.049	Single phase	N/A	
38th	0.002	0.009	Single phase	N/A	
39th	0.008	0.046	Single phase	N/A	
40th	0.001	0.009	Single phase	N/A	
THD	--	7.651	Single phase	23	
PWHD	--	1.555	Single phase	23	

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	-3953 (25°C)				
Voltage (V)	229.19				
Current (A)	17.38				
Power Factor	-0.9923				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	17.331	--	Single phase	--	
2nd	0.026	0.151	Single phase	8	
3rd	1.120	6.446	Single phase	21,6	
4th	0.011	0.063	Single phase	4	
5th	0.570	3.278	Single phase	10,7	
6th	0.031	0.176	Single phase	2,7	
7th	0.315	1.813	Single phase	7,2	
8th	0.016	0.091	Single phase	2	
9th	0.186	1.068	Single phase	3,8	
10th	0.016	0.094	Single phase	1,6	
11th	0.106	0.608	Single phase	3,1	
12th	0.010	0.059	Single phase	1,3	
13th	0.064	0.370	Single phase	2	
14th	0.014	0.082	Single phase	N/A	
15th	0.035	0.201	Single phase	N/A	
16th	0.008	0.047	Single phase	N/A	
17th	0.018	0.104	Single phase	N/A	
18th	0.003	0.014	Single phase	N/A	
19th	0.008	0.048	Single phase	N/A	
20th	0.009	0.052	Single phase	N/A	
21st	0.010	0.057	Single phase	N/A	
22nd	0.010	0.058	Single phase	N/A	
23rd	0.015	0.085	Single phase	N/A	
24th	0.003	0.017	Single phase	N/A	
25th	0.013	0.075	Single phase	N/A	
26th	0.003	0.015	Single phase	N/A	
27th	0.012	0.071	Single phase	N/A	
28th	0.005	0.027	Single phase	N/A	
29th	0.013	0.075	Single phase	N/A	
30th	0.003	0.019	Single phase	N/A	
31st	0.012	0.071	Single phase	N/A	
32nd	0.002	0.012	Single phase	N/A	
33rd	0.011	0.061	Single phase	N/A	
34th	0.002	0.013	Single phase	N/A	
35th	0.010	0.057	Single phase	N/A	
36th	0.005	0.027	Single phase	N/A	
37th	0.009	0.050	Single phase	N/A	
38th	0.002	0.012	Single phase	N/A	
39th	0.008	0.048	Single phase	N/A	
40th	0.001	0.008	Single phase	N/A	
THD	--	7.654	Single phase	23	
PWHD	--	1.564	Single phase	23	

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	-1970 (60°C)				
Voltage (V)	229.56				
Current (A)	8.79				
Power Factor	-0.9762				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	8.731	--	Single phase	--	
2nd	0.021	0.234	Single phase	8	
3rd	0.934	10.624	Single phase	21,6	
4th	0.025	0.279	Single phase	4	
5th	0.347	3.945	Single phase	10,7	
6th	0.019	0.215	Single phase	2,7	
7th	0.086	0.978	Single phase	7,2	
8th	0.009	0.105	Single phase	2	
9th	0.014	0.159	Single phase	3,8	
10th	0.018	0.201	Single phase	1,6	
11th	0.050	0.566	Single phase	3,1	
12th	0.009	0.097	Single phase	1,3	
13th	0.048	0.544	Single phase	2	
14th	0.008	0.096	Single phase	N/A	
15th	0.026	0.300	Single phase	N/A	
16th	0.006	0.068	Single phase	N/A	
17th	0.015	0.172	Single phase	N/A	
18th	0.003	0.029	Single phase	N/A	
19th	0.026	0.292	Single phase	N/A	
20th	0.012	0.140	Single phase	N/A	
21st	0.040	0.452	Single phase	N/A	
22nd	0.004	0.043	Single phase	N/A	
23rd	0.036	0.410	Single phase	N/A	
24th	0.007	0.078	Single phase	N/A	
25th	0.031	0.351	Single phase	N/A	
26th	0.007	0.084	Single phase	N/A	
27th	0.019	0.215	Single phase	N/A	
28th	0.002	0.028	Single phase	N/A	
29th	0.009	0.097	Single phase	N/A	
30th	0.005	0.060	Single phase	N/A	
31st	0.007	0.074	Single phase	N/A	
32nd	0.004	0.047	Single phase	N/A	
33rd	0.002	0.019	Single phase	N/A	
34th	0.003	0.034	Single phase	N/A	
35th	0.005	0.056	Single phase	N/A	
36th	0.006	0.072	Single phase	N/A	
37th	0.005	0.057	Single phase	N/A	
38th	0.002	0.022	Single phase	N/A	
39th	0.006	0.064	Single phase	N/A	
40th	0.002	0.019	Single phase	N/A	
THD	--	11.611	Single phase	23	
PWHD	--	4.299	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	-1965 (-25°C)			
Voltage (V)	229.57			
Current (A)	8.77			
Power Factor	-0.9761			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.711	--	Single phase	--
2nd	0.020	0.232	Single phase	8
3rd	0.932	10.631	Single phase	21,6
4th	0.024	0.277	Single phase	4
5th	0.345	3.939	Single phase	10,7
6th	0.019	0.215	Single phase	2,7
7th	0.085	0.969	Single phase	7,2
8th	0.009	0.104	Single phase	2
9th	0.015	0.167	Single phase	3,8
10th	0.018	0.205	Single phase	1,6
11th	0.050	0.569	Single phase	3,1
12th	0.008	0.094	Single phase	1,3
13th	0.048	0.546	Single phase	2
14th	0.008	0.095	Single phase	N/A
15th	0.026	0.298	Single phase	N/A
16th	0.006	0.065	Single phase	N/A
17th	0.015	0.173	Single phase	N/A
18th	0.002	0.027	Single phase	N/A
19th	0.026	0.296	Single phase	N/A
20th	0.012	0.140	Single phase	N/A
21st	0.040	0.460	Single phase	N/A
22nd	0.004	0.044	Single phase	N/A
23rd	0.036	0.413	Single phase	N/A
24th	0.007	0.076	Single phase	N/A
25th	0.030	0.348	Single phase	N/A
26th	0.007	0.077	Single phase	N/A
27th	0.019	0.214	Single phase	N/A
28th	0.003	0.032	Single phase	N/A
29th	0.008	0.096	Single phase	N/A
30th	0.005	0.061	Single phase	N/A
31st	0.006	0.070	Single phase	N/A
32nd	0.004	0.050	Single phase	N/A
33rd	0.002	0.018	Single phase	N/A
34th	0.003	0.036	Single phase	N/A
35th	0.005	0.056	Single phase	N/A
36th	0.005	0.059	Single phase	N/A
37th	0.005	0.058	Single phase	N/A
38th	0.002	0.021	Single phase	N/A
39th	0.006	0.065	Single phase	N/A
40th	0.002	0.020	Single phase	N/A
THD	--	11.626	Single phase	23
PWHD	--	4.306	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	-1965 (25°C)			
Voltage (V)	229.56			
Current (A)	8.77			
Power Factor	-0.9761			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.711	--	Single phase	--
2nd	0.019	0.221	Single phase	8
3rd	0.933	10.635	Single phase	21,6
4th	0.024	0.274	Single phase	4
5th	0.345	3.939	Single phase	10,7
6th	0.019	0.213	Single phase	2,7
7th	0.085	0.966	Single phase	7,2
8th	0.009	0.104	Single phase	2
9th	0.015	0.168	Single phase	3,8
10th	0.018	0.200	Single phase	1,6
11th	0.050	0.571	Single phase	3,1
12th	0.008	0.097	Single phase	1,3
13th	0.048	0.545	Single phase	2
14th	0.008	0.095	Single phase	N/A
15th	0.026	0.297	Single phase	N/A
16th	0.006	0.068	Single phase	N/A
17th	0.015	0.172	Single phase	N/A
18th	0.002	0.027	Single phase	N/A
19th	0.026	0.297	Single phase	N/A
20th	0.012	0.138	Single phase	N/A
21st	0.040	0.461	Single phase	N/A
22nd	0.004	0.041	Single phase	N/A
23rd	0.036	0.416	Single phase	N/A
24th	0.007	0.076	Single phase	N/A
25th	0.031	0.348	Single phase	N/A
26th	0.007	0.081	Single phase	N/A
27th	0.019	0.211	Single phase	N/A
28th	0.003	0.033	Single phase	N/A
29th	0.009	0.098	Single phase	N/A
30th	0.005	0.061	Single phase	N/A
31st	0.006	0.068	Single phase	N/A
32nd	0.004	0.045	Single phase	N/A
33rd	0.002	0.018	Single phase	N/A
34th	0.003	0.034	Single phase	N/A
35th	0.005	0.060	Single phase	N/A
36th	0.005	0.058	Single phase	N/A
37th	0.005	0.060	Single phase	N/A
38th	0.002	0.024	Single phase	N/A
39th	0.006	0.064	Single phase	N/A
40th	0.002	0.019	Single phase	N/A
THD	--	11.639	Single phase	23
PWHD	--	4.316	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	6042 (60°C)			
Voltage (V)	230.92			
Current (A)	26.22			
Power Factor	0.9977			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	26.210	--	Single phase	--
2nd	0.082	0.314	Single phase	8
3rd	0.720	2.745	Single phase	21,6
4th	0.023	0.087	Single phase	4
5th	0.355	1.353	Single phase	10,7
6th	0.027	0.103	Single phase	2,7
7th	0.219	0.833	Single phase	7,2
8th	0.011	0.041	Single phase	2
9th	0.148	0.564	Single phase	3,8
10th	0.017	0.064	Single phase	1,6
11th	0.103	0.392	Single phase	3,1
12th	0.026	0.098	Single phase	1,3
13th	0.085	0.323	Single phase	2
14th	0.015	0.056	Single phase	N/A
15th	0.068	0.259	Single phase	N/A
16th	0.014	0.054	Single phase	N/A
17th	0.054	0.204	Single phase	N/A
18th	0.011	0.043	Single phase	N/A
19th	0.036	0.139	Single phase	N/A
20th	0.011	0.042	Single phase	N/A
21st	0.035	0.133	Single phase	N/A
22nd	0.005	0.020	Single phase	N/A
23rd	0.034	0.130	Single phase	N/A
24th	0.011	0.043	Single phase	N/A
25th	0.025	0.095	Single phase	N/A
26th	0.003	0.012	Single phase	N/A
27th	0.016	0.062	Single phase	N/A
28th	0.007	0.028	Single phase	N/A
29th	0.012	0.045	Single phase	N/A
30th	0.004	0.014	Single phase	N/A
31st	0.017	0.064	Single phase	N/A
32nd	0.003	0.013	Single phase	N/A
33rd	0.015	0.057	Single phase	N/A
34th	0.003	0.013	Single phase	N/A
35th	0.016	0.062	Single phase	N/A
36th	0.003	0.011	Single phase	N/A
37th	0.013	0.049	Single phase	N/A
38th	0.002	0.007	Single phase	N/A
39th	0.011	0.040	Single phase	N/A
40th	0.001	0.006	Single phase	N/A
THD	--	3.392	Single phase	23
PWHD	--	2.003	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	6039 (-25°C)				
Voltage (V)	230.92				
Current (A)	26.21				
Power Factor	0.9977				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	26.196	--	Single phase	--	
2nd	0.084	0.321	Single phase	8	
3rd	0.716	2.733	Single phase	21,6	
4th	0.023	0.086	Single phase	4	
5th	0.352	1.342	Single phase	10,7	
6th	0.027	0.104	Single phase	2,7	
7th	0.217	0.829	Single phase	7,2	
8th	0.010	0.040	Single phase	2	
9th	0.147	0.560	Single phase	3,8	
10th	0.018	0.068	Single phase	1,6	
11th	0.102	0.390	Single phase	3,1	
12th	0.027	0.102	Single phase	1,3	
13th	0.084	0.320	Single phase	2	
14th	0.015	0.057	Single phase	N/A	
15th	0.068	0.258	Single phase	N/A	
16th	0.015	0.058	Single phase	N/A	
17th	0.053	0.203	Single phase	N/A	
18th	0.012	0.044	Single phase	N/A	
19th	0.036	0.138	Single phase	N/A	
20th	0.011	0.043	Single phase	N/A	
21st	0.035	0.132	Single phase	N/A	
22nd	0.005	0.019	Single phase	N/A	
23rd	0.034	0.130	Single phase	N/A	
24th	0.012	0.047	Single phase	N/A	
25th	0.025	0.095	Single phase	N/A	
26th	0.004	0.014	Single phase	N/A	
27th	0.016	0.063	Single phase	N/A	
28th	0.007	0.027	Single phase	N/A	
29th	0.011	0.042	Single phase	N/A	
30th	0.005	0.020	Single phase	N/A	
31st	0.016	0.062	Single phase	N/A	
32nd	0.003	0.013	Single phase	N/A	
33rd	0.015	0.056	Single phase	N/A	
34th	0.004	0.014	Single phase	N/A	
35th	0.016	0.061	Single phase	N/A	
36th	0.006	0.022	Single phase	N/A	
37th	0.013	0.049	Single phase	N/A	
38th	0.002	0.009	Single phase	N/A	
39th	0.010	0.038	Single phase	N/A	
40th	0.002	0.006	Single phase	N/A	
THD	--	3.378	Single phase	23	
PWHD	--	2.003	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	6041 (25°C)				
Voltage (V)	230.91				
Current (A)	26.22				
Power Factor	0.9977				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	26.209	--	Single phase	--	
2nd	0.083	0.318	Single phase	8	
3rd	0.714	2.723	Single phase	21,6	
4th	0.022	0.085	Single phase	4	
5th	0.351	1.337	Single phase	10,7	
6th	0.026	0.098	Single phase	2,7	
7th	0.217	0.826	Single phase	7,2	
8th	0.011	0.042	Single phase	2	
9th	0.146	0.556	Single phase	3,8	
10th	0.018	0.068	Single phase	1,6	
11th	0.101	0.387	Single phase	3,1	
12th	0.026	0.100	Single phase	1,3	
13th	0.084	0.320	Single phase	2	
14th	0.015	0.059	Single phase	N/A	
15th	0.067	0.256	Single phase	N/A	
16th	0.015	0.058	Single phase	N/A	
17th	0.053	0.200	Single phase	N/A	
18th	0.011	0.044	Single phase	N/A	
19th	0.036	0.137	Single phase	N/A	
20th	0.011	0.042	Single phase	N/A	
21st	0.034	0.130	Single phase	N/A	
22nd	0.005	0.020	Single phase	N/A	
23rd	0.034	0.129	Single phase	N/A	
24th	0.012	0.046	Single phase	N/A	
25th	0.024	0.092	Single phase	N/A	
26th	0.003	0.013	Single phase	N/A	
27th	0.016	0.062	Single phase	N/A	
28th	0.007	0.028	Single phase	N/A	
29th	0.011	0.043	Single phase	N/A	
30th	0.005	0.019	Single phase	N/A	
31st	0.016	0.060	Single phase	N/A	
32nd	0.003	0.010	Single phase	N/A	
33rd	0.015	0.055	Single phase	N/A	
34th	0.004	0.014	Single phase	N/A	
35th	0.016	0.061	Single phase	N/A	
36th	0.004	0.016	Single phase	N/A	
37th	0.013	0.050	Single phase	N/A	
38th	0.002	0.007	Single phase	N/A	
39th	0.010	0.037	Single phase	N/A	
40th	0.002	0.006	Single phase	N/A	
THD	--	3.364	Single phase	23	
PWHD	--	1.977	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	3963 (60°C)			
Voltage (V)	230.66			
Current (A)	17.25			
Power Factor	0.9959			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	17.237	--	Single phase	--
2nd	0.089	0.518	Single phase	8
3rd	0.530	3.071	Single phase	21,6
4th	0.015	0.090	Single phase	4
5th	0.284	1.646	Single phase	10,7
6th	0.010	0.057	Single phase	2,7
7th	0.178	1.034	Single phase	7,2
8th	0.009	0.053	Single phase	2
9th	0.136	0.791	Single phase	3,8
10th	0.004	0.024	Single phase	1,6
11th	0.091	0.525	Single phase	3,1
12th	0.008	0.045	Single phase	1,3
13th	0.075	0.432	Single phase	2
14th	0.010	0.059	Single phase	N/A
15th	0.058	0.334	Single phase	N/A
16th	0.007	0.040	Single phase	N/A
17th	0.059	0.344	Single phase	N/A
18th	0.007	0.039	Single phase	N/A
19th	0.042	0.242	Single phase	N/A
20th	0.017	0.097	Single phase	N/A
21st	0.031	0.177	Single phase	N/A
22nd	0.004	0.023	Single phase	N/A
23rd	0.030	0.171	Single phase	N/A
24th	0.019	0.113	Single phase	N/A
25th	0.028	0.162	Single phase	N/A
26th	0.004	0.025	Single phase	N/A
27th	0.019	0.111	Single phase	N/A
28th	0.013	0.074	Single phase	N/A
29th	0.016	0.091	Single phase	N/A
30th	0.003	0.019	Single phase	N/A
31st	0.017	0.097	Single phase	N/A
32nd	0.007	0.038	Single phase	N/A
33rd	0.014	0.083	Single phase	N/A
34th	0.002	0.011	Single phase	N/A
35th	0.013	0.073	Single phase	N/A
36th	0.002	0.013	Single phase	N/A
37th	0.011	0.066	Single phase	N/A
38th	0.002	0.009	Single phase	N/A
39th	0.011	0.063	Single phase	N/A
40th	0.001	0.008	Single phase	N/A
THD	--	4.014	Single phase	23
PWHD	--	3.040	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	3962 (-25°C)				
Voltage (V)	230.66				
Current (A)	17.25				
Power Factor	0.9959				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	17.234	--	Single phase	--	
2nd	0.093	0.537	Single phase	8	
3rd	0.529	3.069	Single phase	21,6	
4th	0.015	0.087	Single phase	4	
5th	0.284	1.644	Single phase	10,7	
6th	0.010	0.057	Single phase	2,7	
7th	0.178	1.033	Single phase	7,2	
8th	0.010	0.055	Single phase	2	
9th	0.137	0.791	Single phase	3,8	
10th	0.004	0.024	Single phase	1,6	
11th	0.090	0.524	Single phase	3,1	
12th	0.008	0.044	Single phase	1,3	
13th	0.074	0.431	Single phase	2	
14th	0.010	0.060	Single phase	N/A	
15th	0.057	0.331	Single phase	N/A	
16th	0.007	0.041	Single phase	N/A	
17th	0.059	0.340	Single phase	N/A	
18th	0.007	0.039	Single phase	N/A	
19th	0.042	0.242	Single phase	N/A	
20th	0.017	0.096	Single phase	N/A	
21st	0.031	0.177	Single phase	N/A	
22nd	0.004	0.023	Single phase	N/A	
23rd	0.029	0.170	Single phase	N/A	
24th	0.020	0.114	Single phase	N/A	
25th	0.028	0.165	Single phase	N/A	
26th	0.005	0.026	Single phase	N/A	
27th	0.019	0.111	Single phase	N/A	
28th	0.013	0.077	Single phase	N/A	
29th	0.016	0.093	Single phase	N/A	
30th	0.003	0.020	Single phase	N/A	
31st	0.017	0.096	Single phase	N/A	
32nd	0.006	0.036	Single phase	N/A	
33rd	0.014	0.084	Single phase	N/A	
34th	0.002	0.010	Single phase	N/A	
35th	0.013	0.073	Single phase	N/A	
36th	0.002	0.010	Single phase	N/A	
37th	0.011	0.065	Single phase	N/A	
38th	0.002	0.009	Single phase	N/A	
39th	0.011	0.065	Single phase	N/A	
40th	0.001	0.009	Single phase	N/A	
THD	--	4.004	Single phase	23	
PWHD	--	3.036	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	3964 (25°C)				
Voltage (V)	230.67				
Current (A)	17.25				
Power Factor	0.9959				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	17.242	--	Single phase	--	
2nd	0.091	0.526	Single phase	8	
3rd	0.529	3.066	Single phase	21,6	
4th	0.015	0.086	Single phase	4	
5th	0.283	1.641	Single phase	10,7	
6th	0.010	0.057	Single phase	2,7	
7th	0.178	1.031	Single phase	7,2	
8th	0.010	0.056	Single phase	2	
9th	0.136	0.790	Single phase	3,8	
10th	0.004	0.024	Single phase	1,6	
11th	0.090	0.523	Single phase	3,1	
12th	0.007	0.043	Single phase	1,3	
13th	0.075	0.432	Single phase	2	
14th	0.010	0.059	Single phase	N/A	
15th	0.057	0.331	Single phase	N/A	
16th	0.007	0.041	Single phase	N/A	
17th	0.059	0.341	Single phase	N/A	
18th	0.007	0.039	Single phase	N/A	
19th	0.042	0.243	Single phase	N/A	
20th	0.017	0.098	Single phase	N/A	
21st	0.031	0.178	Single phase	N/A	
22nd	0.004	0.024	Single phase	N/A	
23rd	0.030	0.171	Single phase	N/A	
24th	0.020	0.114	Single phase	N/A	
25th	0.029	0.166	Single phase	N/A	
26th	0.005	0.027	Single phase	N/A	
27th	0.019	0.112	Single phase	N/A	
28th	0.013	0.075	Single phase	N/A	
29th	0.016	0.093	Single phase	N/A	
30th	0.004	0.022	Single phase	N/A	
31st	0.016	0.095	Single phase	N/A	
32nd	0.006	0.035	Single phase	N/A	
33rd	0.014	0.083	Single phase	N/A	
34th	0.002	0.009	Single phase	N/A	
35th	0.013	0.074	Single phase	N/A	
36th	0.003	0.016	Single phase	N/A	
37th	0.011	0.065	Single phase	N/A	
38th	0.002	0.010	Single phase	N/A	
39th	0.011	0.064	Single phase	N/A	
40th	0.001	0.009	Single phase	N/A	
THD	--	3.987	Single phase	23	
PWHD	--	3.041	Single phase	23	

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+15Battery				
Active power (W)	1993 (60°C)				
Voltage (V)	230.31				
Current (A)	8.80				
Power Factor	0.9829				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	8.779	--	Single phase	--	
2nd	0.082	0.930	Single phase	8	
3rd	0.510	5.788	Single phase	21,6	
4th	0.040	0.456	Single phase	4	
5th	0.280	3.179	Single phase	10,7	
6th	0.040	0.450	Single phase	2,7	
7th	0.185	2.107	Single phase	7,2	
8th	0.031	0.356	Single phase	2	
9th	0.126	1.430	Single phase	3,8	
10th	0.010	0.119	Single phase	1,6	
11th	0.078	0.883	Single phase	3,1	
12th	0.005	0.062	Single phase	1,3	
13th	0.052	0.595	Single phase	2	
14th	0.021	0.238	Single phase	N/A	
15th	0.026	0.301	Single phase	N/A	
16th	0.023	0.266	Single phase	N/A	
17th	0.017	0.190	Single phase	N/A	
18th	0.020	0.230	Single phase	N/A	
19th	0.020	0.224	Single phase	N/A	
20th	0.003	0.036	Single phase	N/A	
21st	0.028	0.314	Single phase	N/A	
22nd	0.016	0.182	Single phase	N/A	
23rd	0.026	0.293	Single phase	N/A	
24th	0.013	0.146	Single phase	N/A	
25th	0.026	0.298	Single phase	N/A	
26th	0.003	0.039	Single phase	N/A	
27th	0.024	0.270	Single phase	N/A	
28th	0.011	0.123	Single phase	N/A	
29th	0.019	0.221	Single phase	N/A	
30th	0.001	0.017	Single phase	N/A	
31st	0.014	0.162	Single phase	N/A	
32nd	0.005	0.051	Single phase	N/A	
33rd	0.012	0.136	Single phase	N/A	
34th	0.002	0.024	Single phase	N/A	
35th	0.009	0.103	Single phase	N/A	
36th	0.004	0.049	Single phase	N/A	
37th	0.005	0.059	Single phase	N/A	
38th	0.003	0.030	Single phase	N/A	
39th	0.007	0.082	Single phase	N/A	
40th	0.002	0.019	Single phase	N/A	
THD	--	7.567	Single phase	23	
PWHD	--	4.442	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	1998 (-25°C)			
Voltage (V)	230.31			
Current (A)	8.83			
Power Factor	0.9830			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.803	--	Single phase	--
2nd	0.079	0.899	Single phase	8
3rd	0.510	5.777	Single phase	21,6
4th	0.041	0.462	Single phase	4
5th	0.280	3.176	Single phase	10,7
6th	0.040	0.452	Single phase	2,7
7th	0.186	2.106	Single phase	7,2
8th	0.031	0.352	Single phase	2
9th	0.126	1.426	Single phase	3,8
10th	0.011	0.124	Single phase	1,6
11th	0.078	0.888	Single phase	3,1
12th	0.005	0.056	Single phase	1,3
13th	0.053	0.597	Single phase	2
14th	0.021	0.235	Single phase	N/A
15th	0.027	0.306	Single phase	N/A
16th	0.023	0.264	Single phase	N/A
17th	0.017	0.189	Single phase	N/A
18th	0.020	0.232	Single phase	N/A
19th	0.020	0.224	Single phase	N/A
20th	0.003	0.038	Single phase	N/A
21st	0.028	0.312	Single phase	N/A
22nd	0.015	0.175	Single phase	N/A
23rd	0.025	0.288	Single phase	N/A
24th	0.013	0.147	Single phase	N/A
25th	0.026	0.293	Single phase	N/A
26th	0.004	0.040	Single phase	N/A
27th	0.023	0.266	Single phase	N/A
28th	0.011	0.124	Single phase	N/A
29th	0.019	0.218	Single phase	N/A
30th	0.001	0.017	Single phase	N/A
31st	0.014	0.164	Single phase	N/A
32nd	0.004	0.050	Single phase	N/A
33rd	0.012	0.137	Single phase	N/A
34th	0.002	0.026	Single phase	N/A
35th	0.009	0.105	Single phase	N/A
36th	0.005	0.055	Single phase	N/A
37th	0.005	0.057	Single phase	N/A
38th	0.002	0.026	Single phase	N/A
39th	0.007	0.079	Single phase	N/A
40th	0.002	0.018	Single phase	N/A
THD	--	7.574	Single phase	23
PWHD	--	4.414	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+15Battery			
Active power (W)	1957 (25°C)			
Voltage (V)	230.30			
Current (A)	8.65			
Power Factor	0.9822			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	8.628	--	Single phase	--
2nd	0.082	0.943	Single phase	8
3rd	0.512	5.913	Single phase	21,6
4th	0.040	0.462	Single phase	4
5th	0.282	3.255	Single phase	10,7
6th	0.039	0.448	Single phase	2,7
7th	0.186	2.145	Single phase	7,2
8th	0.031	0.353	Single phase	2
9th	0.125	1.441	Single phase	3,8
10th	0.009	0.110	Single phase	1,6
11th	0.076	0.875	Single phase	3,1
12th	0.006	0.075	Single phase	1,3
13th	0.050	0.580	Single phase	2
14th	0.022	0.255	Single phase	N/A
15th	0.024	0.283	Single phase	N/A
16th	0.024	0.272	Single phase	N/A
17th	0.018	0.206	Single phase	N/A
18th	0.020	0.233	Single phase	N/A
19th	0.022	0.260	Single phase	N/A
20th	0.003	0.039	Single phase	N/A
21st	0.030	0.344	Single phase	N/A
22nd	0.016	0.183	Single phase	N/A
23rd	0.027	0.317	Single phase	N/A
24th	0.012	0.137	Single phase	N/A
25th	0.026	0.302	Single phase	N/A
26th	0.004	0.046	Single phase	N/A
27th	0.024	0.273	Single phase	N/A
28th	0.011	0.127	Single phase	N/A
29th	0.019	0.217	Single phase	N/A
30th	0.002	0.022	Single phase	N/A
31st	0.013	0.152	Single phase	N/A
32nd	0.004	0.049	Single phase	N/A
33rd	0.011	0.127	Single phase	N/A
34th	0.002	0.028	Single phase	N/A
35th	0.008	0.097	Single phase	N/A
36th	0.005	0.061	Single phase	N/A
37th	0.005	0.062	Single phase	N/A
38th	0.002	0.022	Single phase	N/A
39th	0.008	0.087	Single phase	N/A
40th	0.001	0.015	Single phase	N/A
THD	--	7.754	Single phase	23
PWHD	--	4.568	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+1Battery				
Active power (W)	-5038 (60°C)				
Voltage (V)	228.88				
Current (A)	22.07				
Power Factor	-0.9971				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	22.069	--	Single phase	--	
2nd	0.036	0.164	Single phase	8	
3rd	0.391	1.772	Single phase	21,6	
4th	0.005	0.025	Single phase	4	
5th	0.198	0.897	Single phase	10,7	
6th	0.006	0.029	Single phase	2,7	
7th	0.119	0.540	Single phase	7,2	
8th	0.006	0.027	Single phase	2	
9th	0.090	0.408	Single phase	3,8	
10th	0.007	0.032	Single phase	1,6	
11th	0.064	0.289	Single phase	3,1	
12th	0.008	0.038	Single phase	1,3	
13th	0.055	0.250	Single phase	2	
14th	0.004	0.020	Single phase	N/A	
15th	0.036	0.161	Single phase	N/A	
16th	0.004	0.020	Single phase	N/A	
17th	0.032	0.144	Single phase	N/A	
18th	0.004	0.019	Single phase	N/A	
19th	0.017	0.078	Single phase	N/A	
20th	0.007	0.030	Single phase	N/A	
21st	0.014	0.062	Single phase	N/A	
22nd	0.005	0.024	Single phase	N/A	
23rd	0.009	0.042	Single phase	N/A	
24th	0.004	0.018	Single phase	N/A	
25th	0.005	0.024	Single phase	N/A	
26th	0.004	0.017	Single phase	N/A	
27th	0.005	0.023	Single phase	N/A	
28th	0.004	0.016	Single phase	N/A	
29th	0.005	0.023	Single phase	N/A	
30th	0.003	0.014	Single phase	N/A	
31st	0.005	0.023	Single phase	N/A	
32nd	0.003	0.012	Single phase	N/A	
33rd	0.006	0.028	Single phase	N/A	
34th	0.003	0.013	Single phase	N/A	
35th	0.007	0.032	Single phase	N/A	
36th	0.004	0.019	Single phase	N/A	
37th	0.007	0.034	Single phase	N/A	
38th	0.003	0.012	Single phase	N/A	
39th	0.009	0.042	Single phase	N/A	
40th	0.002	0.010	Single phase	N/A	
THD	--	2.187	Single phase	23	
PWHD	--	1.151	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+1Battery			
Active power (W)	-3317 (60°C)			
Voltage (V)	229.25			
Current (A)	14.55			
Power Factor	-0.9941			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	14.548	--	Single phase	--
2nd	0.021	0.148	Single phase	8
3rd	0.351	2.415	Single phase	21,6
4th	0.004	0.030	Single phase	4
5th	0.177	1.213	Single phase	10,7
6th	0.006	0.043	Single phase	2,7
7th	0.102	0.702	Single phase	7,2
8th	0.007	0.048	Single phase	2
9th	0.068	0.466	Single phase	3,8
10th	0.005	0.035	Single phase	1,6
11th	0.037	0.256	Single phase	3,1
12th	0.006	0.039	Single phase	1,3
13th	0.027	0.185	Single phase	2
14th	0.007	0.045	Single phase	N/A
15th	0.020	0.136	Single phase	N/A
16th	0.003	0.024	Single phase	N/A
17th	0.015	0.106	Single phase	N/A
18th	0.003	0.022	Single phase	N/A
19th	0.020	0.138	Single phase	N/A
20th	0.007	0.047	Single phase	N/A
21st	0.020	0.140	Single phase	N/A
22nd	0.003	0.019	Single phase	N/A
23rd	0.022	0.149	Single phase	N/A
24th	0.003	0.023	Single phase	N/A
25th	0.023	0.157	Single phase	N/A
26th	0.004	0.029	Single phase	N/A
27th	0.020	0.136	Single phase	N/A
28th	0.003	0.019	Single phase	N/A
29th	0.019	0.127	Single phase	N/A
30th	0.004	0.025	Single phase	N/A
31st	0.018	0.127	Single phase	N/A
32nd	0.003	0.019	Single phase	N/A
33rd	0.017	0.114	Single phase	N/A
34th	0.003	0.020	Single phase	N/A
35th	0.015	0.106	Single phase	N/A
36th	0.003	0.022	Single phase	N/A
37th	0.013	0.086	Single phase	N/A
38th	0.002	0.013	Single phase	N/A
39th	0.012	0.080	Single phase	N/A
40th	0.001	0.009	Single phase	N/A
THD	--	2.923	Single phase	23
PWHD	--	2.324	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+1Battery				
Active power (W)	-1660 (60°C)				
Voltage (V)	229.59				
Current (A)	7.38				
Power Factor	-0.9794				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	7.377	--	Single phase	--	
2nd	0.009	0.125	Single phase	8	
3rd	0.295	3.996	Single phase	21,6	
4th	0.007	0.101	Single phase	4	
5th	0.113	1.535	Single phase	10,7	
6th	0.007	0.098	Single phase	2,7	
7th	0.029	0.389	Single phase	7,2	
8th	0.008	0.112	Single phase	2	
9th	0.027	0.362	Single phase	3,8	
10th	0.004	0.056	Single phase	1,6	
11th	0.038	0.510	Single phase	3,1	
12th	0.005	0.064	Single phase	1,3	
13th	0.031	0.419	Single phase	2	
14th	0.004	0.054	Single phase	N/A	
15th	0.031	0.424	Single phase	N/A	
16th	0.006	0.076	Single phase	N/A	
17th	0.023	0.315	Single phase	N/A	
18th	0.003	0.044	Single phase	N/A	
19th	0.021	0.279	Single phase	N/A	
20th	0.003	0.037	Single phase	N/A	
21st	0.023	0.305	Single phase	N/A	
22nd	0.003	0.043	Single phase	N/A	
23rd	0.021	0.288	Single phase	N/A	
24th	0.005	0.065	Single phase	N/A	
25th	0.020	0.267	Single phase	N/A	
26th	0.003	0.041	Single phase	N/A	
27th	0.010	0.139	Single phase	N/A	
28th	0.002	0.033	Single phase	N/A	
29th	0.005	0.065	Single phase	N/A	
30th	0.003	0.041	Single phase	N/A	
31st	0.003	0.044	Single phase	N/A	
32nd	0.003	0.043	Single phase	N/A	
33rd	0.007	0.093	Single phase	N/A	
34th	0.003	0.037	Single phase	N/A	
35th	0.007	0.101	Single phase	N/A	
36th	0.004	0.056	Single phase	N/A	
37th	0.010	0.141	Single phase	N/A	
38th	0.001	0.020	Single phase	N/A	
39th	0.011	0.151	Single phase	N/A	
40th	0.002	0.024	Single phase	N/A	
THD	--	4.528	Single phase	23	
PWHD	--	3.905	Single phase	23	

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P _{SMAX} and P _{CMAX} (CEI EN 61000-3-12)			P
Model	AF6K-SLP+1Battery			
Active power (W)	5010 (60°C)			
Voltage (V)	230.81			
Current (A)	21.77			
Power Factor	0.9974			
Frequency (Hz)	50.00			
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)
1st	21.764	--	Single phase	--
2nd	0.047	0.215	Single phase	8
3rd	0.122	0.562	Single phase	21,6
4th	0.003	0.013	Single phase	4
5th	0.097	0.444	Single phase	10,7
6th	0.006	0.028	Single phase	2,7
7th	0.060	0.275	Single phase	7,2
8th	0.008	0.038	Single phase	2
9th	0.060	0.274	Single phase	3,8
10th	0.006	0.028	Single phase	1,6
11th	0.047	0.217	Single phase	3,1
12th	0.006	0.028	Single phase	1,3
13th	0.041	0.189	Single phase	2
14th	0.002	0.009	Single phase	N/A
15th	0.030	0.139	Single phase	N/A
16th	0.008	0.036	Single phase	N/A
17th	0.030	0.138	Single phase	N/A
18th	0.004	0.017	Single phase	N/A
19th	0.027	0.122	Single phase	N/A
20th	0.010	0.044	Single phase	N/A
21st	0.029	0.134	Single phase	N/A
22nd	0.006	0.030	Single phase	N/A
23rd	0.024	0.108	Single phase	N/A
24th	0.012	0.055	Single phase	N/A
25th	0.013	0.057	Single phase	N/A
26th	0.004	0.020	Single phase	N/A
27th	0.011	0.051	Single phase	N/A
28th	0.008	0.035	Single phase	N/A
29th	0.013	0.059	Single phase	N/A
30th	0.002	0.011	Single phase	N/A
31st	0.014	0.064	Single phase	N/A
32nd	0.003	0.014	Single phase	N/A
33rd	0.011	0.050	Single phase	N/A
34th	0.002	0.009	Single phase	N/A
35th	0.012	0.056	Single phase	N/A
36th	0.002	0.011	Single phase	N/A
37th	0.011	0.052	Single phase	N/A
38th	0.001	0.007	Single phase	N/A
39th	0.011	0.051	Single phase	N/A
40th	0.002	0.007	Single phase	N/A
THD	--	1.052	Single phase	23
PWHD	--	1.595	Single phase	23

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+1Battery				
Active power (W)	3322 (60°C)				
Voltage (V)	230.51				
Current (A)	14.51				
Power Factor	0.9936				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	14.503	--	Single phase	--	
2nd	0.029	0.200	Single phase	8	
3rd	0.119	0.822	Single phase	21,6	
4th	0.005	0.036	Single phase	4	
5th	0.097	0.666	Single phase	10,7	
6th	0.006	0.043	Single phase	2,7	
7th	0.068	0.470	Single phase	7,2	
8th	0.011	0.075	Single phase	2	
9th	0.062	0.426	Single phase	3,8	
10th	0.011	0.076	Single phase	1,6	
11th	0.051	0.353	Single phase	3,1	
12th	0.011	0.074	Single phase	1,3	
13th	0.047	0.322	Single phase	2	
14th	0.010	0.069	Single phase	N/A	
15th	0.034	0.233	Single phase	N/A	
16th	0.006	0.044	Single phase	N/A	
17th	0.037	0.255	Single phase	N/A	
18th	0.017	0.118	Single phase	N/A	
19th	0.033	0.229	Single phase	N/A	
20th	0.014	0.100	Single phase	N/A	
21st	0.028	0.193	Single phase	N/A	
22nd	0.007	0.047	Single phase	N/A	
23rd	0.025	0.172	Single phase	N/A	
24th	0.015	0.107	Single phase	N/A	
25th	0.026	0.179	Single phase	N/A	
26th	0.004	0.028	Single phase	N/A	
27th	0.013	0.090	Single phase	N/A	
28th	0.008	0.054	Single phase	N/A	
29th	0.019	0.133	Single phase	N/A	
30th	0.003	0.023	Single phase	N/A	
31st	0.015	0.101	Single phase	N/A	
32nd	0.003	0.023	Single phase	N/A	
33rd	0.015	0.104	Single phase	N/A	
34th	0.002	0.013	Single phase	N/A	
35th	0.012	0.085	Single phase	N/A	
36th	0.004	0.024	Single phase	N/A	
37th	0.010	0.067	Single phase	N/A	
38th	0.002	0.012	Single phase	N/A	
39th	0.010	0.068	Single phase	N/A	
40th	0.001	0.009	Single phase	N/A	
THD	--	1.626	Single phase	23	
PWHD	--	2.868	Single phase	23	

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.3	TABLE: Harmonics measurement under test condition 25°C /-25°C / 60°C, 100% / 66% / 33% P_{SMAX} and P_{CMAX} (CEI EN 61000-3-12)				P
Model	AF6K-SLP+1Battery				
Active power (W)	1666 (60°C)				
Voltage (V)	230.24				
Current (A)	7.44				
Power Factor	0.9733				
Frequency (Hz)	50.00				
Harmonics	Current Magnitude (A)	Current Percent of Fundamental (%)	Phase	Harmonic Current Limits (%)	
1st	7.431	--	Single phase	--	
2nd	0.023	0.308	Single phase	8	
3rd	0.189	2.537	Single phase	21,6	
4th	0.006	0.080	Single phase	4	
5th	0.135	1.821	Single phase	10,7	
6th	0.007	0.098	Single phase	2,7	
7th	0.102	1.366	Single phase	7,2	
8th	0.012	0.166	Single phase	2	
9th	0.063	0.847	Single phase	3,8	
10th	0.016	0.214	Single phase	1,6	
11th	0.059	0.793	Single phase	3,1	
12th	0.015	0.204	Single phase	1,3	
13th	0.033	0.437	Single phase	2	
14th	0.009	0.119	Single phase	N/A	
15th	0.024	0.323	Single phase	N/A	
16th	0.003	0.036	Single phase	N/A	
17th	0.023	0.304	Single phase	N/A	
18th	0.010	0.138	Single phase	N/A	
19th	0.029	0.385	Single phase	N/A	
20th	0.012	0.161	Single phase	N/A	
21st	0.029	0.396	Single phase	N/A	
22nd	0.004	0.057	Single phase	N/A	
23rd	0.025	0.339	Single phase	N/A	
24th	0.009	0.120	Single phase	N/A	
25th	0.028	0.379	Single phase	N/A	
26th	0.009	0.119	Single phase	N/A	
27th	0.019	0.251	Single phase	N/A	
28th	0.003	0.038	Single phase	N/A	
29th	0.017	0.223	Single phase	N/A	
30th	0.004	0.056	Single phase	N/A	
31st	0.007	0.093	Single phase	N/A	
32nd	0.003	0.045	Single phase	N/A	
33rd	0.008	0.113	Single phase	N/A	
34th	0.004	0.048	Single phase	N/A	
35th	0.004	0.058	Single phase	N/A	
36th	0.003	0.043	Single phase	N/A	
37th	0.007	0.092	Single phase	N/A	
38th	0.002	0.021	Single phase	N/A	
39th	0.006	0.087	Single phase	N/A	
40th	0.001	0.020	Single phase	N/A	
THD	--	3.967	Single phase	23	
PWHD	--	4.723	Single phase	23	

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
Bbis.3 a) Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
60°C, 100% P_{C_{MAX}} power condition: AF1K-SL-1+1Battery						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.009	--	--	1.080		
3rd	0.224	--	--	2.300		
4th	0.008	--	--	0.430		
5th	0.026	--	--	1.140		
6th	0.006	--	--	0.300		
7th	0.057	--	--	0.770		
8th	0.006	--	--	0.230		
9th	0.034	--	--	0.400		
10th	0.005	--	--	0.184		
11th	0.022	--	--	0.330		
12th	0.005	--	--	0.153		
13th	0.035	--	--	0.210		
14th	0.006	--	--	0.131		
15th	0.054	--	--	0.150		
16th	0.006	--	--	0.115		
17th	0.039	--	--	0.132		
18th	0.005	--	--	0.102		
19th	0.006	--	--	0.118		
20th	0.004	--	--	0.092		
21th	0.013	--	--	0.107		
22th	0.005	--	--	0.084		
23th	0.016	--	--	0.098		
24th	0.003	--	--	0.077		
25th	0.011	--	--	0.090		
26th	0.003	--	--	0.071		
27th	0.007	--	--	0.083		
28th	0.003	--	--	0.066		
29th	0.011	--	--	0.078		
30th	0.002	--	--	0.061		
31th	0.014	--	--	0.073		
32th	0.002	--	--	0.058		
33th	0.011	--	--	0.068		
34th	0.003	--	--	0.054		
35th	0.006	--	--	0.064		
36th	0.004	--	--	0.051		
37th	0.008	--	--	0.061		
38th	0.002	--	--	0.048		
39th	0.010	--	--	0.058		
40th	0.002	--	--	0.046		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
60°C, 66% P_{C_{MAX}} power condition: AF1K-SL-1+1Battery				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.009	--	--	1.080
3rd	0.118	--	--	2.300
4th	0.008	--	--	0.430
5th	0.057	--	--	1.140
6th	0.007	--	--	0.300
7th	0.051	--	--	0.770
8th	0.006	--	--	0.230
9th	0.025	--	--	0.400
10th	0.006	--	--	0.184
11th	0.070	--	--	0.330
12th	0.006	--	--	0.153
13th	0.050	--	--	0.210
14th	0.005	--	--	0.131
15th	0.005	--	--	0.150
16th	0.004	--	--	0.115
17th	0.022	--	--	0.132
18th	0.004	--	--	0.102
19th	0.016	--	--	0.118
20th	0.005	--	--	0.092
21th	0.017	--	--	0.107
22th	0.004	--	--	0.084
23th	0.021	--	--	0.098
24th	0.004	--	--	0.077
25th	0.014	--	--	0.090
26th	0.004	--	--	0.071
27th	0.004	--	--	0.083
28th	0.003	--	--	0.066
29th	0.011	--	--	0.078
30th	0.003	--	--	0.061
31th	0.007	--	--	0.073
32th	0.002	--	--	0.058
33th	0.014	--	--	0.068
34th	0.002	--	--	0.054
35th	0.015	--	--	0.064
36th	0.004	--	--	0.051
37th	0.010	--	--	0.061
38th	0.002	--	--	0.048
39th	0.008	--	--	0.058
40th	0.001	--	--	0.046

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
60°C, 33% P_{C_{MAX}} power condition: AF1K-SL-1+1Battery				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.010	--	--	1.080
3rd	0.033	--	--	2.300
4th	0.008	--	--	0.430
5th	0.080	--	--	1.140
6th	0.007	--	--	0.300
7th	0.059	--	--	0.770
8th	0.007	--	--	0.230
9th	0.076	--	--	0.400
10th	0.009	--	--	0.184
11th	0.015	--	--	0.330
12th	0.006	--	--	0.153
13th	0.028	--	--	0.210
14th	0.006	--	--	0.131
15th	0.025	--	--	0.150
16th	0.006	--	--	0.115
17th	0.032	--	--	0.132
18th	0.004	--	--	0.102
19th	0.011	--	--	0.118
20th	0.004	--	--	0.092
21th	0.012	--	--	0.107
22th	0.004	--	--	0.084
23th	0.011	--	--	0.098
24th	0.003	--	--	0.077
25th	0.017	--	--	0.090
26th	0.004	--	--	0.071
27th	0.014	--	--	0.083
28th	0.003	--	--	0.066
29th	0.010	--	--	0.078
30th	0.003	--	--	0.061
31th	0.010	--	--	0.073
32th	0.002	--	--	0.058
33th	0.013	--	--	0.068
34th	0.002	--	--	0.054
35th	0.012	--	--	0.064
36th	0.003	--	--	0.051
37th	0.009	--	--	0.061
38th	0.002	--	--	0.048
39th	0.008	--	--	0.058
40th	0.002	--	--	0.046

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
60°C, 100% P_{S MAX} power condition: AF1K-SL-1+1Battery				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.021	--	--	1.080
3rd	0.222	--	--	2.300
4th	0.008	--	--	0.430
5th	0.130	--	--	1.140
6th	0.011	--	--	0.300
7th	0.079	--	--	0.770
8th	0.012	--	--	0.230
9th	0.029	--	--	0.400
10th	0.012	--	--	0.184
11th	0.040	--	--	0.330
12th	0.011	--	--	0.153
13th	0.043	--	--	0.210
14th	0.005	--	--	0.131
15th	0.048	--	--	0.150
16th	0.006	--	--	0.115
17th	0.034	--	--	0.132
18th	0.008	--	--	0.102
19th	0.021	--	--	0.118
20th	0.007	--	--	0.092
21th	0.007	--	--	0.107
22th	0.006	--	--	0.084
23th	0.006	--	--	0.098
24th	0.007	--	--	0.077
25th	0.010	--	--	0.090
26th	0.003	--	--	0.071
27th	0.006	--	--	0.083
28th	0.004	--	--	0.066
29th	0.004	--	--	0.078
30th	0.004	--	--	0.061
31th	0.008	--	--	0.073
32th	0.002	--	--	0.058
33th	0.013	--	--	0.068
34th	0.002	--	--	0.054
35th	0.012	--	--	0.064
36th	0.004	--	--	0.051
37th	0.010	--	--	0.061
38th	0.002	--	--	0.048
39th	0.009	--	--	0.058
40th	0.001	--	--	0.046

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)				
60°C, 66% P_{S MAX} power condition: AF1K-SL-1+1Battery				
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)
2nd	0.016	--	--	1.080
3rd	0.262	--	--	2.300
4th	0.008	--	--	0.430
5th	0.099	--	--	1.140
6th	0.011	--	--	0.300
7th	0.057	--	--	0.770
8th	0.012	--	--	0.230
9th	0.061	--	--	0.400
10th	0.009	--	--	0.184
11th	0.068	--	--	0.330
12th	0.006	--	--	0.153
13th	0.024	--	--	0.210
14th	0.005	--	--	0.131
15th	0.011	--	--	0.150
16th	0.004	--	--	0.115
17th	0.013	--	--	0.132
18th	0.008	--	--	0.102
19th	0.007	--	--	0.118
20th	0.005	--	--	0.092
21th	0.014	--	--	0.107
22th	0.004	--	--	0.084
23th	0.020	--	--	0.098
24th	0.005	--	--	0.077
25th	0.019	--	--	0.090
26th	0.004	--	--	0.071
27th	0.010	--	--	0.083
28th	0.004	--	--	0.066
29th	0.015	--	--	0.078
30th	0.003	--	--	0.061
31th	0.012	--	--	0.073
32th	0.003	--	--	0.058
33th	0.008	--	--	0.068
34th	0.002	--	--	0.054
35th	0.006	--	--	0.064
36th	0.005	--	--	0.051
37th	0.008	--	--	0.061
38th	0.002	--	--	0.048
39th	0.006	--	--	0.058
40th	0.001	--	--	0.046

CEI 0-21						
Clause	Requirement - Test	Result - Remark		Verdict		
Harmonics measurement under test condition 25°C /-25°C / 60°C (CEI EN 61000-3-2)						
60°C, 33% P_{SMAX} power condition: AF1K-SL-1+1Battery						
Harmonic	L1 Phase (A)	L2 Phase (A)	L3 Phase (A)	Limit (A)		
2nd	0.014	--	--	1.080		
3rd	0.269	--	--	2.300		
4th	0.007	--	--	0.430		
5th	0.068	--	--	1.140		
6th	0.007	--	--	0.300		
7th	0.110	--	--	0.770		
8th	0.006	--	--	0.230		
9th	0.038	--	--	0.400		
10th	0.008	--	--	0.184		
11th	0.025	--	--	0.330		
12th	0.007	--	--	0.153		
13th	0.008	--	--	0.210		
14th	0.004	--	--	0.131		
15th	0.026	--	--	0.150		
16th	0.007	--	--	0.115		
17th	0.029	--	--	0.132		
18th	0.006	--	--	0.102		
19th	0.021	--	--	0.118		
20th	0.004	--	--	0.092		
21th	0.019	--	--	0.107		
22th	0.003	--	--	0.084		
23th	0.004	--	--	0.098		
24th	0.007	--	--	0.077		
25th	0.014	--	--	0.090		
26th	0.004	--	--	0.071		
27th	0.011	--	--	0.083		
28th	0.005	--	--	0.066		
29th	0.011	--	--	0.078		
30th	0.002	--	--	0.061		
31th	0.008	--	--	0.073		
32th	0.003	--	--	0.058		
33th	0.009	--	--	0.068		
34th	0.002	--	--	0.054		
35th	0.009	--	--	0.064		
36th	0.002	--	--	0.051		
37th	0.008	--	--	0.061		
38th	0.002	--	--	0.048		
39th	0.010	--	--	0.058		
40th	0.002	--	--	0.046		

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.3 c)	TABLE: Flicker measurement	P
<input checked="" type="checkbox"/> CEI EN 61000-3-3		
<input checked="" type="checkbox"/> CEI EN 61000-3-11		
<input checked="" type="checkbox"/> Ambient temperature		
<input checked="" type="checkbox"/> -25°C temperature		
<input checked="" type="checkbox"/> +60°C temperature		
<input checked="" type="checkbox"/> Full power, 66% and 33% of P_{SMAX} / P_{NINV}		
<input checked="" type="checkbox"/> Full power, 66% and 33% of P_{CMAX}		
c) limits of voltage fluctuations and flicker (CEI EN 61000-3-3 or CEI EN 61000-3-11); they must be repeated in 6 sessions (at 33%, 66% and 100% of the P_{SMAX} , or P_{NINV} for integrated EESS, and at 33%, 66% and 100% of the P_{CMAX}), and for storage systems connected to unidirectional converters in 3 sessions (at 33%, 66% and 100% of the maximum available power in discharge)		
Supplementary information: *If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test.		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Mode	AF6K-SLP+15Battery-Discharge				
Normal ambient					
Output power:	Flicker limits according to*:		Result:		
			Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11		0.104	0.107	0.015
66%	EN61000-3-3 / EN61000-3-11		0.105	0.114	0.043
100%	EN61000-3-3 / EN61000-3-11		0.105	0.112	0.015
Minimum ambient rating (-25°C) or -10°C					
Output power:	Flicker limits according to*:		Result:		
			Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11		0.105	0.112	0.025
66%	EN61000-3-3 / EN61000-3-11		0.100	0.108	0.047
100%	EN61000-3-3 / EN61000-3-11		0.106	0.112	0.017
Maximum ambient rating (+60°C) or +55°C					
Output power:	Flicker limits according to*:		Result:		
			Plt	Pst	dc%
33%	EN61000-3-3 / EN61000-3-11		0.100	0.110	0.046
66%	EN61000-3-3 / EN61000-3-11		0.102	0.112	0.046
100%	EN61000-3-3 / EN61000-3-11		0.106	0.113	0.023
Note:					
* Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega; jX_{max} = \Omega @ 50Hz (Z_{max} = \Omega)$					
Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c : $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$					
The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.					
	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.013 Pass	0.291 Pass	0.0 Pass	0.106 Pass	
2	0.011 Pass	0.278 Pass	0.0 Pass	0.102 Pass	
3	0.011 Pass	0.287 Pass	0.0 Pass	0.104 Pass	
4	0.009 Pass	0.276 Pass	0.0 Pass	0.107 Pass	
5	0.009 Pass	0.291 Pass	0.0 Pass	0.107 Pass	
6	0.013 Pass	0.299 Pass	0.0 Pass	0.101 Pass	
7	0.013 Pass	0.283 Pass	0.0 Pass	0.102 Pass	
8	0.015 Pass	0.271 Pass	0.0 Pass	0.102 Pass	
9	0.014 Pass	0.276 Pass	0.0 Pass	0.107 Pass	
10	0.007 Pass	0.301 Pass	0.0 Pass	0.102 Pass	
11	0.010 Pass	0.297 Pass	0.0 Pass	0.103 Pass	
12	0.014 Pass	0.296 Pass	0.0 Pass	0.102 Pass	
Result	Pass	Pass	Pass	Pass	0.104 Pass

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Mode	AF6K-SLP+15Battery-Charge									
Normal ambient										
Output power:	Flicker limits according to*:		Result:							
			Plt	Pst	dc%					
33%	EN61000-3-3 / EN61000-3-11	0.104	0.116	0.046						
66%	EN61000-3-3 / EN61000-3-11	0.103	0.113	0.046						
100%	EN61000-3-3 / EN61000-3-11	0.100	0.102	0.027						
Minimum ambient rating (-25°C) or -10°C										
Output power:	Flicker limits according to*:		Result:							
			Plt	Pst	dc%					
33%	EN61000-3-3 / EN61000-3-11	0.103	0.115	0.047						
66%	EN61000-3-3 / EN61000-3-11	0.103	0.115	0.047						
100%	EN61000-3-3 / EN61000-3-11	0.101	0.109	0.034						
Maximum ambient rating (+60°C) or +55°C										
Output power:	Flicker limits according to*:		Result:							
			Plt	Pst	dc%					
33%	EN61000-3-3 / EN61000-3-11	0.102	0.108	0.030						
66%	EN61000-3-3 / EN61000-3-11	0.101	0.104	0.031						
100%	EN61000-3-3 / EN61000-3-11	0.103	0.108	0.025						
Note:										
* Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega; jX_{max} = \Omega @ 50Hz (Z_{max} = \Omega)$										
Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c : $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$										
Limit	dc[%]		dmax[%]		d(t)[ms]		Pst		Plt	
	3.30		4.00		500 3.30%		1.00		0.65 N:12	
No. 1	0.042	Pass	0.254	Pass	0.0	Pass	0.093	Pass		
2	0.040	Pass	0.264	Pass	0.0	Pass	0.115	Pass		
3	0.039	Pass	0.264	Pass	0.0	Pass	0.103	Pass		
4	0.045	Pass	0.261	Pass	0.0	Pass	0.116	Pass		
5	0.045	Pass	0.273	Pass	0.0	Pass	0.096	Pass		
6	0.040	Pass	0.275	Pass	0.0	Pass	0.115	Pass		
7	0.039	Pass	0.266	Pass	0.0	Pass	0.094	Pass		
8	0.037	Pass	0.256	Pass	0.0	Pass	0.100	Pass		
9	0.035	Pass	0.263	Pass	0.0	Pass	0.115	Pass		
10	0.046	Pass	0.262	Pass	0.0	Pass	0.102	Pass		
11	0.041	Pass	0.260	Pass	0.0	Pass	0.097	Pass		
12	0.041	Pass	0.255	Pass	0.0	Pass	0.096	Pass		
Result	Pass		Pass		Pass		Pass		0.104 Pass	

CEI 0-21											
Clause	Requirement - Test			Result - Remark		Verdict					
Mode AF6K-SLP+1Battery-Discharge											
Abnormal ambient											
Output power:	Flicker limits according to*:			Result:							
				Plt	Pst	dc%					
33%	EN61000-3-3 / EN61000-3-11			0.105	0.112	0.037					
66%	EN61000-3-3 / EN61000-3-11			0.104	0.112	0.039					
100%	EN61000-3-3 / EN61000-3-11			0.103	0.109	0.039					
Note:											
* Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega$; $jX_{max} = \Omega @ 50Hz$ ($ Z_{max} = \Omega$)											
Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c : $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$											
The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.											
If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).											
Limit	dc[%]		dmax[%]		d(t)[ms]						
	3.30		4.00		500 3.30%						
No. 1	0.030	Pass	0.298	Pass	0.0	Pass					
2	0.034	Pass	0.293	Pass	0.0	Pass					
3	0.029	Pass	0.298	Pass	0.0	Pass					
4	0.029	Pass	0.303	Pass	0.0	Pass					
5	0.034	Pass	0.297	Pass	0.0	Pass					
6	0.037	Pass	0.295	Pass	0.0	Pass					
7	0.031	Pass	0.300	Pass	0.0	Pass					
8	0.033	Pass	0.298	Pass	0.0	Pass					
9	0.035	Pass	0.292	Pass	0.0	Pass					
10	0.032	Pass	0.293	Pass	0.0	Pass					
11	0.037	Pass	0.292	Pass	0.0	Pass					
12	0.032	Pass	0.292	Pass	0.0	Pass					
Result	Pass		Pass		Pass						
					0.105 Pass						

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Mode	AF6K-SLP+1Battery-Charge			
Abnormal ambient				
Output power:	Flicker limits according to*:		Result:	
			Plt	Pst
33%	EN61000-3-3 / EN61000-3-11	0.104	0.111	0.038
66%	EN61000-3-3 / EN61000-3-11	0.104	0.112	0.038
100%	EN61000-3-3 / EN61000-3-11	0.103	0.109	0.035

Note:

* Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega; jX_{max} = \Omega @ 50Hz (|Z_{max}| = \Omega)$

Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c :
 $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$

The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.

If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.032 Pass	0.295 Pass	0.0 Pass	0.111 Pass	
2	0.032 Pass	0.296 Pass	0.0 Pass	0.103 Pass	
3	0.031 Pass	0.304 Pass	0.0 Pass	0.103 Pass	
4	0.030 Pass	0.303 Pass	0.0 Pass	0.112 Pass	
5	0.032 Pass	0.299 Pass	0.0 Pass	0.100 Pass	
6	0.031 Pass	0.302 Pass	0.0 Pass	0.102 Pass	
7	0.030 Pass	0.295 Pass	0.0 Pass	0.105 Pass	
8	0.038 Pass	0.298 Pass	0.0 Pass	0.098 Pass	
9	0.031 Pass	0.293 Pass	0.0 Pass	0.100 Pass	
10	0.031 Pass	0.293 Pass	0.0 Pass	0.108 Pass	
11	0.029 Pass	0.292 Pass	0.0 Pass	0.104 Pass	
12	0.035 Pass	0.300 Pass	0.0 Pass	0.099 Pass	
Result	Pass	Pass	Pass	Pass	0.104 Pass

CEI 0-21											
Clause	Requirement - Test			Result - Remark		Verdict					
Mode AF1K-SL-1+1Battery-Discharge											
Abnormal ambient											
Output power:	Flicker limits according to*:			Result:							
				Plt	Pst	dc%					
33%	EN61000-3-3 / EN61000-3-11			0.104	0.112	0.036					
66%	EN61000-3-3 / EN61000-3-11			0.103	0.110	0.033					
100%	EN61000-3-3 / EN61000-3-11			0.096	0.104	0.028					
Note:											
* Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega; jX_{max} = \Omega @ 50Hz (Z_{max} = \Omega)$											
Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c : $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$											
The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.											
If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).											
	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt						
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12						
No. 1	0.027 Pass	0.291 Pass	0.0 Pass	0.104 Pass							
2	0.029 Pass	0.288 Pass	0.0 Pass	0.107 Pass							
3	0.028 Pass	0.317 Pass	0.0 Pass	0.100 Pass							
4	0.036 Pass	0.293 Pass	0.0 Pass	0.105 Pass							
5	0.027 Pass	0.297 Pass	0.0 Pass	0.107 Pass							
6	0.027 Pass	0.307 Pass	0.0 Pass	0.101 Pass							
7	0.032 Pass	0.301 Pass	0.0 Pass	0.105 Pass							
8	0.025 Pass	0.290 Pass	0.0 Pass	0.112 Pass							
9	0.026 Pass	0.313 Pass	0.0 Pass	0.099 Pass							
10	0.030 Pass	0.301 Pass	0.0 Pass	0.100 Pass							
11	0.025 Pass	0.297 Pass	0.0 Pass	0.108 Pass							
12	0.028 Pass	0.300 Pass	0.0 Pass	0.101 Pass							
Result	Pass	Pass	Pass	Pass	0.104	Pass					

CEI 0-21								
Clause	Requirement - Test			Result - Remark				
Mode	AF1K-SL-1+1Battery-Charge							
Abnormal ambient								
Output power:	Flicker limits according to*:			Result:				
				Plt	Pst			
33%	EN61000-3-3 / EN61000-3-11			0.107	0.110			
66%	EN61000-3-3 / EN61000-3-11			0.104	0.112			
100%	EN61000-3-3 / EN61000-3-11			0.104	0.107			
Note: * Mains Impedance according EN61000-3-3 / EN61000-3-11: $R_{max} = \Omega; jX_{max} = \Omega @ 50Hz (Z_{max} = \Omega)$								
Calculation of the maximum permissible grid impedance at the point of common coupling based on d_c : $Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$								
The tests should be based on the limits of the EN61000-3-3 for less than 16A and on EN 61000-3-11 for more than 16A.								
If the EUT operating temperature out of -10°C to 55°C, please use the upper and lower operating temperature limit in the test (such as -25°C / +60°C).								
	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt			
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12			
No. 1	0.036 Pass	0.326 Pass	0.0 Pass	0.110 Pass				
2	0.041 Pass	0.259 Pass	0.0 Pass	0.108 Pass				
3	0.040 Pass	0.299 Pass	0.0 Pass	0.107 Pass				
4	0.049 Pass	0.290 Pass	0.0 Pass	0.108 Pass				
5	0.042 Pass	0.225 Pass	0.0 Pass	0.107 Pass				
6	0.037 Pass	0.267 Pass	0.0 Pass	0.107 Pass				
7	0.034 Pass	0.288 Pass	0.0 Pass	0.107 Pass				
8	0.038 Pass	0.235 Pass	0.0 Pass	0.105 Pass				
9	0.032 Pass	0.247 Pass	0.0 Pass	0.105 Pass				
10	0.039 Pass	0.270 Pass	0.0 Pass	0.107 Pass				
11	0.040 Pass	0.307 Pass	0.0 Pass	0.107 Pass				
12	0.046 Pass	0.264 Pass	0.0 Pass	0.110 Pass				
Result	Pass	Pass	Pass	Pass	0.107 Pass			

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.4	TABLE: Check the operating range in voltage and frequency					P						
Model	AF6K-SLP+15Battery											
Supplementary information:												
$P_{SMAX} = 6kW$												
$P_{CMAX} = 6kW$												
Test Point	Voltage (%)	Frequency(Hz)	P (W) *	$\cos \varphi$	Time (s)	Result						
Test 1	85.08	47.50	5328	0.999	>5min	No disconnection						
Test 2	110.02	51.50	5990	0.999	>5min	No disconnection						
Test 3	85.03	47.50	-5326	-0.998	>5min	No disconnection						
Test 4	109.87	51.50	-6049	-0.997	>5min	No disconnection						
Test 1: $V = 85 \% * V_n$; $f = 47,5$ Hz; $P = 100 \% * P_{SMAX}$ (PNINV for integrated EESS); $\cos \varphi = 1$												
Test 2: $V = 110 \% * V_n$; $f = 51,5$ Hz; $P = 100 \% * P_{SMAX}$ (PNINV for integrated EESS); $\cos \varphi = 1$												
Test 3: $V = 85 \% * V_n$; $f = 47,5$ Hz; $P = 100 \% * P_{CMAX}$; $\cos \varphi = 1$												
Test 4: $V = 110 \% * V_n$; $f = 51,5$ Hz; $P = 100 \% * P_{CMAX}$; $\cos \varphi = 1$												
*: Due to conversion efficiency, it is not possible to achieve 100% P_{SMAX}												
During the tests it is necessary to disable the automatic regulation in reduction / increase of the power in case of over / under frequency.												

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram of Test 1





Diagram of Test 2



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram of Test 3





Diagram of Test 4



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Bbis.5	TABLE: Conditions of connection, reconnection and gradual power supply		
Model	AF6K-SLP+15Battery		
Test:			
Power meter measurement-data:	Sample-Rate:	0.2 s	
	Sample time:		
Voltage conditons			
a) Out of voltage range	84% U_n for 30s	111% U_n for 30s	
Connection:	No connection	No connection	
Limit	No connection allowed		
b) In voltage range at start-up	85% U_n < U < 110% U_n		
Reconnection time [s]	32.6	33.2	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
c) In voltage range after voltage failture	85% U_n < U < 110% U_n		
Reconnection time [s]	305.4	303.8	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Frequency conditions			
d) Out of frequency range	49,88 ± 0,01	50,12 ± 0,01	
Connection:	No connection	No connection	
Limit	No connection allowed		
e) In frequency range at start-up	49,90 Hz < f < 50,10		
Reconnection time [s]	34.8	32.6	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
f) In frequency range after frequency failture	49,90 Hz < f < 50,10		
Reconnection time [s]	303.8	307.2	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Changable reconnection conditions:	Frequency range: 49Hz-51Hz in 0,05Hz steps (default value: 49,90 and 50,10Hz)		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Test: Test condition b) and c): voltage within the limits of 85% to 110% U_n Test condition e) and f): frequency within the limits of 49,90Hz to 50,10Hz Max deviation of the gradient: $+2,5\%P_{SMAX}$ or P_{NINV}		Reconnection time range: 0-900s in steps of 5s (default value: 300s)	

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------





CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Bbis.5	TABLE: Conditions of connection, reconnection and gradual power supply		
Model	AF6K-SLP+1Battery		
Test:			
Power meter measurement-data:	Sample-Rate:	0.2 s	
	Sample time:	-	
Voltage conditons			
a) Out of voltage range	84% U_n for 30s	111% U_n for 30s	
Connection:	No connection	No connection	
Limit	No connection allowed		
b) In voltage range at start-up	85% U_n < U < 110% U_n		
Reconnection time [s]	31.2	33.6	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
c) In voltage range after voltage failture	85% U_n < U < 110% U_n		
Reconnection time [s]	306.4	305.4	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Frequency conditions			
d) Out of frequency range	49,88 ± 0,01	50,12 ± 0,01	
Connection:	No connection	No connection	
Limit	No connection allowed		
e) In frequency range at start-up	49,90 Hz < f < 50,10		
Reconnection time [s]	33.6	32.8	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
f) In frequency range after frequency failture	49,90 Hz < f < 50,10		
Reconnection time [s]	308.6	305.4	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Changable reconnection conditions:	Frequency range: 49Hz-51Hz in 0,05Hz steps (default value: 49,90 and 50,10Hz)		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict																																																					
Test: Test condition b) and c): voltage within the limits of 85% to 110% U_n Test condition e) and f): frequency within the limits of 49,90Hz to 50,10Hz Max deviation of the gradient: $+2,5\%P_{SMAX}$ or P_{NINV}		Reconnection time range: 0-900s in steps of 5s (default value: 300s)																																																						
	 <table border="1"> <caption>Data for Graph 1</caption> <thead> <tr> <th>Time [s]</th> <th>Power [W]</th> <th>Voltage [V]</th> </tr> </thead> <tbody> <tr><td>0</td><td>0</td><td>200</td></tr> <tr><td>0</td><td>0</td><td>240</td></tr> <tr><td>360</td><td>5000</td><td>240</td></tr> <tr><td>540</td><td>0</td><td>180</td></tr> <tr><td>900</td><td>0</td><td>180</td></tr> <tr><td>900</td><td>0</td><td>240</td></tr> <tr><td>1080</td><td>5000</td><td>240</td></tr> <tr><td>1260</td><td>5000</td><td>240</td></tr> </tbody> </table>  <table border="1"> <caption>Data for Graph 2</caption> <thead> <tr> <th>Time [s]</th> <th>Power [W]</th> <th>Voltage [V]</th> </tr> </thead> <tbody> <tr><td>0</td><td>0</td><td>200</td></tr> <tr><td>0</td><td>0</td><td>240</td></tr> <tr><td>360</td><td>5000</td><td>240</td></tr> <tr><td>540</td><td>0</td><td>180</td></tr> <tr><td>900</td><td>0</td><td>180</td></tr> <tr><td>900</td><td>0</td><td>240</td></tr> <tr><td>1080</td><td>5000</td><td>240</td></tr> <tr><td>1260</td><td>5000</td><td>240</td></tr> </tbody> </table>	Time [s]	Power [W]	Voltage [V]	0	0	200	0	0	240	360	5000	240	540	0	180	900	0	180	900	0	240	1080	5000	240	1260	5000	240	Time [s]	Power [W]	Voltage [V]	0	0	200	0	0	240	360	5000	240	540	0	180	900	0	180	900	0	240	1080	5000	240	1260	5000	240	
Time [s]	Power [W]	Voltage [V]																																																						
0	0	200																																																						
0	0	240																																																						
360	5000	240																																																						
540	0	180																																																						
900	0	180																																																						
900	0	240																																																						
1080	5000	240																																																						
1260	5000	240																																																						
Time [s]	Power [W]	Voltage [V]																																																						
0	0	200																																																						
0	0	240																																																						
360	5000	240																																																						
540	0	180																																																						
900	0	180																																																						
900	0	240																																																						
1080	5000	240																																																						
1260	5000	240																																																						

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Bbis.5	TABLE: Conditions of connection, reconnection and gradual power supply		
Model	AF1K-SL-1+1Battery		
Test:			
Power meter measurement-data:	Sample-Rate:	0.2 s	
	Sample time:	-	
Voltage conditons			
a) Out of voltage range	84% U_n for 30s	111% U_n for 30s	
Connection:	No connection	No connection	
Limit	No connection allowed		
b) In voltage range at start-up	85% U_n < U < 110% U_n		
Reconnection time [s]	34.6	36.4	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
c) In voltage range after voltage failture	85% U_n < U < 110% U_n		
Reconnection time [s]	303.2	302.8	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Frequency conditions			
d) Out of frequency range	49,88 ± 0,01	50,12 ± 0,01	
Connection:	No connection	No connection	
Limit	No connection allowed		
e) In frequency range at start-up	49,90 Hz < f < 50,10		
Reconnection time [s]	35.4	32.6	
Limit:	Reconnection after 30s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
f) In frequency range after frequency failture	49,90 Hz < f < 50,10		
Reconnection time [s]	306.2	304.6	
Limit:	Reconnection after 300s		
Gradient:	Gradient schould be recorded for at least 300s until the inverter has the full output power. Max gradient: 20% % P_{SMAX} or P_{NINV} / min For recorded gradient see diagram underneath		
Changable reconnection conditions:	Frequency range: 49Hz-51Hz in 0,05Hz steps (default value: 49,90 and 50,10Hz)		

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Test: Test condition b) and c): voltage within the limits of 85% to 110% U_n Test condition e) and f): frequency within the limits of 49,90Hz to 50,10Hz Max deviation of the gradient: $+2,5\%P_{SMAX}$ or P_{NINV}		Reconnection time range: 0-900s in steps of 5s (default value: 300s)	
			


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	

Model	AF6K-SLP+15Battery
-------	--------------------

TABLE: Reactive power production with set point Q = 0

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-5976	-99.60%	-185	-3.08%	-5435	-90.59%	-0.9995
80% -90% P _{CMAX}	-5371	-89.52%	-180	-3.00%	-4885	-81.41%	-0.9994
70% -80% P _{CMAX}	-4767	-79.44%	-174	-2.90%	-4335	-72.25%	-0.9993
60% -70% P _{CMAX}	-4160	-69.33%	-167	-2.78%	-3783	-63.05%	-0.9992
50% -60% P _{CMAX}	-3556	-59.26%	-161	-2.68%	-3233	-53.88%	-0.9990
40% -50% P _{CMAX}	-2951	-49.18%	-153	-2.56%	-2682	-44.71%	-0.9986
30% -40% P _{CMAX}	-2346	-39.10%	-146	-2.43%	-2132	-35.54%	-0.9980
20% -30% P _{CMAX}	-1741	-29.02%	-136	-2.26%	-1582	-26.36%	-0.9969
10% -20% P _{CMAX}	-1139	-18.99%	-121	-2.02%	-1034	-17.23%	-0.9943
0% -10% P _{CMAX}	-538	-8.96%	-100	-1.66%	-487	-8.11%	-0.9830
0% -10% P _{SMAX}	500	8.33%	-98	-1.64%	554	9.24%	0.9796
10% -20% P _{SMAX}	1120	18.67%	-88	-1.47%	1236	20.60%	0.9966
20% -30% P _{SMAX}	1729	28.81%	-81	-1.35%	1905	31.74%	0.9988
30% -40% P _{SMAX}	2333	38.89%	-76	-1.27%	2569	42.82%	0.9994
40% -50% P _{SMAX}	2929	48.82%	-73	-1.22%	3224	53.73%	0.9997
50% -60% P _{SMAX}	3522	58.70%	-70	-1.17%	3876	64.60%	0.9998
60% -70% P _{SMAX}	4115	68.58%	-70	-1.16%	4526	75.44%	0.9998
70% -80% P _{SMAX}	4705	78.41%	-68	-1.13%	5175	86.25%	0.9999
80% -90% P _{SMAX}	5295	88.24%	-68	-1.13%	5823	97.05%	0.9999
90% -100% P _{SMAX}	5952	99.20%	-80	-1.34%	6545	109.09%	0.9999

TABLE: Reactive power production with set point Q = -Q_{max} (>11.08 kW) or cos φ = -0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-5379	-89.66%	-2903	-48.39%	-4892	-81.53%	-0.8799
80% -90% P _{CMAX}	-5165	-86.09%	-2902	-48.37%	-4697	-78.28%	-0.8717
70% -80% P _{CMAX}	-4774	-79.56%	-2904	-48.40%	-4340	-72.34%	-0.8547
60% -70% P _{CMAX}	-4168	-69.47%	-2903	-48.39%	-3789	-63.15%	-0.8210
50% -60% P _{CMAX}	-3564	-59.39%	-2903	-48.38%	-3239	-53.98%	-0.7763
40% -50% P _{CMAX}	-2957	-49.28%	-2904	-48.40%	-2687	-44.79%	-0.7135
30% -40% P _{CMAX}	-2354	-39.24%	-2905	-48.42%	-2139	-35.65%	-0.6304
20% -30% P _{CMAX}	-1751	-29.19%	-2905	-48.42%	-1590	-26.50%	-0.5172

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	
10% -20% P _{CMAX}	-1148	-19.14%	-2904	-48.40%	-1041	-17.35%	-0.3688
0% -10% P _{CMAX}	-546	-9.10%	-2903	-48.39%	-493	-8.22%	-0.1861
0% -10% P _{SMAX}	507	8.45%	-2904	-48.40%	560	9.34%	0.1707
10% -20% P _{SMAX}	1120	18.66%	-2909	-48.48%	1234	20.56%	0.3581
20% -30% P _{SMAX}	1731	28.86%	-2904	-48.41%	1905	31.76%	0.5110
30% -40% P _{SMAX}	2328	38.80%	-2905	-48.42%	2561	42.69%	0.6248
40% -50% P _{SMAX}	2927	48.78%	-2907	-48.46%	3220	53.66%	0.7088
50% -60% P _{SMAX}	3523	58.72%	-2905	-48.41%	3875	64.58%	0.7713
60% -70% P _{SMAX}	4119	68.64%	-2904	-48.40%	4529	75.48%	0.8171
70% -80% P _{SMAX}	4711	78.51%	-2906	-48.44%	5180	86.33%	0.8507
80% -90% P _{SMAX}	5144	85.74%	-2906	-48.44%	5656	94.27%	0.8707
90% -100% P _{SMAX}	5333	88.88%	-2904	-48.40%	5863	97.72%	0.8780

TABLE: Reactive power production with set point Q =+Q_{max} (>11.08 kW) or cos φ = +0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-5404	-90.06%	2911	48.52%	-4913	-81.88%	-0.8813
80% -90% P _{CMAX}	-5238	-87.31%	2915	48.59%	-4762	-79.37%	-0.8743
70% -80% P _{CMAX}	-4791	-79.85%	2911	48.51%	-4355	-72.59%	-0.8556
60% -70% P _{CMAX}	-4186	-69.77%	2911	48.52%	-3805	-63.42%	-0.8221
50% -60% P _{CMAX}	-3580	-59.67%	2911	48.52%	-3253	-54.22%	-0.7772
40% -50% P _{CMAX}	-2974	-49.57%	2912	48.54%	-2702	-45.04%	-0.7163
30% -40% P _{CMAX}	-2370	-39.50%	2912	48.53%	-2152	-35.87%	-0.6332
20% -30% P _{CMAX}	-1767	-29.44%	2911	48.51%	-1603	-26.72%	-0.5215
10% -20% P _{CMAX}	-1163	-19.39%	2911	48.51%	-1054	-17.57%	-0.3734
0% -10% P _{CMAX}	-561	-9.36%	2913	48.54%	-506	-8.44%	-0.1912
0% -10% P _{SMAX}	528	8.80%	2909	48.48%	582	9.71%	0.1794
10% -20% P _{SMAX}	1106	18.43%	2908	48.47%	1217	20.29%	0.3574
20% -30% P _{SMAX}	1712	28.53%	2911	48.51%	1883	31.38%	0.5094
30% -40% P _{SMAX}	2312	38.53%	2909	48.48%	2542	42.37%	0.6239
40% -50% P _{SMAX}	2914	48.57%	2909	48.48%	3204	53.41%	0.7089
50% -60% P _{SMAX}	3515	58.58%	2910	48.50%	3865	64.42%	0.7709
60% -70% P _{SMAX}	4108	68.47%	2908	48.46%	4516	75.27%	0.8161
70% -80% P _{SMAX}	4698	78.31%	2909	48.48%	5165	86.09%	0.8507
80% -90% P _{SMAX}	5291	88.19%	2908	48.47%	5817	96.94%	0.8764
90% -100% P _{SMAX}	5349	89.15%	2909	48.48%	5881	98.01%	0.8786

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	
Model AF6K-SLP+1Battery							

TABLE: Reactive power production with set point Q = 0							
Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-4913	-98.25%	-174	-2.89%	-4467	-89.34%	-0.9993
80% -90% P _{CMAX}	-4410	-88.19%	-167	-2.79%	-4009	-80.19%	-0.9993
70% -80% P _{CMAX}	-3912	-78.24%	-162	-2.69%	-3556	-71.13%	-0.9991
60% -70% P _{CMAX}	-3410	-68.20%	-157	-2.61%	-3100	-61.99%	-0.9989
50% -60% P _{CMAX}	-2908	-58.16%	-150	-2.50%	-2643	-52.85%	-0.9986
40% -50% P _{CMAX}	-2413	-48.26%	-144	-2.40%	-2192	-43.85%	-0.9981
30% -40% P _{CMAX}	-1906	-38.13%	-137	-2.28%	-1731	-34.62%	-0.9973
20% -30% P _{CMAX}	-1406	-28.13%	-126	-2.10%	-1276	-25.52%	-0.9958
10% -20% P _{CMAX}	-907	-18.13%	-110	-1.84%	-822	-16.44%	-0.9922
0% -10% P _{CMAX}	-403	-8.06%	-93	-1.55%	-363	-7.26%	-0.9730
0% -10% P _{SMAX}	419	8.38%	-101	-1.68%	462	9.23%	0.9697
10% -20% P _{SMAX}	919	18.39%	-93	-1.55%	1012	20.24%	0.9945
20% -30% P _{SMAX}	1433	28.65%	-86	-1.44%	1575	31.51%	0.9980
30% -40% P _{SMAX}	1924	38.49%	-81	-1.36%	2116	42.32%	0.9990
40% -50% P _{SMAX}	2422	48.43%	-78	-1.30%	2662	53.25%	0.9994
50% -60% P _{SMAX}	2927	58.55%	-75	-1.24%	3218	64.37%	0.9996
60% -70% P _{SMAX}	3422	68.44%	-72	-1.20%	3762	75.24%	0.9998
70% -80% P _{SMAX}	3922	78.43%	-71	-1.18%	4311	86.22%	0.9998
80% -90% P _{SMAX}	4420	88.39%	-69	-1.15%	4858	97.16%	0.9999
90% -100% P _{SMAX}	4912	98.24%	-67	-1.12%	5399	107.99%	0.9999

TABLE: Reactive power production with set point Q = -Q_{max} (>11.08 kW) or cos φ = -0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-4926	-98.52%	-2916	-48.60%	-4479	-89.59%	-0.8605
80% -90% P _{CMAX}	-4417	-88.35%	-2922	-48.69%	-4017	-80.34%	-0.8346
70% -80% P _{CMAX}	-3909	-78.19%	-2926	-48.77%	-3555	-71.10%	-0.8016
60% -70% P _{CMAX}	-3414	-68.28%	-2912	-48.53%	-3103	-62.07%	-0.7605
50% -60% P _{CMAX}	-2906	-58.12%	-2924	-48.73%	-2642	-52.84%	-0.7061
40% -50% P _{CMAX}	-2411	-48.23%	-2916	-48.59%	-2192	-43.84%	-0.6376
30% -40% P _{CMAX}	-1911	-38.22%	-2909	-48.48%	-1737	-34.73%	-0.5486
20% -30% P _{CMAX}	-1411	-28.22%	-2917	-48.61%	-1281	-25.62%	-0.4363

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	
10% -20% P _{CMAX}	-911	-18.22%	-2917	-48.62%	-826	-16.53%	-0.2991
0% -10% P _{CMAX}	-411	-8.23%	-2917	-48.61%	-372	-7.44%	-0.1409
0% -10% P _{SMAX}	428	8.56%	-2930	-48.83%	472	9.43%	0.1433
10% -20% P _{SMAX}	913	18.27%	-2924	-48.73%	1005	20.11%	0.2970
20% -30% P _{SMAX}	1422	28.43%	-2931	-48.85%	1564	31.27%	0.4364
30% -40% P _{SMAX}	1922	38.45%	-2919	-48.65%	2114	42.28%	0.5488
40% -50% P _{SMAX}	2424	48.48%	-2929	-48.82%	2665	53.31%	0.6378
50% -60% P _{SMAX}	2928	58.56%	-2919	-48.65%	3219	64.38%	0.7074
60% -70% P _{SMAX}	3429	68.58%	-2926	-48.77%	3770	75.39%	0.7608
70% -80% P _{SMAX}	3923	78.47%	-2925	-48.75%	4313	86.26%	0.8018
80% -90% P _{SMAX}	4423	88.45%	-2927	-48.78%	4862	97.23%	0.8341
90% -100% P _{SMAX}	4919	98.37%	-2922	-48.70%	5407	108.13%	0.8596

TABLE: Reactive power production with set point Q =+Q_{max} (>11.08 kW) or cos φ = +0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-4920	-98.39%	2921	48.68%	-4474	-89.48%	-0.8602
80% -90% P _{CMAX}	-4412	-88.23%	2921	48.68%	-4012	-80.24%	-0.8343
70% -80% P _{CMAX}	-3910	-78.19%	2933	48.88%	-3555	-71.10%	-0.8017
60% -70% P _{CMAX}	-3407	-68.15%	2920	48.66%	-3098	-61.96%	-0.7599
50% -60% P _{CMAX}	-2911	-58.23%	2931	48.85%	-2647	-52.94%	-0.7068
40% -50% P _{CMAX}	-2410	-48.20%	2934	48.90%	-2190	-43.81%	-0.6374
30% -40% P _{CMAX}	-1908	-38.17%	2912	48.53%	-1734	-34.68%	-0.5482
20% -30% P _{CMAX}	-1407	-28.15%	2928	48.80%	-1278	-25.56%	-0.4354
10% -20% P _{CMAX}	-907	-18.14%	2923	48.72%	-822	-16.45%	-0.2979
0% -10% P _{CMAX}	-407	-8.14%	2930	48.83%	-368	-7.35%	-0.1395
0% -10% P _{SMAX}	421	8.43%	2922	48.71%	464	9.28%	0.1411
10% -20% P _{SMAX}	919	18.38%	2923	48.72%	1010	20.21%	0.2986
20% -30% P _{SMAX}	1426	28.53%	2927	48.79%	1569	31.37%	0.4376
30% -40% P _{SMAX}	1922	38.43%	2931	48.86%	2113	42.25%	0.5486
40% -50% P _{SMAX}	2421	48.42%	2927	48.79%	2662	53.23%	0.6374
50% -60% P _{SMAX}	2930	58.61%	2932	48.87%	3221	64.42%	0.7076
60% -70% P _{SMAX}	3427	68.53%	2936	48.94%	3766	75.33%	0.7605
70% -80% P _{SMAX}	3926	78.53%	2935	48.92%	4316	86.31%	0.8020
80% -90% P _{SMAX}	4430	88.59%	2922	48.71%	4869	97.37%	0.8345
90% -100% P _{SMAX}	4925	98.49%	2922	48.70%	5413	108.26%	0.8599

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	

Model	AF1K-SL-1+1Battery						
-------	--------------------	--	--	--	--	--	--

TABLE: Reactive power production with set point Q = 0

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-959	-95.85%	30	3.00%	-858	-85.80%	-0.9996
80% -90% P _{CMAX}	-892	-89.25%	30	2.98%	-799	-79.85%	-0.9995
70% -80% P _{CMAX}	-796	-79.55%	30	2.96%	-711	-71.13%	-0.9994
60% -70% P _{CMAX}	-692	-69.22%	38	3.80%	-618	-61.81%	-0.9988
50% -60% P _{CMAX}	-590	-59.03%	37	3.68%	-527	-52.66%	-0.9984
40% -50% P _{CMAX}	-495	-49.52%	37	3.66%	-441	-44.08%	-0.9978
30% -40% P _{CMAX}	-393	-39.27%	39	3.89%	-349	-34.86%	-0.9960
20% -30% P _{CMAX}	-291	-29.09%	37	3.69%	-257	-25.71%	-0.9936
10% -20% P _{CMAX}	-193	-19.26%	37	3.75%	-169	-16.86%	-0.9852
0% -10% P _{CMAX}	-91	-9.13%	36	3.59%	-77	-7.74%	-0.9453
0% -10% P _{SMAX}	101	10.07%	26	2.62%	113	11.26%	0.9668
10% -20% P _{SMAX}	192	19.19%	27	2.66%	214	21.39%	0.9905
20% -30% P _{SMAX}	300	29.98%	27	2.65%	334	33.38%	0.9961
30% -40% P _{SMAX}	396	39.58%	27	2.69%	440	44.03%	0.9977
40% -50% P _{SMAX}	489	48.90%	27	2.71%	544	54.41%	0.9985
50% -60% P _{SMAX}	599	59.92%	27	2.71%	666	66.63%	0.9990
60% -70% P _{SMAX}	696	69.59%	26	2.65%	774	77.38%	0.9993
70% -80% P _{SMAX}	779	77.92%	27	2.71%	866	86.64%	0.9994
80% -90% P _{SMAX}	900	90.01%	29	2.93%	1001	100.06%	0.9995
90% -100% P _{SMAX}	1004	100.35%	30	2.97%	1116	111.57%	0.9996

TABLE: Reactive power production with set point Q = -Q_{max} (>11.08 kW) or cos φ = -0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-927	-92.69%	-515	-51.48%	-834	-83.41%	-0.8743
80% -90% P _{CMAX}	-876	-87.62%	-490	-49.01%	-789	-78.86%	-0.8711
70% -80% P _{CMAX}	-779	-77.86%	-489	-48.90%	-701	-70.07%	-0.8454
60% -70% P _{CMAX}	-671	-67.10%	-488	-48.79%	-604	-60.37%	-0.8076
50% -60% P _{CMAX}	-580	-57.96%	-487	-48.68%	-521	-52.15%	-0.7650
40% -50% P _{CMAX}	-474	-47.36%	-486	-48.59%	-426	-42.61%	-0.6982
30% -40% P _{CMAX}	-369	-36.89%	-485	-48.49%	-332	-33.19%	-0.6072
20% -30% P _{CMAX}	-282	-28.16%	-484	-48.40%	-253	-25.33%	-0.5065

CEI 0-21							
Clause	Requirement - Test			Result - Remark		Verdict	
10% -20% P _{CMAX}	-187	-18.75%	-483	-48.30%	-169	-16.86%	-0.3698
0% -10% P _{CMAX}	-75	-7.48%	-482	-48.21%	-67	-6.72%	-0.1637
0% -10% P _{SMAX}	83	8.32%	-482	-48.19%	93	9.28%	0.1571
10% -20% P _{SMAX}	187	18.68%	-483	-48.28%	208	20.79%	0.3475
20% -30% P _{SMAX}	297	29.65%	-483	-48.30%	330	33.01%	0.5111
30% -40% P _{SMAX}	384	38.42%	-484	-48.40%	427	42.72%	0.6109
40% -50% P _{SMAX}	484	48.39%	-485	-48.50%	538	53.80%	0.6971
50% -60% P _{SMAX}	585	58.49%	-486	-48.59%	650	65.03%	0.7616
60% -70% P _{SMAX}	686	68.58%	-487	-48.72%	763	76.25%	0.8089
70% -80% P _{SMAX}	783	78.32%	-488	-48.79%	871	87.07%	0.8432
80% -90% P _{SMAX}	893	89.27%	-488	-48.78%	992	99.23%	0.8728
90% -100% P _{SMAX}	936	93.63%	-518	-51.76%	1041	104.07%	0.8723

TABLE: Reactive power production with set point Q =+Q_{max} (>11.08 kW) or cos φ = +0.9 (≤ 11.08 kW)

Power-Bin	Active Power		Reactive Power		DC Power		Power Factor
	W	p.u.	VAr	p.u.	W	p.u.	Cos φ
90% -100% P _{CMAX}	-938	-93.83%	532	53.19%	-842	-84.16%	-0.8733
80% -90% P _{CMAX}	-878	-87.83%	498	49.83%	-788	-78.76%	-0.8715
70% -80% P _{CMAX}	-781	-78.08%	497	49.74%	-700	-69.98%	-0.8457
60% -70% P _{CMAX}	-680	-67.96%	496	49.65%	-609	-60.88%	-0.8107
50% -60% P _{CMAX}	-577	-57.71%	496	49.56%	-517	-51.65%	-0.7627
40% -50% P _{CMAX}	-480	-48.02%	495	49.54%	-429	-42.94%	-0.7011
30% -40% P _{CMAX}	-386	-38.59%	495	49.46%	-344	-34.44%	-0.6215
20% -30% P _{CMAX}	-287	-28.65%	493	49.34%	-255	-25.51%	-0.5097
10% -20% P _{CMAX}	-184	-18.42%	493	49.26%	-163	-16.30%	-0.3586
0% -10% P _{CMAX}	-75	-7.52%	492	49.17%	-65	-6.49%	-0.1595
0% -10% P _{SMAX}	86	8.56%	487	48.65%	95	9.46%	0.1650
10% -20% P _{SMAX}	192	19.20%	487	48.73%	213	21.29%	0.3593
20% -30% P _{SMAX}	289	28.85%	488	48.76%	320	32.01%	0.5032
30% -40% P _{SMAX}	395	39.46%	488	48.75%	438	43.79%	0.6242
40% -50% P _{SMAX}	492	49.19%	488	48.84%	546	54.61%	0.7057
50% -60% P _{SMAX}	596	59.56%	489	48.95%	661	66.14%	0.7693
60% -70% P _{SMAX}	684	68.41%	490	49.04%	760	75.97%	0.8101
70% -80% P _{SMAX}	791	79.11%	491	49.15%	878	87.84%	0.8471
80% -90% P _{SMAX}	877	87.72%	491	49.15%	974	97.42%	0.8703
90% -100% P _{SMAX}	949	94.88%	521	52.11%	1054	105.39%	0.8762

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.6.3 Bbis.6.4	TABLE: Reactive power production according to an assigned level (Required for inverter used in plant > 11.08 kW)			P
Model	AF6K-SLP+15Battery			
Power meter measurement data:	Sample-Rate:		0.2 s	
	Samples time:		3 min for each power point	
P _n in %	Q _{min/cosφ min} (180s)		Q=0/ cosφ=0 (180s)	Q _{max/cosφ max} (180s)
file: 50% P _{sMAX}				
50% P _n	Reactive power Set point Q/S _n [%]	Reactive power measured Q/S _n [%]	Deviation from set point ΔQ/S _n [%]	Limit [%]
-Q _{min} (=40%S _n)	-40.00%	-40.36%	-0.36%	ΔQ ≤ ±5% S _n
0	0.00%	-1.34%	-1.34%	ΔQ ≤ ±5% S _n
+Q _{max} (=40%S _n)	40.00%	40.41%	0.41%	ΔQ ≤ ±5% S _n
<p>The graph plots Power [W] & Q [var] against Time [s]. The active power (P) starts at ~3000 W and remains constant until 360s, then drops to ~2200 W. The reactive power (Q) starts at ~-2500 var and remains constant until 180s, then drops to 0 var.</p>				

Test procedure:

- c) The test must be performed according to the following steps:
 - bring the generator to 50% of the maximum active power available in discharge;
 - send to the generator an inductive reactive power set-point equal to 40% of the rated power of the converter (S_n);
 - maintain the set-point for a time of 60 s, compatibly with the energy capacity of the storage system;
 - measure the reactive power delivered by the inverter, at least 30 seconds after the command of the new reactive power regulation set-point is sent (this is to ensure that the system has reached the steady state).

The test is considered successfully passed if the maximum deviation between the assigned level and the current measured value (average value with 1 min window) for the reactive power is equal to:

- ΔQ ≤ ±5 % the nominal apparent power of the converter (direct setting of the reactive power level);
- Δcos φ ≤ ±0,01 (setting via power factor).

- d) In the case of storage systems connected to bidirectional converters, the test must also be repeated in the condition of withdrawal of energy from the grid.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.6.3	TABLE: reactive power production according to an assigned level (Required for inverter used in plant > 11.08 kW)			P
Model	AF6K-SLP+15Battery			
Power meter measurement data:		Sample-Rate:	0.2 s	
		Samples time:	3 min for each power point	
P (%)		Qmin/cosφ min (180s)	Q=0/ cosφ=0 (180s)	Qmax/cosφ max (180s)
file: 50% P_{CMAX}				
50% Pn	Reactive power Set point Q/S _n [%]	Reactive power measured Q/S _n [%]	Deviation from set point ΔQ/S _n [%]	Limit [%]
-Q _{min} (=40%S _n)	-40.00%	-40.15%	-0.15%	ΔQ ≤ ±5% S _n
0	0.00%	-2.57%	-2.57%	ΔQ ≤ ±5% S _n
+Q _{max} (=40%S _n)	40.00%	40.39%	0.39%	ΔQ ≤ ±5% S _n

Test procedure:

c) The test must be performed according to the following steps:

- bring the generator to 50% of the maximum active power available in discharge;
- send to the generator an inductive reactive power set-point equal to 40% of the rated power of the converter (S_n);
- maintain the set-point for a time of 60 s, compatibly with the energy capacity of the storage system;
- measure the reactive power delivered by the inverter, at least 30 seconds after the command of the new reactive power regulation set-point is sent (this is to ensure that the system has reached the steady state).

The test is considered successfully passed if the maximum deviation between the assigned level and the current measured value (average value with 1 min window) for the reactive power is equal to:

- ΔQ ≤ ±5 % the nominal apparent power of the converter (direct setting of the reactive power level);
- Δcos φ ≤ ±0,01 (setting via power factor).

d) In the case of storage systems connected to bidirectional converters, the test must also be repeated in the condition of withdrawal of energy from the grid.

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.6.5	TABLE: Response time to a step change of the assigned level (Required for inverter used in plant > 11.08 kW)		P
Model	AF6K-SLP+15Battery		
Power meter measurement data:	Sample-Rate: Samples time:	0,2 s at least 2 minutes for each power point	

Test:

- From the results of the capability tests referred to in Paragraphs Bbis.6.1 and Bbis.6.2, the $Q_{\max}|_{cap}$ and $Q_{\max}|_{ind}$ values of the maximum capacitive and inductive reactive power that can be supplied by the converter at 50% and 100% of the active discharge power maximum ($P_{S\text{MAX}}$; for integrated storage systems, equal to $P_{N\text{INV}}$) and maximum charge, $P_{C\text{MAX}}$ (for storage systems connected to bidirectional converters).
- The values measured as averages at 0.2 s of the reactive power during the execution of reactive power regulation commands with step variations, when the storage system respectively delivers a power, should be reported in a graph similar to the exemplary one in Figure 65. active equal to 50% (Test 1) and 100% of the maximum active discharge / charge power (Test 2).
- Note the response time (Tr = settling time in the graph in Figure 65), which is equivalent to the time interval that elapses from the instant of application of the new set-point to the instant in which the reactive power reaches an overall value within an interval included within a band of $\pm 5\% * Sn$ of the new assigned value.
- As shown in Figure 65, the response time must be detected in correspondence with a variation of the set-point from zero to $Q_{\max}|_{ind}$ (step 1), from $Q_{\max}|_{ind}$ to $Q_{\max}|_{cap}$ (step 2) and from $Q_{\max}|_{cap}$ to zero (step 3).

The response time values must be documented in the test report, which must also indicate the values of $Q_{\max}|_{cap}$, $Q_{\max}|_{ind}$, of the active power delivered / absorbed during the test and the method used to send the set control command point of reactive power.

The test is passed if the maximum response time detected is less than 10 s under all measurement conditions.




Figure 65 - Measurement of the response time to step changes of the set-point assigned for the reactive power

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Test 1 (see Graph 1): 100%P_{SMAX}																					
Point	Output power [W]	transient	Vac [V]	Q [VAr]	Tr [s]	Limit [s]															
1	5319	0 → Q _{max ind}	230.43	-2899	1.8	10															
2	5326	Q _{max ind} → Q _{max cap}	230.77	2888	2.0	10															
3	5943	Q _{max cap} → 0	230.61	-69	1.8	10															
Test 2 (see Graph 2): 50%P_{SMAX}																					
Point	Output power [W]	transient	Vac [V]	Q [VAr]	Tr [s]	Limit [s]															
1	2926	0 → Q _{max ind}	229.93	-2895	1.6	10															
2	2969	Q _{max ind} → Q _{max cap}	230.23	2893	1.8	10															
3	2979	Q _{max cap} → 0	230.09	-76	1.8	10															
Graph 1 of the reaction time after a step variation of the assigned level (100%-Test 1)																					
<table border="1"> <caption>Data for Graph 1 (100%-Test 1)</caption> <thead> <tr> <th>Time [s]</th> <th>P [W]</th> <th>Q [VAr]</th> </tr> </thead> <tbody> <tr><td>0</td><td>6000</td><td>0</td></tr> <tr><td>120</td><td>5500</td><td>-3500</td></tr> <tr><td>375</td><td>6000</td><td>0</td></tr> <tr><td>540</td><td>6000</td><td>0</td></tr> </tbody> </table>							Time [s]	P [W]	Q [VAr]	0	6000	0	120	5500	-3500	375	6000	0	540	6000	0
Time [s]	P [W]	Q [VAr]																			
0	6000	0																			
120	5500	-3500																			
375	6000	0																			
540	6000	0																			
Graph 2 of the reaction time after a step variation of the assigned level (50%-Test 2)																					
<table border="1"> <caption>Data for Graph 2 (50%-Test 2)</caption> <thead> <tr> <th>Time [s]</th> <th>P [W]</th> <th>Q [VAr]</th> </tr> </thead> <tbody> <tr><td>0</td><td>3000</td><td>0</td></tr> <tr><td>270</td><td>2700</td><td>-3500</td></tr> <tr><td>420</td><td>3000</td><td>0</td></tr> <tr><td>540</td><td>3000</td><td>0</td></tr> </tbody> </table>							Time [s]	P [W]	Q [VAr]	0	3000	0	270	2700	-3500	420	3000	0	540	3000	0
Time [s]	P [W]	Q [VAr]																			
0	3000	0																			
270	2700	-3500																			
420	3000	0																			
540	3000	0																			

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1 (see Graph 1): 100%P _{CMAX}						
Point	Output power [W]	transient	Vac [V]	Q [VAr]	Tr [s]	Limit [s]
1	-5165	0 → Q _{max ind}	228.05	-2895	1.8	10
2	-5161	Q _{max ind} → Q _{max cap}	228.32	2887	2.0	10
3	-6033	Q _{max cap} → 0	227.99	-179	1.8	10

Test 2 (see Graph 2): 50%P _{Cmax}						
Point	Output power [W]	transient	Vac [V]	Q [VAr]	Tr [s]	Limit [s]
1	-2991	0 → Q _{max ind}	228.52	-2890	1.8	10
2	-3038	Q _{max ind} → Q _{max cap}	228.84	2911	2.2	10
3	-3013	Q _{max cap} → 0	228.66	-151	2.0	10

Graph 1 of the reaction time after a step variation of the assigned level (100%-Test 1)**Graph 2 of the reaction time after a step variation of the assigned level (50%-Test 2)**

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.6.6 Bbis.6.7	TABLE: Automatic production of reactive power according to a characteristic curve $\cos\varphi = f(P)$	P
Max. $\cos\varphi$ declared.....	$\cos\varphi: 0.9$	
Set value.....	Lock-in: 1.05 Vn (Vn and 1.1 Vn with steps of 0.01) Lock-out: 0.98 Vn (0.9 Vn and Vn with steps of 0.01)	
<p>Figure 66 - Standard characteristic curve $\cos\varphi = f(P)$</p>	<p>(*) $\cos\varphi_{max}$ dipende dalla potenza complessiva installata (0.95 fino a 6 kW, 0.90 oltre 6 kW)</p>	
A: $P = 20\% * P_{SMAX}$; $\cos \varphi = 1$		
B: $P = 50\% * P_{SMAX}$; $\cos \varphi = 1$		
C: $P = P_{SMAX}$; $\cos \varphi = \cos \varphi_{min}$ where $\cos \varphi_{min}$ is equal to 0.90 (inductive).		
The automatic adjustment mode is disabled when:		
– the active power P delivered falls below 50% of P_{SMAX} (point B), or P_{NINV} for integrated storage systems, defined as power lock-out, independent of the voltage at the terminals, or		
– the voltage read at the output terminals of the converter falls below the lock-out limit, to be set at a default value equal to Vn , but which must be adjustable in the interval between $0.9 * Vn$ and Vn with intervals of $0.01 * Vn$.		
Supplementary information:		
– Function must be enabled by a local command of the converter.		
– Each value must be reached in < 10s.		


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Model: AF6K-SLP+15Battery								
P/P _{SMAX} [%]	P[W]	Vout[V]	Q[Var]	Cosφ Setpoint	Cosφ measured	ΔCosφ	Limit Δcosφ_max	Result
20	1194	239.46	156	1.00	0.992	-0.008	≤ ± 0.01	P
30	1798	239.48	214	1.00	0.993	-0.007	≤ ± 0.01	P
40	2401	239.47	284	1.00	0.993	-0.007	≤ ± 0.01	P
50	2998	239.45	290	1.00	0.995	-0.005	≤ ± 0.01	P
60	3593	239.47	302	1.00	0.997	-0.003	≤ ± 0.01	P
60	3599	244.08	755	0.98	0.977	-0.003	≤ ± 0.01	P
70	4198	244.07	1322	0.96	0.954	-0.006	≤ ± 0.01	P
80	4796	244.11	1748	0.94	0.940	0.000	≤ ± 0.01	P
90	5396	244.10	2356	0.92	0.917	-0.003	≤ ± 0.01	P
100*	6003	244.09	2920	0.90	0.899	-0.001	≤ ± 0.01	P
100*	6038	234.51	2907	0.90	0.901	0.001	≤ ± 0.01	P
100	6032	226.44	385	1.00	0.998	-0.002	≤ ± 0.01	P

Due to conversion efficiency, it is not possible to achieve 100% P_{SMAX}

Graph reactive power production according to a characteristic curve cos(phi) = f(P)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Model:	AF6K-SLP+1Battery							
P/P _{SMAX} [%]	P[W]	Vout[V]	Q[Var]	Cos Setpoint	Cosφ measured	ΔCosφ	Limit Δcosφ_max	Result
20	996	239.20	130	1.00	0.992	-0.008	≤ ± 0.01	P
30	1498	239.18	180	1.00	0.993	-0.007	≤ ± 0.01	P
40	2001	239.19	237	1.00	0.993	-0.007	≤ ± 0.01	P
50	2499	239.18	245	1.00	0.995	-0.005	≤ ± 0.01	P
60	2994	239.19	254	1.00	0.996	-0.004	≤ ± 0.01	P
60	3001	244.13	699	0.98	0.974	-0.006	≤ ± 0.01	P
70	3499	244.13	1103	0.96	0.954	-0.006	≤ ± 0.01	P
80	3997	244.14	1459	0.94	0.939	-0.001	≤ ± 0.01	P
90	4497	244.13	1965	0.92	0.916	-0.004	≤ ± 0.01	P
100	5003	244.13	2435	0.90	0.899	-0.001	≤ ± 0.01	P
100	5032	234.54	2424	0.90	0.901	0.001	≤ ± 0.01	P
100	5027	224.56	340	1.00	0.997	-0.003	≤ ± 0.01	P

Graph reactive power production according to a characteristic curve cos(phi) = f(P)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Model:	AF1K-SL-1+1Battery							
P/P _{SMAX} [%]	P[W]	Vout[V]	Q[Var]	Cos φSetpoint	Cos φmeasured	ΔCosφ	Limit Δcosφ_max	Result
20	220	236.68	29	1.00	0.992	-0.008	≤ ± 0.01	P
30	324	236.77	40	1.00	0.993	-0.007	≤ ± 0.01	P
40	427	236.84	54	1.00	0.992	-0.008	≤ ± 0.01	P
50	526	236.92	50	1.00	0.996	-0.004	≤ ± 0.01	P
60	629	237.09	55	1.00	0.997	-0.003	≤ ± 0.01	P
60	630	244.09	146	0.98	0.975	-0.005	≤ ± 0.01	P
70	716	244.21	228	0.96	0.953	-0.007	≤ ± 0.01	P
80	811	244.31	305	0.94	0.936	-0.004	≤ ± 0.01	P
90	915	244.40	407	0.92	0.914	-0.006	≤ ± 0.01	P
100	923	244.40	453	0.90	0.898	-0.002	≤ ± 0.01	P
100	909	230.66	425	0.90	0.906	0.006	≤ ± 0.01	P
100	990	223.10	52	1.00	0.999	-0.001	≤ ± 0.01	P

Graph reactive power production according to a characteristic curve cos(phi) = f(P)



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.6.8 Bbis.6.9	TABLE: Automatic reactive power production according to a characteristic curve $Q = f(V)$ (Required for inverter used in plant $\geq 11.08 \text{ kW}$)	P
	 <p>Fig. a Fig. b</p>	

Figure 51 - Standard characteristic curves $Q = f (V)$




Figure 67 - Standard characteristic curve $Q = f (V)$

Q = f (V) standard curve default setting value: Lock-in--> 20% $P_{S\text{MAX}}$ (or $P_{N\text{INV}}$) and > 20% $P_{C\text{MAX}}$ for bidirectional EESS Lock-out --> $\leq 5\%$ $P_{S\text{MAX}}$ (or $P_{N\text{INV}}$) and $\leq 5\%$ $P_{C\text{MAX}}$ for bidirectional EESS $V1s = 1.08Vn; V2s = 1.1Vn;$ $V1i = 0.92Vn ; V2i = 0.9Vn;$ $k = 0.1$ delay's time of reactive power = 3 seconds
--

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Curve A.1 - Test for bidirectional EESS in DISCHARGE with $k = +0.1$						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	ReactivePower expected [Var]	ΔQ
<20%P _{SMAX}	1.07Vn	1071	246.04	302	k^*Q_{max}	$\leq 5\%S_n$
<20%P _{SMAX}	1.09Vn	1069	250.61	307	k^*Q_{max}	$\leq 5\%S_n$
30%P _{SMAX}	1.09Vn	1780	250.40	-1078	-0.4*Q _{max} (lock-in) within 10sec	$\leq 5\%S_n$
40%P _{SMAX}	1.09Vn	2384	250.40	-1082	-0.4*Q _{max}	$\leq 5\%S_n$
50%P _{SMAX}	1.09Vn	2987	250.51	-1109	-0.4*Q _{max}	$\leq 5\%S_n$
60%P _{SMAX}	1.09Vn	3585	250.52	-1101	-0.4*Q _{max}	$\leq 5\%S_n$
70%P _{SMAX}	1.09Vn	4179	250.52	-1086	-0.4*Q _{max}	$\leq 5\%S_n$
80%P _{SMAX}	1.09Vn	4771	250.54	-1082	-0.4*Q _{max}	$\leq 5\%S_n$
90%P _{SMAX}	1.09Vn	5365	250.66	-1106	-0.4*Q _{max}	$\leq 5\%S_n$
100%P _{SMAX}	1.09Vn	5926	250.65	-1108	-0.4*Q _{max}	$\leq 5\%S_n$
100%P _{SMAX}	1.1Vn	5436	252.87	-2582	-0.9*Q _{max}	$\leq 5\%S_n$
10%P _{SMAX}	1.1Vn	529	252.59	-2551	-0.9*Q _{max}	$\leq 5\%S_n$
$\leq 5\%P_{SMAX}$	1.1Vn	180	252.65	206	k^*Q_{max} (lock-out)	$\leq 5\%S_n$

Curve B.1 - Test for bidirectional EESS in DISCHARGE with $k = +0.1$						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{SMAX}	0.93Vn	1063	213.79	292	k^*Q_{max}	$\leq 5\%S_n$
<20%P _{SMAX}	0.91Vn	1061	209.20	285	k^*Q_{max}	$\leq 5\%S_n$
30%P _{SMAX}	0.91Vn	1777	208.85	1773	0.6*Q _{max} (lock-in)within 10sec	$\leq 5\%S_n$
40%P _{SMAX}	0.91Vn	2378	208.90	1805	0.6*Q _{max}	$\leq 5\%S_n$
50%P _{SMAX}	0.91Vn	2976	208.92	1789	0.6*Q _{max}	$\leq 5\%S_n$
60%P _{SMAX}	0.91Vn	3565	208.95	1786	0.6*Q _{max}	$\leq 5\%S_n$
70%P _{SMAX}	0.91Vn	4153	209.08	1768	0.6*Q _{max}	$\leq 5\%S_n$
80%P _{SMAX}	0.91Vn	4741	209.10	1764	0.6*Q _{max}	$\leq 5\%S_n$
90%P _{SMAX}	0.91Vn	5328	209.14	1775	0.6*Q _{max}	$\leq 5\%S_n$
100%P _{SMAX}	0.91Vn	5791	209.13	1783	0.6*Q _{max}	$\leq 5\%S_n$
100%P _{SMAX}	0.90Vn	5318	207.04	2902	Q _{max}	$\leq 5\%S_n$
10%P _{SMAX}	0.90Vn	538	206.94	2871	Q _{max}	$\leq 5\%S_n$
$\leq 5\%P_{SMAX}$	0.90Vn	173	206.88	365	k^*Q_{max} (lock-out)	$\leq 5\%S_n$

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Curve A.2 - Test for bidirectional EESS in DISCHARGE with <u>k = -0.1</u>						
Setting Power[%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{SMAX}	1.07Vn	1073	246.10	293	-k*Qmax	$\leq 5\%Sn$
<20%P _{SMAX}	1.09Vn	1073	250.68	288	-k*Qmax	$\leq 5\%Sn$
30%P _{SMAX}	1.09Vn	1771	250.61	-1697	-0.6*Qmax (lock-in)within 10sec	$\leq 5\%Sn$
40%P _{SMAX}	1.09Vn	2375	250.64	-1726	-0.6*Qmax	$\leq 5\%Sn$
50%P _{SMAX}	1.09Vn	2977	250.65	-1725	-0.6*Qmax	$\leq 5\%Sn$
60%P _{SMAX}	1.09Vn	3577	250.74	-1791	-0.6*Qmax	$\leq 5\%Sn$
70%P _{SMAX}	1.09Vn	4171	250.74	-1769	-0.6*Qmax	$\leq 5\%Sn$
80%P _{SMAX}	1.09Vn	4763	250.75	-1764	-0.6*Qmax	$\leq 5\%Sn$
90%P _{SMAX}	1.09Vn	5356	250.76	-1731	-0.6*Qmax	$\leq 5\%Sn$
100%P _{SMAX}	1.09Vn	5802	250.76	-1731	-0.6*Qmax	$\leq 5\%Sn$
100%P _{SMAX}	1.1Vn	5296	253.17	-2877	-Qmax	$\leq 5\%Sn$
10%P _{SMAX}	1.1Vn	517	253.01	-2911	-Qmax	$\leq 5\%Sn$
$\leq 5\%P_{SMAX}$	1.1Vn	184	253.08	-369	-k*Qmax (lock-out)	$\leq 5\%Sn$

Curve B.2 - Test for bidirectional EESS in DISCHARGE with <u>k = -0.1</u>						
Setting Power[%]	SettingVolatge [V]	OutputPower [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{SMAX}	0.93Vn	1060	213.68	286	-k*Qmax	$\leq 5\%Sn$
<20%P _{SMAX}	0.91Vn	1061	209.09	293	-k*Qmax	$\leq 5\%Sn$
30%P _{SMAX}	0.91Vn	1783	208.93	1181	0.4*Qmax (lock-in)within 10sec	$\leq 5\%Sn$
40%P _{SMAX}	0.91Vn	2382	208.96	1193	0.4*Qmax	$\leq 5\%Sn$
50%P _{SMAX}	0.91Vn	2978	208.98	1160	0.4*Qmax	$\leq 5\%Sn$
60%P _{SMAX}	0.91Vn	3571	209.01	1155	0.4*Qmax	$\leq 5\%Sn$
70%P _{SMAX}	0.91Vn	4159	209.14	1150	0.4*Qmax	$\leq 5\%Sn$
80%P _{SMAX}	0.91Vn	4748	209.17	1127	0.4*Qmax	$\leq 5\%Sn$
90%P _{SMAX}	0.91Vn	5330	209.19	1164	0.4*Qmax	$\leq 5\%Sn$
100%P _{SMAX}	0.91Vn	5924	209.20	1165	0.4*Qmax	$\leq 5\%Sn$
100%P _{SMAX}	0.90Vn	5364	206.92	2595	0.9*Qmax	$\leq 5\%Sn$
10%P _{SMAX}	0.90Vn	544	206.83	2572	0.9*Qmax	$\leq 5\%Sn$
$\leq 5\%P_{SMAX}$	0.90Vn	170	206.69	-196	-k*Qmax (lock-out)	$\leq 5\%Sn$

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Curve A.1 - Test for bidirectional EESS in CHARGE with <u>k = +0.1</u>						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	ReactivePower expected [Var]	ΔQ
<20%P _{C_{MAX}}	1.07Vn	-1077	246.22	100	k*Qmax	$\leq 5\%Sn$
<20%P _{C_{MAX}}	1.09Vn	-1078	250.80	96	k*Qmax	$\leq 5\%Sn$
30%P _{C_{MAX}}	1.09Vn	-1793	250.64	-1127	-0.4*Qmax (lock-in)within 10sec	$\leq 5\%Sn$
40%P _{C_{MAX}}	1.09Vn	-2396	250.60	-1168	-0.4*Qmax	$\leq 5\%Sn$
50%P _{C_{MAX}}	1.09Vn	-3000	250.60	-1172	-0.4*Qmax	$\leq 5\%Sn$
60%P _{C_{MAX}}	1.09Vn	-3604	250.68	-1197	-0.4*Qmax	$\leq 5\%Sn$
70%P _{C_{MAX}}	1.09Vn	-4206	250.67	-1201	-0.4*Qmax	$\leq 5\%Sn$
80%P _{C_{MAX}}	1.09Vn	-4814	250.72	-1205	-0.4*Qmax	$\leq 5\%Sn$
90%P _{C_{MAX}}	1.09Vn	-5421	250.64	-1128	-0.4*Qmax	$\leq 5\%Sn$
100%P _{C_{MAX}}	1.09Vn	-5865	250.75	-1178	-0.4*Qmax	$\leq 5\%Sn$
100%P _{C_{MAX}}	1.1Vn	-5288	253.09	-2645	-0.9*Qmax	$\leq 5\%Sn$
10%P _{C_{MAX}}	1.1Vn	-579	253.07	-2642	-0.9*Qmax	$\leq 5\%Sn$
$\leq 5\%P_{C_{MAX}}$	1.1Vn	-178	253.26	77	k*Qmax (lock-out)	$\leq 5\%Sn$

Curve B.1 - Test for bidirectional EESS in CHARGE with <u>k = +0.1</u>						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{C_{MAX}}	0.93Vn	-1074	213.93	137	k*Qmax	$\leq 5\%Sn$
<20%P _{C_{MAX}}	0.91Vn	-1073	209.42	142	k*Qmax	$\leq 5\%Sn$
30%P _{C_{MAX}}	0.91Vn	-1810	209.00	1695	0.6*Qmax(lock-in)within 10sec	$\leq 5\%Sn$
40%P _{C_{MAX}}	0.91Vn	-2414	208.96	1767	0.6*Qmax	$\leq 5\%Sn$
50%P _{C_{MAX}}	0.91Vn	-3018	208.93	1811	0.6*Qmax	$\leq 5\%Sn$
60%P _{C_{MAX}}	0.91Vn	-3622	208.79	1809	0.6*Qmax	$\leq 5\%Sn$
70%P _{C_{MAX}}	0.91Vn	-4224	208.86	1831	0.6*Qmax	$\leq 5\%Sn$
80%P _{C_{MAX}}	0.91Vn	-4830	208.91	1792	0.6*Qmax	$\leq 5\%Sn$
90%P _{C_{MAX}}	0.91Vn	-5435	208.97	1804	0.6*Qmax	$\leq 5\%Sn$
100%P _{C_{MAX}}	0.91Vn	-5758	209.01	1787	0.6*Qmax	$\leq 5\%Sn$
100%P _{C_{MAX}}	0.90Vn	-5373	206.96	2889	Qmax	$\leq 5\%Sn$
10%P _{C_{MAX}}	0.90Vn	-617	207.22	2940	Qmax	$\leq 5\%Sn$
$\leq 5\%P_{C_{MAX}}$	0.90Vn	-173	207.16	208	k*Qmax(lock-out)	$\leq 5\%Sn$

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict


Curve A.2 - Test for bidirectional EESS in CHARGE with <u>k = -0.1</u>						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{CMAX}	1.07Vn	-1085	246.15	103	-k*Qmax	$\leq 5\%Sn$
<20%P _{CMAX}	1.09Vn	-1086	250.73	99	-k*Qmax	$\leq 5\%Sn$
30%P _{CMAX}	1.09Vn	-1796	250.62	-1713	-0.9*Qmax (lock-in)within 10sec	$\leq 5\%Sn$
40%P _{CMAX}	1.09Vn	-2399	250.50	-1715	-0.6*Qmax	$\leq 5\%Sn$
50%P _{CMAX}	1.09Vn	-3003	250.50	-1710	-0.6*Qmax	$\leq 5\%Sn$
60%P _{CMAX}	1.09Vn	-3607	250.58	-1737	-0.6*Qmax	$\leq 5\%Sn$
70%P _{CMAX}	1.09Vn	-4210	250.57	-1730	-0.6*Qmax	$\leq 5\%Sn$
80%P _{CMAX}	1.09Vn	-4817	250.54	-1678	-0.6*Qmax	$\leq 5\%Sn$
90%P _{CMAX}	1.09Vn	-5423	250.68	-1750	-0.6*Qmax	$\leq 5\%Sn$
100%P _{CMAX}	1.09Vn	-5696	250.70	-1765	-0.6*Qmax	$\leq 5\%Sn$
100%P _{CMAX}	1.1Vn	-5148	253.01	-2896	-Qmax	$\leq 5\%Sn$
10%P _{CMAX}	1.1Vn	-585	253.08	-2922	-Qmax	$\leq 5\%Sn$
$\leq 5\%P_{C MAX}$	1.1Vn	-185	253.28	62	-k*Qmax (lock-out)	$\leq 5\%Sn$

Curve B.2 - Test for bidirectional EESS in CHARGE with <u>k = -0.1</u>						
Setting Power [%]	Setting Volatge [V]	Output Power [W]	Voltage [V]	Reactive Power [Var]	Reactive Power expected [Var]	ΔQ
<20%P _{CMAX}	0.93Vn	-1073	213.89	144	-k*Qmax	$\leq 5\%Sn$
<20%P _{CMAX}	0.91Vn	-1072	209.30	149	-k*Qmax	$\leq 5\%Sn$
30%P _{CMAX}	0.91Vn	-1803	209.02	1114	0.4*Qmax (lock-in)within 10sec	$\leq 5\%Sn$
40%P _{CMAX}	0.91Vn	-2407	209.10	1149	0.4*Qmax	$\leq 5\%Sn$
50%P _{CMAX}	0.91Vn	-3012	208.95	1196	0.4*Qmax	$\leq 5\%Sn$
60%P _{CMAX}	0.91Vn	-3615	208.91	1189	0.4*Qmax	$\leq 5\%Sn$
70%P _{CMAX}	0.91Vn	-4214	208.99	1161	0.4*Qmax	$\leq 5\%Sn$
80%P _{CMAX}	0.91Vn	-4823	209.06	1154	0.4*Qmax	$\leq 5\%Sn$
90%P _{CMAX}	0.91Vn	-5427	209.01	1211	0.4*Qmax	$\leq 5\%Sn$
100%P _{CMAX}	0.91Vn	-5802	209.05	1183	0.4*Qmax	$\leq 5\%Sn$
100%P _{CMAX}	0.90Vn	-5508	206.95	2603	0.9*Qmax	$\leq 5\%Sn$
10%P _{CMAX}	0.90Vn	-614	207.07	2626	0.9*Qmax	$\leq 5\%Sn$
$\leq 5\%P_{C MAX}$	0.90Vn	-172	207.01	210	-k*Qmax(lock-out)	$\leq 5\%Sn$

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.7.1	TABLE: Active power limitation for voltage values near to 110 % U_n					P						
Model	AF6K-SLP+15Battery											
$P_{SMAX} = 6000 \text{ W}$												
$P_{CMAX} = 6000 \text{ W}$												
Set point	Activation threshold U_1			Deactivation threshold U_2								
U/U_n	110%			112%								
P/P_n	100%			20%								
Step	Set voltage [V/Vn]	Voltage [V]	Measured power [W]	Measured power [%]	Limit	Result						
1	1,08	248.85	6005	100.08	100%	P						
2	1,12	257.65	-5726	-95.43	One-way: $P < 20\% P_{SMAX}$ Biaxially: $> 80\% P_{CMAX}$	P						
3	1,08	248.64	6038	100.63	100%	P						

Graph curve $P=f(V)$:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.7.1	TABLE: Active power limitation for voltage values near to 110 % U_n					P
Model	AF6K-SLP+1Battery					
$P_{SMAX} = 5000 \text{ W}$						
$P_{CMAX} = 5000 \text{ W}$						
Set point	Activation threshold U_1			Deactivation threshold U_2		
U/U_n	110%			112%		
P/P_n	100%			20%		
Step	Set voltage [V/Vn]	Voltage [V]	Measured power [W]	Measured power [%]	Limit	Result
1	1,08	248.83	4987	99.73	100%	P
2	1,12	257.64	-4756	-95.12	One-way: $P < 20\% P_{SMAX}$ Biaxially: $> 80\% P_{CMAX}$	P
3	1,08	248.63	5017	100.34	100%	P

Graph curve $P=f(V)$:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.7.1	TABLE: Active power limitation for voltage values near to 110 % U_n					P						
Model	AF1K-SL-1+1Battery											
$P_{SMAX} = 1000W$												
$P_{CMAX} = 1000W$												
Set point	Activation threshold U_1			Deactivation threshold U_2								
U/U_n	110%			112%								
P/P_n	100%			20%								
Step	Set voltage [V/Vn]	Voltage [V]	Measured power [W]	Measured power [%]	Limit	Result						
1	1,08	248.51	996	99.65	100%	P						
2	1,12	257.33	-868	-86.80	One-way: $P < 20\% P_{SMAX}$ Biaxially: $> 80\% P_{CMAX}$	P						
3	1,08	248.31	1012	101.20	100%	P						

Graph curve $P=f(V)$:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------




Bbis.7.2	TABLE: Verification of automatic reduction of active power in the presence of overfrequency transients on the network		
Model	AF6K-SLP+15Battery		
Activation settings.....	Settable delay from 0s to 1s with step of 50ms (default value: no intentional delay)		
Figure 68 - Active power limitation curves for bidirectional converters			Figure 69 - Active power limitation curves for unidirectional converters
Supplementary information:			
<ul style="list-style-type: none"> - bring all the parameters of the storage system under test to their respective normal operating values, such that the AC power delivered at the output is equal to the maximum AC power that can be delivered for sequence A, i.e. respectively at 50% and 0% in the case of the sequences B and C; energy equal to 80% of the useful capacity, CUS, must be stored in the storage system; - perform the measurements on 7 points (the frequency value must have an uncertainty of maximum ± 10 mHz) temporally consequent to each other: <ol style="list-style-type: none"> 1. $f = 47,51$ Hz (t_1 for sequence A, t'_1 for sequence B, t''_1 for sequence C); 2. $f = 50$ Hz + 0,15 Hz (t_2 for sequence A, t'_2 for sequence B, t''_2 for sequence C); 3. $f = 50$ Hz + 0,40 Hz (t_3 for sequence A, t'_3 for sequence B, t''_3 for sequence C); 4. $f = 50$ Hz + 0,60 Hz (t_4 for sequence A, t'_4 for sequence B, t''_4 for sequence C); 5. $f = 50$ Hz + 1,49 Hz (t_5 for sequence A, t'_5 for sequence B, t''_5 for sequence C); 6. $f = 50$ Hz + 0,11 Hz (t_6 for sequence A, t'_6 for sequence B, t''_6 for sequence C); 7. $f = 50$ Hz (t_7 for sequence A, t'_7 for sequence B, t''_7 for sequence C). The frequency is reported to the nominal value for the verification of the conditions of gradual restoration of the maximum supply (sequence A), that is to say at 50% or 0% of the maximum available power (respectively, sequence B and C). 			
* The sequence C is applicable only for bi-directional converters.			

CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model	AF6K-SLP+15Battery					
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100	47.51	6000	6017	± 2.5% Pn	t ₁
2	100	50.15	6000	6018	± 2.5% Pn	t ₂
3	100	50.40	4154	4095	± 2.5% Pn	t ₃
4	100	50.60	2308	2307	± 2.5% Pn	t ₄
5	100	51.49	-5908	-5801	± 2.5% Pn	t ₅
6	100	50.10	-5908	-5900	± 2.5% Pn	t ₆
7	100	50.00	6000	6037	Pn	t ₇
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	47.51	3000	2983	± 2.5% Pn	t' ₁
2	50	50.15	3000	2985	± 2.5% Pn	t' ₂
3	50	50.40	1615	1592	± 2.5% Pn	t' ₃
4	50	50.60	231	236	± 2.5% Pn	t' ₄
5	50	51.49	-5931	-5899	± 2.5% Pn	t' ₅
6	50	50.10	-5931	-5937	± 2.5% Pn	t' ₆
7	50	50.00	3000	3001	50% Pn	t' ₇
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	47.51	0	-28	± 2.5% Pn	t" ₁
2	0	50.15	0	-28	± 2.5% Pn	t" ₂
3	0	50.40	-923	-891	± 2.5% Pn	t" ₃
4	0	50.60	-1846	-1855	± 2.5% Pn	t" ₄
5	0	51.49	-5954	-5897	± 2.5% Pn	t" ₅
6	0	50.10	-5954	-5959	± 2.5% Pn	t" ₆
7	0	50.00	0	-38	0% Pn	t" ₇

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------






CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model	AF6K-SLP+1Battery					
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100	47.51	5000	5007	± 2.5% Pn	t ₁
2	100	50.15	5000	5008	± 2.5% Pn	t ₂
3	100	50.40	3462	3441	± 2.5% Pn	t ₃
4	100	50.60	1923	1934	± 2.5% Pn	t ₄
5	100	51.49	-4923	-4799	± 2.5% Pn	t ₅
6	100	50.10	-4923	-4934	± 2.5% Pn	t ₆
7	100	50.00	5000	5046	Pn	t ₇
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	47.51	2500	2495	± 2.5% Pn	t' ₁
2	50	50.15	2500	2494	± 2.5% Pn	t' ₂
3	50	50.40	1346	1332	± 2.5% Pn	t' ₃
4	50	50.60	192	172	± 2.5% Pn	t' ₄
5	50	51.49	-4942	-4825	± 2.5% Pn	t' ₅
6	50	50.10	-4942	-4949	± 2.5% Pn	t' ₆
7	50	50.00	2500	2506	50% Pn	t' ₇
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	47.51	0	-8	± 2.5% Pn	t" ₁
2	0	50.15	0	5	± 2.5% Pn	t" ₂
3	0	50.40	-769	-757	± 2.5% Pn	t" ₃
4	0	50.60	-1538	-1548	± 2.5% Pn	t" ₄
5	0	51.49	-4962	-4908	± 2.5% Pn	t" ₅
6	0	50.10	-4962	-4945	± 2.5% Pn	t" ₆
7	0	50.00	0	19	0% Pn	t" ₇

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------






CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model	AF1K-SL-1+1Battery					
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100	47.51	1000	1001	± 2.5% Pn	t ₁
2	100	50.15	1000	1000	± 2.5% Pn	t ₂
3	100	50.40	692	696	± 2.5% Pn	t ₃
4	100	50.60	385	388	± 2.5% Pn	t ₄
5	100	51.49	-985	-956	± 2.5% Pn	t ₅
6	100	50.10	-985	-978	± 2.5% Pn	t ₆
7	100	50.00	1000	1013	Pn	t ₇
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	47.51	500	497	± 2.5% Pn	t' ₁
2	50	50.15	500	496	± 2.5% Pn	t' ₂
3	50	50.40	269	271	± 2.5% Pn	t' ₃
4	50	50.60	38	36	± 2.5% Pn	t' ₄
5	50	51.49	-988	-966	± 2.5% Pn	t' ₅
6	50	50.10	-988	-980	± 2.5% Pn	t' ₆
7	50	50.00	500	509	50% Pn	t' ₇
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	47.51	0	9	± 2.5% Pn	t" ₁
2	0	50.15	0	14	± 2.5% Pn	t" ₂
3	0	50.40	-154	-136	± 2.5% Pn	t" ₃
4	0	50.60	-308	-291	± 2.5% Pn	t" ₄
5	0	51.49	-992	-965	± 2.5% Pn	t" ₅
6	0	50.10	-992	-974	± 2.5% Pn	t" ₆
7	0	50.00	0	28	0% Pn	t" ₇

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.7.3	TABLE: Verification of the automatic increase of active power in the presence of underfrequency transients on the network		
Activation settings.....	Settable delay from 0s to 1s with step of 50ms (default value: no intentional delay)		
<p>Figure 70 - Active power limitation curves</p> <p>Bbis.7.4 Verification of the regulation of the active power on an external command from the DSO</p> <p>Supplementary information:</p> <p>The function of power derating under over-frequency was disable for this test.</p> <ul style="list-style-type: none"> - bring all the parameters of the storage system under test to their respective normal operating values, such that the AC power delivered at the output is respectively equal, for sequences A and B, to 50% and 0% of P_{SMAX} (or P_{NINV} for integrated storage systems) and, for sequence C, 100% of the P_{CMAX}; energy equal to 20% of the useful capacity, CUS, must be stored in the storage system; - perform the measurements on 7 points (the frequency value must have an uncertainty of maximum ± 10 mHz) temporally consequent to each other: <ol style="list-style-type: none"> 1. $f = 51,49$ Hz (t_1 for sequence A, t'_1 for sequence B, t''_1 for sequence C); 2. $f = 50$ Hz - 0,15 Hz (t_2 for sequence A, t'_2 for sequence B, t''_2 for sequence C); 3. $f = 50$ Hz - 0,40 Hz (t_3 for sequence A, t'_3 for sequence B, t''_3 for sequence C); 4. $f = 50$ Hz - 0,60 Hz (t_4 for sequence A, t'_4 for sequence B, t''_4 for sequence C); 5. $f = 50$ Hz - 0,89 Hz (t_5 for sequence A, t'_5 for sequence B, t''_5 for sequence C); 6. $f = 50$ Hz - 0,11 Hz (t_6 for sequence A, t'_6 for sequence B, t''_6 for sequence C); 7. $f = 50$ Hz (t_7 for the sequence A, t'_7 for the sequence B, t''_7 for the sequence C). The frequency is reported at the nominal value for the verification of the gradual recovery conditions, for sequences A and B, respectively of 50% and 0% of the P_{SMAX} (or of P_{NINV} for integrated storage systems) and, for sequence C, 100% of the P_{CMAX}. 			


CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model		AF6K-SLP+15Battery				
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	51.49	3000	2991	± 2.5% Sn	t ₁
2	50	49.85	3000	2991	± 2.5% Sn	t ₂
3	50	49.60	3000	3001	± 2.5% Sn	t ₃
4	50	49.40	4200	4195	± 2.5% Sn	t ₄
5	50	49.10	6000	5982	± 2.5% Sn	t ₅
6	50	49.89	6000	5998	± 2.5% Sn	t ₆
7	50	50.00	3000	2974	± 2.5% Sn	t ₇
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	51.49	0	0	± 2.5% Sn	t' ₁
2	0	49.85	0	-10	± 2.5% Sn	t' ₂
3	0	49.60	0	18	± 2.5% Sn	t' ₃
4	0	49.40	2400	2431	± 2.5% Sn	t' ₄
5	0	49.10	6000	5979	± 2.5% Sn	t' ₅
6	0	49.89	6000	6011	± 2.5% Sn	t' ₆
7	0	50.00	0	-16	± 2.5% Sn	t' ₇
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100% P _{CMAX}	51.49	-6000	-6006	± 2.5% Sn	t" ₁
2	100% P _{CMAX}	49.85	-6000	-5999	± 2.5% Sn	t" ₂
3	100% P _{CMAX}	49.60	-2571	-2561	± 2.5% Sn	t" ₃
4	100% P _{CMAX}	49.40	857	864	± 2.5% Sn	t" ₄
5	100% P _{CMAX}	49.10	6000	5966	± 2.5% Sn	t" ₅
6	100% P _{CMAX}	49.89	6000	6010	± 2.5% Sn	t" ₆
7	100% P _{CMAX}	50.00	-6000	-6028	± 2.5% Sn	t" ₇


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence A



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence B



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence C




CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model		AF6K-SLP+1Battery				
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	51.49	2500	2499	± 2.5% Sn	t ₁
2	50	49.85	2500	2498	± 2.5% Sn	t ₂
3	50	49.60	2500	2507	± 2.5% Sn	t ₃
4	50	49.40	3500	3514	± 2.5% Sn	t ₄
5	50	49.10	5000	4996	± 2.5% Sn	t ₅
6	50	49.89	5000	5009	± 2.5% Sn	t ₆
7	50	50.00	2500	2485	± 2.5% Sn	t ₇
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	51.49	0	32	± 2.5% Sn	t' ₁
2	0	49.85	0	-15	± 2.5% Sn	t' ₂
3	0	49.60	0	2	± 2.5% Sn	t' ₃
4	0	49.40	2000	2017	± 2.5% Sn	t' ₄
5	0	49.10	5000	4990	± 2.5% Sn	t' ₅
6	0	49.89	5000	5006	± 2.5% Sn	t' ₆
7	0	50.00	0	-20	± 2.5% Sn	t' ₇
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100% P _{CMAX}	51.49	-5000	-4995	± 2.5% Sn	t" ₁
2	100% P _{CMAX}	49.85	-5000	-4991	± 2.5% Sn	t" ₂
3	100% P _{CMAX}	49.60	-2143	-2123	± 2.5% Sn	t" ₃
4	100% P _{CMAX}	49.40	714	733	± 2.5% Sn	t" ₄
5	100% P _{CMAX}	49.10	5000	4981	± 2.5% Sn	t" ₅
6	100% P _{CMAX}	49.89	5000	5017	± 2.5% Sn	t" ₆
7	100% P _{CMAX}	50.00	-5000	-5014	± 2.5% Sn	t" ₇


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence A



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence B



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence C




CEI 0-21						
Clause	Requirement - Test			Result - Remark		Verdict

Model	AF1K-SL-1+1Battery					
Sequence A						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	50	51.49	500	510	$\pm 2.5\% Sn$	t_1
2	50	49.85	500	510	$\pm 2.5\% Sn$	t_2
3	50	49.60	500	511	$\pm 2.5\% Sn$	t_3
4	50	49.40	700	706	$\pm 2.5\% Sn$	t_4
5	50	49.10	1000	1009	$\pm 2.5\% Sn$	t_5
6	50	49.89	1000	1011	$\pm 2.5\% Sn$	t_6
7	50	50.00	500	501	$\pm 2.5\% Sn$	t_7
Sequence B						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	0	51.49	0	19	$\pm 2.5\% Sn$	t'_1
2	0	49.85	0	13	$\pm 2.5\% Sn$	t'_2
3	0	49.60	0	17	$\pm 2.5\% Sn$	t'_3
4	0	49.40	400	401	$\pm 2.5\% Sn$	t'_4
5	0	49.10	1000	995	$\pm 2.5\% Sn$	t'_5
6	0	49.89	1000	1000	$\pm 2.5\% Sn$	t'_6
7	0	50.00	0	-13	$\pm 2.5\% Sn$	t'_7
Sequence C						
Step No.	Set output power [%]	Frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100% P_{CMAX}	51.49	-1000	-1000	$\pm 2.5\% Sn$	t''_1
2	100% P_{CMAX}	49.85	-1000	-999	$\pm 2.5\% Sn$	t''_2
3	100% P_{CMAX}	49.60	-429	-430	$\pm 2.5\% Sn$	t''_3
4	100% P_{CMAX}	49.40	143	137	$\pm 2.5\% Sn$	t''_4
5	100% P_{CMAX}	49.10	1000	985	$\pm 2.5\% Sn$	t''_5
6	100% P_{CMAX}	49.89	1000	992	$\pm 2.5\% Sn$	t''_6
7	100% P_{CMAX}	50.00	-1000	-1010	$\pm 2.5\% Sn$	t''_7


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence A



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence B



Graph Active power regulation in coincidence with transitory on the transmission grid
Sequence C



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.7.4	TABLE: Active power limitation in coincidence with external command coming from the Electricity Distributor				P
Model	AF6K-SLP+15Battery				
Set Point	P [W]	Actual power [W]	$\Delta P/Pn\%$	Limit [%]	Result
50% P_{SMAX}	3000	2988	-0.20	--	P
30% P_{SMAX}	1800	1785	-0.25	$\pm 2.5\% P_{SMAX}$	P
30% P_{CMAX}	-1800	-1775	0.42	$\pm 2.5\% P_{SMAX}$	P

The test must be performed according to the following steps:

- Bring the storage system to 50% of the active power available for injection.
- Send to the generator an active power set-point equal to 30% of the P_{SMAX} .
- Maintain the set-point for a time of 60 s, compatibly with the energy capacity of the storage system.
- Measure the active power delivered by the inverter, at least 30 seconds after the command of the new active power regulation set-point is sent (this is to ensure that the system has reached the steady state).

The test is considered to have been successfully passed if the maximum deviation between the assigned level and the current measured value (average value with a window of 1 min.) For the active power is less than $\pm 2.5\% P_{SMAX}$.

In the case of storage systems connected to bidirectional converters, repeat the test at 30% of the P_{CMAX} .

Diagram:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.7.4	TABLE: Active power limitation in coincidence with external command coming from the Electricity Distributor				P
Model	AF6K-SLP+1Battery				
Set Point	P [W]	Actual power [W]	$\Delta P/Pn\%$	Limit [%]	Result
50% P_{SMAX}	2500	2517	0.33	--	P
30% P_{SMAX}	1500	1514	0.28	$\pm 2.5\% P_{SMAX}$	P
30% P_{CMAX}	-1500	-1467	0.65	$\pm 2.5\% P_{SMAX}$	P

The test must be performed according to the following steps:

- Bring the storage system to 50% of the active power available for injection.
- Send to the generator an active power set-point equal to 30% of the P_{SMAX} .
- Maintain the set-point for a time of 60 s, compatibly with the energy capacity of the storage system.
- Measure the active power delivered by the inverter, at least 30 seconds after the command of the new active power regulation set-point is sent (this is to ensure that the system has reached the steady state).

The test is considered to have been successfully passed if the maximum deviation between the assigned level and the current measured value (average value with a window of 1 min.) For the active power is less than $\pm 2.5\% P_{SMAX}$.

In the case of storage systems connected to bidirectional converters, repeat the test at 30% of the P_{CMAX} .

Diagram:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------


Bbis.7.4	TABLE: Active power limitation in coincidence with external command coming from the Electricity Distributor				P
Model	AF1K-SL-1+1Battery				
Set Point	P [W]	Actual power [W]	$\Delta P/Pn\%$	Limit [%]	Result
50% P_{SMAX}	500	518	1.84	--	P
30% P_{SMAX}	300	312	1.15	$\pm 2.5\% P_{SMAX}$	P
30% P_{CMAX}	-300	-297	0.28	$\pm 2.5\% P_{SMAX}$	P

The test must be performed according to the following steps:

- Bring the storage system to 50% of the active power available for injection.
- Send to the generator an active power set-point equal to 30% of the P_{SMAX} .
- Maintain the set-point for a time of 60 s, compatibly with the energy capacity of the storage system.
- Measure the active power delivered by the inverter, at least 30 seconds after the command of the new active power regulation set-point is sent (this is to ensure that the system has reached the steady state).

The test is considered to have been successfully passed if the maximum deviation between the assigned level and the current measured value (average value with a window of 1 min.) For the active power is less than $\pm 2.5\% P_{SMAX}$.

In the case of storage systems connected to bidirectional converters, repeat the test at 30% of the P_{CMAX} .



Diagram:

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.7.4.1	TABLE: Verification of the settling time at a power increase / decrease command						P
Model	AF6K-SLP+15Battery						
Set Point	P [W]	Actual power [W]	Setting time (s)	ΔP/Pn (%)	Deviation Limit	Setting time	
Bidirectional converters							
100% P _{SMAX} 30% P _{CMAX}	-1800	-1815	12	-0.25	± 2.5 % Pn	≤ 50 s	
100% P _{CMAX} 50% P _{SMAX}	3000	2991	14	-0.14	± 2.5 % Pn	≤ 50 s	
Unidirectional converters							
100% P _{SMAX} 30% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
0% P _{SMAX} 50% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
<p>To check the settling time at a command to reduce the active power delivered, or increase the active power absorbed, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{SMAX} to 30% P_{CMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 100% P_{SMAX} to 30% P_{SMAX} at time t₀. <p>To check the settling time at a command to increase the active power, or reduce the absorbed active power, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{CMAX} to 50% P_{SMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 0%P_{SMAX} to 50%P_{SMAX} at time t₀. <p>The settling time is the time interval from the instant t₀ of application of the step of increasing / limiting the active power (e.g. 100%P_{SMAX} → 30%P_{SMAX}) to the instant in which the power is stably within a tolerance band of ± 2.5%S_n with respect to the new set value.</p> <p>The maximum measured settling time must be less than 50 s, and in any case not more than 60 s if the limitation command provides for the passage from 100%S_n to 15%S_n.</p>							

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Graph: 100% $P_{S\text{MAX}}$ to 30% $P_{C\text{MAX}}$:Graph: 100% $P_{C\text{MAX}}$ to 50% $P_{S\text{MAX}}$:

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.7.4.1	TABLE: Verification of the settling time at a power increase / decrease command						P
Model	AF6K-SLP+1Battery						
Set Point	P [W]	Actual power [W]	Setting time (s)	ΔP/Pn (%)	Deviation Limit	Setting time	
Bidirectional converters							
100% P _{SMAX} 30% P _{CMAX}	-1500	-1505	15	-0.10	± 2.5 % Pn	≤ 50 s	
100% P _{CMAX} 50% P _{SMAX}	2500	2517	14	0.34	± 2.5 % Pn	≤ 50 s	
Unidirectional converters							
100% P _{SMAX} 30% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
0% P _{SMAX} 50% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
<p>To check the settling time at a command to reduce the active power delivered, or increase the active power absorbed, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{SMAX} to 30% P_{CMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 100% P_{SMAX} to 30% P_{SMAX} at time t₀. <p>To check the settling time at a command to increase the active power, or reduce the absorbed active power, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{CMAX} to 50% P_{SMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 0%P_{SMAX} to 50%P_{SMAX} at time t₀. <p>The settling time is the time interval from the instant t₀ of application of the step of increasing / limiting the active power (e.g. 100%P_{SMAX} → 30%P_{SMAX}) to the instant in which the power is stably within a tolerance band of ± 2.5%S_n with respect to the new set value.</p> <p>The maximum measured settling time must be less than 50 s, and in any case not more than 60 s if the limitation command provides for the passage from 100%S_n to 15%S_n.</p>							

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



Graph: 100% $P_{S\text{MAX}}$ to 30% $P_{C\text{MAX}}$:Graph: 100% $P_{C\text{MAX}}$ to 50% $P_{S\text{MAX}}$:

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.7.4.1	TABLE: Verification of the settling time at a power increase / decrease command						P
Model	AF1K-SL-1+1Battery						
Set Point	P [W]	Actual power [W]	Setting time (s)	ΔP/Pn (%)	Deviation Limit	Setting time	
Bidirectional converters							
100% P _{SMAX} 30% P _{CMAX}	-300	-302	16	-0.15	± 2.5 % Pn	≤ 50 s	
100% P _{CMAX} 50% P _{SMAX}	500	499	14	-0.10	± 2.5 % Pn	≤ 50 s	
Unidirectional converters							
100% P _{SMAX} 30% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
0% P _{SMAX} 50% P _{SMAX}	--	--	--	--	± 2.5 % Pn	≤ 50 s	
<p>To check the settling time at a command to reduce the active power delivered, or increase the active power absorbed, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{SMAX} to 30% P_{CMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 100% P_{SMAX} to 30% P_{SMAX} at time t₀. <p>To check the settling time at a command to increase the active power, or reduce the absorbed active power, the test is carried out:</p> <ul style="list-style-type: none"> –for storage systems connected to bidirectional converters, by adjusting the regulation parameter from 100%P_{CMAX} to 50% P_{SMAX} at time t₀; –for storage systems connected to unidirectional converters, by adjusting the regulation parameter from 0%P_{SMAX} to 50%P_{SMAX} at time t₀. <p>The settling time is the time interval from the instant t₀ of application of the step of increasing / limiting the active power (e.g. 100%P_{SMAX} → 30%P_{SMAX}) to the instant in which the power is stably within a tolerance band of ± 2.5%S_n with respect to the new set value.</p> <p>The maximum measured settling time must be less than 50 s, and in any case not more than 60 s if the limitation command provides for the passage from 100%S_n to 15%S_n.</p>							

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Graph: 100% $P_{S\text{MAX}}$ to 30% $P_{C\text{MAX}}$:Graph: 100% $P_{C\text{MAX}}$ to 50% $P_{S\text{MAX}}$:

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Bbis.8.1			
	TABLE: Verification of continuous component emission		P
Model	AF6K-SLP+15Battery		
Completed test			
Power Level [%P_{SMAX}]	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	1977	3945	5955
Output Vrms	230.21	230.61	230.90
Output Arms	8.57	17.09	25.78
Cos φ	0.9991	0.9998	0.9999
L1 DC Component (A)	0.021	0.021	0.017
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.079%	0.081%	0.066%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Minimum ambient rating (-25°C) or -10°C			
Total output Power (W)	1975	3944	5952
Output Vrms	230.20	230.62	230.91
Output Arms	8.57	17.09	25.76
Cos φ	0.9991	0.9998	0.9999
L1 DC Component (A)	0.021	0.022	0.019
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I_r)	0.079%	0.084%	0.071%
L2 DC Component (% I_r)	-	-	-
L3 DC Component (% I_r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Ambient			
Total output Power (W)	-1987	-3979	-6016
Output Vrms			
Output Arms	229.40	228.98	228.54
Cos φ	8.70	17.41	26.35
L1 DC Component (A)	-0.9974	-0.9991	-0.9995
L2 DC Component (A)	0.018	0.019	0.016
L3 DC Component (A)	-	-	-
L1 DC Component (% I_r)	0.069%	0.072%	0.062%
L2 DC Component (% I_r)	-	-	-
L3 DC Component (% I_r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Minimum ambient rating (-25°C) or -10°C			
Total output Power (W)	-1987	-3979	-6012
Output Vrms	229.40	228.99	228.57
Output Arms	8.70	17.41	26.33
Cos φ	-0.9974	-0.9991	-0.9995
L1 DC Component (A)	0.019	0.020	0.016
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I_r)	0.074%	0.075%	0.061%
L2 DC Component (% I_r)	-	-	-
L3 DC Component (% I_r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Maximum ambient rating (+60°C) or +55°C			
Total output Power (W)	-1986	-3977	-6008
Output Vrms	229.39	228.98	228.56
Output Arms	8.69	17.40	26.31
Cos φ	-0.9974	-0.9991	-0.9995
L1 DC Component (A)	0.020	0.020	0.017
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I_r)	0.075%	0.077%	0.065%
L2 DC Component (% I_r)	-	-	-
L3 DC Component (% I_r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Bbis.8.1			P
Model AF6K-SLP+1Battery			
Completed test-			
Power Level [%P_{SMAX}]	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	1671	3318	5026
Output Vrms	229.70	230.03	230.27
Output Arms	7.27	14.41	21.82
Cos φ	0.9986	0.9997	0.9999
L1 DC Component (A)	0.019	0.019	0.018
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.071%	0.071%	0.069%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Power Level [%P _{C_{MAX}}]	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	-1655	-3316	-5013
Output Vrms	229.02	228.69	228.21
Output Arms	7.26	14.53	21.99
Cos φ	-0.9967	-0.9989	-0.9995
L1 DC Component (A)	0.013	0.015	0.013
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.049%	0.056%	0.048%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
Bbis.8.1			
	TABLE: Verification of continuous component emission		P
Model	AF1K-SL-1+1Battery		
Completed test			
Power Level [%P_{SMAX}]	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	330	665	994
Output Vrms	229.35	229.40	229.43
Output Arms	1.91	3.16	4.51
Cos φ	0.7465	0.9131	0.9568
L1 DC Component (A)	0.005	0.004	0.004
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.108%	0.093%	0.100%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Power Level [%P _{CMAX}]	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient			
Total output Power (W)	-325	-659	-988
Output Vrms	229.36	229.41	229.44
Output Arms	1.91	3.16	4.52
Cos φ	-0.7467	-0.9132	-0.9568
L1 DC Component (A)	0.005	0.005	0.004
L2 DC Component (A)	-	-	-
L3 DC Component (A)	-	-	-
L1 DC Component (% I _r)	0.105%	0.111%	0.096%
L2 DC Component (% I _r)	-	-	-
L3 DC Component (% I _r)	-	-	-

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.8.2	TABLE: Verification of protections against the continuous DC injection			P
Model	AF6K-SLP+15Battery			
Actual Power [%P _{SMAX}]	Limits	Measurement [mA]	Limiting value[mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	136.2	130.4	997
66%	+0,5%I _{nom} /1s	136.2	130.4	996
100%	+0,5%I _{nom} /1s	134.7	130.4	992
Minimum ambient rating (-25°C) or -10°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	135.4	130.4	993
66%	+0,5%I _{nom} /1s	135.3	130.4	998
100%	+0,5%I _{nom} /1s	136.1	130.4	998
Maximum ambient rating (+60°C) or +55°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	135.6	130.4	997
66%	+0,5%I _{nom} /1s	135.9	130.4	992
100%	+0,5%I _{nom} /1s	136.1	130.4	998
Ambient 25°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.016	1000	198.4
66%	+1A I _{dc} /200ms	1.023	1000	196.4
100%	+1A I _{dc} /200ms	1.023	1000	198.0
Minimum ambient rating (-25°C) or -10°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.021	1000	196.0
66%	+1A I _{dc} /200ms	1.029	1000	197.6
100%	+1A I _{dc} /200ms	1.024	1000	198.4
Maximum ambient rating (+60°C) or +55°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.018	1000	194.4
66%	+1A I _{dc} /200ms	1.023	1000	197.6
100%	+1A I _{dc} /200ms	1.023	1000	195.6
Actual Power [%P _{CMAX}]	Limits	Measurement [mA]	Limiting value [mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	133.4	130.4	996
66%	+0,5%I _{nom} /1s	133.2	130.4	994
100%	+0,5%I _{nom} /1s	134.3	130.4	997
Minimum ambient rating (-25°C) or -10°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	133.3	130.4	996
66%	+0,5%I _{nom} /1s	133.0	130.4	994

CEI 0-21				
Clause	Requirement - Test	Result - Remark		Verdict
100%	+0,5% I_{nom} /1s	133.6	130.4	995
Maximum ambient rating (+60°C) or +55°C, $I_{dc} = 0,5\%$ of I_{nom}				
33%	+0,5% I_{nom} /1s	133.1	130.4	996
66%	+0,5% I_{nom} /1s	132.8	130.4	994
100%	+0,5% I_{nom} /1s	133.0	130.4	997
Ambient 25°C, $I_{dc} = 1A$				
33%	+1A $I_{dc}/200ms$	1.022	1000	196.4
66%	+1A $I_{dc}/200ms$	1.030	1000	195.6
100%	+1A $I_{dc}/200ms$	1.035	1000	194.8
Minimum ambient rating (-25°C) or -10°C, $I_{dc} = 1A$				
33%	+1A $I_{dc}/200ms$	1.016	1000	196.8
66%	+1A $I_{dc}/200ms$	1.030	1000	196.8
100%	+1A $I_{dc}/200ms$	1.027	1000	194.0
Maximum ambient rating (+60°C) or +55°C, $I_{dc} = 1A$				
33%	+1A $I_{dc}/200ms$	1.017	1000	192.4
66%	+1A $I_{dc}/200ms$	1.028	1000	196.8
100%	+1A $I_{dc}/200ms$	1.035	1000	197.6
Note: The internal temperature of the EUT must be stabilized.				

CEI 0-21				
Clause	Requirement - Test	Result - Remark		Verdict

Bbis.8.2	TABLE: Verification of protections against the continuous DC injection			P
Model	AF6K-SLP+1Battery			
Actual Power [%P _{SMAX}]	Limits	Measurement [mA]	Limiting value[mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	135.4	130.4	996
66%	+0,5%I _{nom} /1s	136.8	130.4	998
100%	+0,5%I _{nom} /1s	135.2	130.4	996
Ambient 25°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.031	1000	197.6
66%	+1A I _{dc} /200ms	1.030	1000	196.8
100%	+1A I _{dc} /200ms	1.024	1000	196.8
Actual Power [%P _{CMAX}]	Limits	Measurement [mA]	Limiting value [mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	136.8	130.4	993
66%	+0,5%I _{nom} /1s	136.0	130.4	997
100%	+0,5%I _{nom} /1s	132.4	130.4	993
Ambient 25°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.029	1000	194.4
66%	+1A I _{dc} /200ms	1.036	1000	198.4
100%	+1A I _{dc} /200ms	1.034	1000	197.2
Note: The internal temperature of the EUT must be stabilized.				

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	

Bbis.8.2	TABLE: Verification of protections against the continuous DC injection			P
Model	AF1K-SL-1+1Battery			
Actual Power [%P _{SMAX}]	Limits	Measurement [mA]	Limiting value[mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	22.63	21.74	991
66%	+0,5%I _{nom} /1s	22.55	21.74	992
100%	+0,5%I _{nom} /1s	22.39	21.74	990
Ambient 25°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.049	1000	190.2
66%	+1A I _{dc} /200ms	1.051	1000	193.0
100%	+1A I _{dc} /200ms	1.055	1000	193.0
Actual Power [%P _{CMAX}]	Limits	Measurement [mA]	Limiting value [mA]	Disconnection time [ms]
Ambient 25°C, I_{dc} = 0,5% of I_{nom}				
33%	+0,5%I _{nom} /1s	22.28	21.74	994
66%	+0,5%I _{nom} /1s	21.98	21.74	993
100%	+0,5%I _{nom} /1s	22.17	21.74	991
Ambient 25°C, I_{dc} = 1A				
33%	+1A I _{dc} /200ms	1.038	1000	194.0
66%	+1A I _{dc} /200ms	1.070	1000	195.0
100%	+1A I _{dc} /200ms	1.043	1000	195.0
Note: The internal temperature of the EUT must be stabilized.				

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.9	TABLE: Verification of insensitivity to voltage dips (UVRT and OVRT(8.5. 1-figure 30) capability)	P
Model	AF6K-SL	
<p>These tests have the purpose of verifying that the storage system, when used in plants with a total power greater than 11.08 kW, is insensitive to voltage drops according to the voltage-time profile indicated in Figure 71, based on what is reported in 8.5.1.</p> <ul style="list-style-type: none"> in the hatched area of Figure 71 the storage system must not disconnect from the grid. In this area it is allowed to temporarily interrupt the supply / absorption of the active and reactive power exchanged with the grid before the onset of the fault; in the area below (grey) the generator can disconnect from the grid. within 400 ms from restoring network voltage to within the range of +10% and -15% of nominal voltage, the generator must return to supplying active and reactive power to the network as before the fault, with a maximum tolerance of $\pm 10\%$ of the nominal voltage of the generator. If voltage returns but remains in the range between 85% and 90%, power distribution may be reduced in relation to the generator limits of output power. <p>Verification of compliance with the requirements of immunity to voltage drop are carried out according to the test sequences shown in Table 38, to be carried out with the storage system running respectively:</p> <p>a)between 10% and 30% of P_{SMAX};</p> <p>b)and above 90% of P_{SMAX}.</p> <p>In general, regardless of the test circuit used, the result of each sequence should be documented as follows:</p> <p>-Time trend of active power P, reactive power Q, phase voltages at the output terminals (V_r, V_s and V_t) and related phase currents, as moving average rms values of a network cycle and updated every half cycle (10 ms), over a time window that runs from 100 ms before the start of the test and ends at least after 1 000 ms from the end of the voltage transient (in order to verify the restoration of active and reactive power). The voltage transient ends when the voltage returns to more than 85% of the rated voltage value. For phase currents, in addition to the rms value averaged over a period, the peak value for each phase must also be recorded and documented.</p> <p>-In the same period of observation, the oscillograms of the voltages and phase currents will have to be reported (possibly with enlarged detail of the trend during the rising and falling voltage fronts).</p> <p>-The calculation method used to determine the power, the power factor and the reactive current must also be described in the test report.</p> <p>It will therefore be necessary to carry out at least 12 distinct test sequences, corresponding to 2 residual voltage levels to be replicated in order to simulate the cases of symmetrical three-phase and two-phase asymmetric MV and LV faults. Each sequence must then be repeated with the storage system operating at two levels of initial power delivered (a: $10\% * P_{SMAX} - 30\% * P_{SMAX}$; b:$> 90\% * P_{SMAX}$).</p>		
<p>Figure 71 - Requirements for UVRT</p>		


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Bbis.9.2.2 Alternative test methods - network simulator:


With reference to the list of tests shown in **Table 39**, the voltage drops that are the subject of these tests are caused by faults produced on the low, medium or high voltage distribution line. The types of faults considered are three:

- 1) three-phase symmetrical fault (**Table 39**, Tests No. 1 and 2)



- 2) two-phase asymmetric fault (**Table 39**, Tests No. 3 and 4)

A fault in MV, which causes a variation in LV not only of amplitude but also of the phase relationship of the voltages (the case considered involves the presence of a transformer Dy in the secondary substation).




During the two-phase asymmetric fault, the residual amplitude of the 3 voltages and the phase shifts between the phases must comply with the values shown in the following table.

Table 40 - LV phase vectors in the presence of asymmetrical two-phase faults on the primary side of a transformer Dy in the secondary substation

Test No.	V/Vn	Phase-to-earth voltages			Phase angles		
		u ₁ /u _{1,n}	u ₂ /u _{2,n}	u ₃ /u _{3,n}	Φ _{u1}	Φ _{u2}	Φ _{u3}
1a	0,10 ± 0,05	0,87 ± 0,05	0,87 ± 0,05	0,10 ± 0,05	27°	-147°	120°
2a	0,25 ± 0,05	0,88 ± 0,05	0,88 ± 0,05	0,25 ± 0,05	22°	-142°	120°
3a	0,50 ± 0,05	0,90 ± 0,05	0,90 ± 0,05	0,50 ± 0,05	14°	-134°	120°
4a	0,75 ± 0,05	0,94 ± 0,05	0,94 ± 0,05	0,75 ± 0,05	7°	-127°	120°
normal conditions	1	1	1	1	0°	-120°	120°

- 3) LV two-phase asymmetric fault (**Table 39**, Tests No. 5 and 6)



CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Requirement of LVRT test:							
List of tests		Residual amplitude of phase-to-phase voltage V/V_{nom}	Drop duration limit [ms]	Power re-supply time after restoring network [ms]	Shape (*)		
1s – three-phase symmetrical fault		$0,10 \pm 0,05 (V_1/V_n)$	200 ± 20	400			
1a – two-phase asymmetric failure		$0,10 \pm 0,05 (V_1/V_n)$	200 ± 20	400			
2s – three-phase symmetrical fault		$0,25 \pm 0,05 (V_2/V_n)$	400 ± 20	400			
2a – two-phase asymmetric failure		$0,25 \pm 0,05 (V_2/V_n)$	400 ± 20	400			
3s – three-phase asymmetrical fault		$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	400			
3a – two-phase asymmetric failure		$0,50 \pm 0,05 (V_3/V_n)$	850 ± 20	400			
4s – three-phase asymmetrical fault		$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	400			
4a – two-phase asymmetric failure		$0,75 \pm 0,05 (V_4/V_n)$	1300 ± 20	400			
5 – LV two-phase asymmetrical fault		$0,10 \pm 0,05 (V_5/V_n)$	200 ± 20	400			
6 – LV two-phase asymmetrical fault		$0,50 \pm 0,05 (V_6/V_n)$	850 ± 20	400			
7 – three-phase symmetrical fault		$1,20 \pm 0,05 (V_7/V_n)$	500 ± 20	400			
8 – three-phase symmetrical fault		$1,25 \pm 0,05 (V_8/V_n)$	100 ± 20	400			
Test No.	V/V_{nom}	Phase-to-earth voltages			Phase angles		
		$U_1/U_{1,nom}$	$U_2/U_{2,nom}$	$U_3/U_{3,nom}$	Φ_{U1}	Φ_{U2}	
1s	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	$0,10 \pm 0,05$	0°	-120°	120°
1a	$0,10 \pm 0,05$	$0,87 \pm 0,05$	$0,87 \pm 0,05$	$0,10 \pm 0,05$	27°	-147°	120°
2s	$0,25 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	$0,25 \pm 0,05$	0°	-120°	120°
2a	$0,25 \pm 0,05$	$0,88 \pm 0,05$	$0,88 \pm 0,05$	$0,25 \pm 0,05$	22°	-142°	120°
3s	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	$0,50 \pm 0,05$	0°	-120°	120°
3a	$0,50 \pm 0,05$	$0,90 \pm 0,05$	$0,90 \pm 0,05$	$0,50 \pm 0,05$	14°	-134°	120°
4s	$0,75 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	$0,75 \pm 0,05$	0°	-120°	120°
4a	$0,75 \pm 0,05$	$0,94 \pm 0,05$	$0,94 \pm 0,05$	$0,75 \pm 0,05$	7°	-127°	120°
5	$0,10 \pm 0,05$	1	$0,10 \pm 0,05$	$0,10 \pm 0,05$	0°	-120°	120°
6	$0,50 \pm 0,05$	1	$0,50 \pm 0,05$	$0,50 \pm 0,05$	0°	-120°	120°
7	$1,20 \pm 0,05$	$1,20 \pm 0,05$	$1,20 \pm 0,05$	$1,20 \pm 0,05$	0°	-120°	120°
8	$1,25 \pm 0,05$	$1,25 \pm 0,05$	$1,25 \pm 0,05$	$1,25 \pm 0,05$	0°	-120°	120°
normal condition	1	1	1	1	0°	-120°	120°
(*) Regardless of the method used to simulate the transients (simulator or impedance network), the falling and rising edges of the voltage must have a duration of less than 10 ms.							

CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict


Graph of LVRT and OVRT test:				
Model	AF6K-SLP+15Battery			
List of tests	Residual amplitude of phase-to-phase voltage V/V _{nom}	Drop duration limit [ms]	Measured drop duration [ms]	Duration of restoring network [ms]
1s – three-phase symmetrical fault (P = 0,1 - 0,3)	0,10 ± 0,05 (V ₁ /V _n)	200 +20	210	98
1s – three-phase symmetrical fault (P > 0,9)	0,10 ± 0,05 (V ₁ /V _n)	200 +20	210	153
1a – two-phase asymmetrical fault (P = 0,1 - 0,3)	0,10 ± 0,05 (V ₁ /V _n)	200 +20	210	167
1a – two-phase asymmetrical fault (P > 0,9)	0,10 ± 0,05 (V ₁ /V _n)	200 +20	210	184
2s – three-phase symmetrical fault (P = 0,1 - 0,3)	0,25 ± 0,05 (V ₂ /V _n)	400 +20	410	107
2s – three-phase symmetrical fault (P > 0,9)	0,25 ± 0,05 (V ₂ /V _n)	400 +20	410	126
2a – three-phase symmetrical fault (P = 0,1 - 0,3)	0,25 ± 0,05 (V ₂ /V _n)	400 +20	410	155
2a – three-phase symmetrical fault (P > 0,9)	0,25 ± 0,05 (V ₂ /V _n)	400 +20	410	172
3s – three-phase symmetrical fault (P = 0,1 - 0,3)	0,50 ± 0,05 (V ₃ /V _n)	850 ± 20	860	102
3s – three-phase symmetrical fault (P > 0,9)	0,50 ± 0,05 (V ₃ /V _n)	850 ± 20	860	143
3a – two-phase asymmetrical fault (P = 0,1 - 0,3)	0,50 ± 0,05 (V ₃ /V _n)	850 ± 20	860	117
3a – two-phase asymmetrical fault (P > 0,9)	0,50 ± 0,05 (V ₃ /V _n)	850 ± 20	860	171
4s – three-phase symmetrical fault (P = 0,1 - 0,3)	0,75 ± 0,05 (V ₄ /V _n)	1300 ± 20	1313	105
4s – three-phase symmetrical fault (P > 0,9)	0,75 ± 0,05 (V ₄ /V _n)	1300 ± 20	1313	132
4a – two-phase asymmetrical fault (P = 0,1 - 0,3)	0,75 ± 0,05 (V ₄ /V _n)	1300 ± 20	1306	126
4a – two-phase asymmetrical fault (P > 0,9)	0,75 ± 0,05 (V ₄ /V _n)	1300 ± 20	1306	189
5 – LV two-phase asymmetrical fault (P = 0,1 - 0,3)	0,10 ± 0,05 (V ₅ /V _n)	200 +20	209	0
5 – LV two-phase asymmetrical fault (P > 0,9)	0,10 ± 0,05 (V ₅ /V _n)	200 +20	209	0
6 – LV two-phase asymmetrical fault (P = 0,1 - 0,3)	0,50 ± 0,05 (V ₆ /V _n)	850 +20	860	0
6 – LV two-phase asymmetrical fault (P > 0,9)	0,50 ± 0,05 (V ₆ /V _n)	850 +20	860	0

CEI 0-21				
Clause	Requirement - Test	Result - Remark	Verdict	
7– HV three-phase symmetrical fault ($P = 0,1 - 0,3$)	$1,20 \pm 0,05 (V_7/Vn)$	500 +20	508	95
7– HV three-phase symmetrical fault ($P > 0,9$)	$1,20 \pm 0,05 (V_7/Vn)$	500 +20	508	127
8– HV three-phase symmetrical fault ($P = 0,1 - 0,3$)	$1,25 \pm 0,05 (V_8/Vn)$	100 +20	108	107
8– HV three-phase symmetrical fault ($P > 0,9$)	$1,25 \pm 0,05 (V_8/Vn)$	100 +20	108	145
Note: The interface protection shall be disabled or adjusted to avoid spurious tripping during testing. The test conditions are performed as worst case conditions. The inverter feeds maximal active and reactive power during the complete test.				


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A), 0% load
 Test overview(voltage,current,active and reactive power)




Test 1s-1.1 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
 Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-1.2 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 1s-1.3 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-1.4 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 1s-2.1 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-2.2 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 1s-2.3 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1s-2.4 Depth of fault phase: 0.1p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 1a-Depth of fault phase: 0.1p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-1.1 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 1a-1.2 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-1.3 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 1a-1.4 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-2.1 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 1a-2.2 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 1a-2.3 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D), 95% load
Instantaneous curve and RMS value of phase currents




Test 1a-2.4 Depth of fault phase: 0.1p.u., two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 2s-1.1 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-1.2 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 2s-1.3 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-1.4 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 2s-2.1 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-2.2 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 2s-2.3 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2s-2.4 Depth of fault phase: 0.25p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 2a-Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-1.1 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 2a-1.2 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-1.3 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 2a-1.4 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-2.1 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 2a-2.2 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 2a-2.3 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 2a-2.4 Depth of fault phase: 0.25p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 3s-1.1 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-1.2 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 3s-1.3 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-1.4 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 3s-2.1 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-2.2 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 3s-2.3 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3s-2.4 Depth of fault phase: 0.5p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 3a-Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-1.1 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 3a-1.2 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-1.3 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 3a-1.4 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-2.1 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 3a-2.2 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 3a-2.3 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




Test 3a-2.4 Depth of fault phase: 0.5p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 4s-1.1 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-1.2 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 4s-1.3 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-1.4 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 4s-2.1 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-2.2 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 4s-2.3 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4s-2.4 Depth of fault phase: 0.75p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 4a-Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-1.1 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 4a-1.2 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-1.3 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 4a-1.4 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-2.1 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 4a-2.2 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 4a-2.3 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents



Test 4a-2.4 Depth of fault phase: 0.75p.u.,two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




Test 5-1.1 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-1.2 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 5-1.3 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-1.4 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),20% load
restoring time




Test 5-2.1 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-2.2 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 5-2.3 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 5-2.4 Depth of fault phase: 0.1p.u.,LV two-phase-asymmetrical (type D), 95% load
restoring time




Test 6-Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-1.1 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Test overview(voltage,current,active and reactive power)




Test 6-1.2 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-1.3 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
Instantaneous curve and RMS value of phase currents




Test 6-1.4 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-2.1 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Test overview(voltage,current,active and reactive power)




Test 6-2.2 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 6-2.3 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D),95% load
Instantaneous curve and RMS value of phase currents



Test 6-2.4 Depth of fault phase: 0.5p.u.,LV two-phase-asymmetrical (type D), 95% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




Test 7-1.1 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-1.2 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




Test 7-1.3 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-1.4 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),20% load
restoring time




Test 7-2.1 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-2.2 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages



Test 7-2.3 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 7-2.4 Depth of fault phase: 1.20p.u.,three-phase-symmetrical (type A), 95% load
restoring time




Test 8-Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A), 0% load
Test overview(voltage,current,active and reactive power)




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-1.1 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Test overview(voltage,current,active and reactive power)




Test 8-1.2 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-1.3 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
Instantaneous curve and RMS value of phase currents




Test 8-1.4 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),20% load
restoring time




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-2.1 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Test overview(voltage,current,active and reactive power)




Test 8-2.2 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase-to-neutral voltages




CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Test 8-2.3 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A),95% load
Instantaneous curve and RMS value of phase currents



Test 8-2.4 Depth of fault phase: 1.25p.u.,three-phase-symmetrical (type A), 95% load
restoring time




CEI 0-21			
Clause	Requirement - Test	Result - Remark	Verdict

Bbis.10	TABLE: Verification of insensitivity to automatic reclosing in phase discrepancy					P
Model	AF6K-SLP+15Battery					
Test 1: Phase angle shift of 90°						
Power level	Cos φ	Phase shift angle(°)	Current 20 ms before phase shift(A)	Current 200ms after phase shift(A)	Result	
100%	0.9995	90	22.50	23.47	The PV inverter continue to feed power to grid after phase angle shift has been performed. No damage, no hazard.	
Test 2: Phase angle shift of 180°						
Power level	Cos φ	Phase shift angle(°)	Current 20 ms before phase shift(A)	Current 200ms after phase shift(A)	Result	
100%	0.9996	180	22.51	0	The inverter is protected off the grid after performing the phase angle conversion and then reconnected to the grid to continue supplying power to the grid. No damage, no danger.	
Note: With reference to the diagram shown in Figure 75 - use of simulated network: -the network simulator must be able to produce phase jumps in the voltage at the inverter output terminals of 90° and 180° respectively; -the storage system must operate at a power level compatible with the characteristics of the test circuit and with a unitary power factor ($\cos \varphi = 1$); -VR: simulated mains voltage. -The storage system must be brought into operation at the full power available for discharge. Let the system operate in the set conditions for at least 5 minutes, compatibly with the energy capacity of the EESS, or the time required for the internal temperature of the converter to stabilize. At the end of the stabilization period, 2 tests must be carried out in sequence, inducing a transient that suddenly produces a phase shift angle on the simulated mains voltage VR equal to 90 ° and 180 °. In the test report, the following must be indicated for each of the two test sequences: -the angle between the voltage before and after the phase jump, with an instrument having an error of 1°; -the current of the storage system over a time window that runs from 20 ms before to at least 200 ms after the phase jump of the simulated mains voltage.						


CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram: shift of 90°

CEI 0-21

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Diagram: shift of 180°

Annex 1

ISO 9001 certificate



CERTIFICATE

N. CN23 – 12689A

This is to certify that the Quality Management System of

AFORE NEW ENERGY TECHNOLOGY (SHANGHAI) CO.,LTD.

Unified social credit code: 91310000561932991K

Registered Address

Building 7, No.333, Wanfang Road, Minhang District, Shanghai

Office & Production Address

Building 7, No.333, Wanfang Road, Minhang District, Shanghai, China

Has been independently assessed and found in conformance with the standard

ISO 9001:2015

For the following scope of activities:

R & D and Manufacture of Photovoltaic Inverter

IAF 19

For further and updated information regarding any changes in the status of this certification please contact via phone under +355696037861 / +39 0296368458 or via email to info@axe-register.com or verify directly on the website www.axe-register.com by using the organization name or the certificate number.

The validity of this certificate is subject to periodic yearly surveillance audit and triennial review of the entire management system of the certified organization.

Date of first registration 10/07/2017
 Date of this certificate 07/07/2023
 Date of expiry 09/07/2026



On behalf of the Certification Body

AXE REGISTER Ltd

Antonio Llavia

Technical Director

DA
CS 007 26.02.18



Signatory of EA/MLA, Mutual Recognition Agreements

During validity period of the certificate a surveillance audit should be carried out once within each 12 months. The label should be pasted on specified position of right side of the certificate then it is valid. The certificate can be checked out at CNCA website (www.cnca.gov.cn).



AXE REGISTER

Piazza Unità d'Italia, 5 - 21047 Saronno (VA) - Italia | +39 02 96368458 | info@axe-register.com

ACM (CHINA) LIMITED, Rm B201, No 352, Waihuan Road, Minhang District, Shanghai 201199, China

Annex 2

IEC 62619 Certificate for used battery



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Lithium-Ion Battery
Name and address of the applicant	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District Shanghai, 201112 - China
Name and address of the manufacturer	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District Shanghai, 201112 - China
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	51,2V, 100Ah, 5120Wh
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	AF5000W-LE, AF5000W-LH
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62619:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	CNDQ-ESH-P24020836

This CB Test Certificate is issued by the National Certification Body



IEC 62619 Certificate for used battery



Ref. Certif. No.

FR_719708

ANNEX

Name and address of the factories:**Dongguan Lithium Valley Energy Co., Ltd.**

No.11 Yinyang Road, Zhangyang Community, Zhangmutou Town, Dongguan City, Guangdong Province - China

Dongguan Lithium Valley Energy Co., Ltd.Room 101, No.4 Fuzhu 4th Street, Zhangyang Community, Zhangmutou Town, Dongguan City
Guangdong Province - China

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 25/07/2024



Annex 3

Datasheet of the relay

HF161F-W

SOLAR RELAY



File No.:E134517



File No.:40031410

File No.:CQC10002050943
CQC18002203499

Features

- 31A switching capacity
- Applicable to inverter used for photovoltaic power generation systems
- Ideal for UPS
- 1.5mm contact gap (compliant to European Photovoltaic Standard VDE0126)
- 1.8mm contact gap (compliant to IEC 62109-2-2011)
- The clearance distance between contact and coil is bigger than 6.4mm, the creepage distance is bigger than 8mm. (special code 477: **7.5mm**)
- Low coil holding voltage contributes to saving energy of equipment.
- UL insulation system: Class F

RoHS compliant

CONTACT DATA

Contact gap	1.5mm	1.8mm	2.0mm	2.3mm
Contact arrangement	1A			
Contact resistance ¹⁾	$\leq 100\text{m}\Omega$ (1A 6VDC)			
Contact material	AgSnO ₂			
Contact rating	Resistive: 26A 250VAC Inductive: 31A 250VAC (cos ϕ =0.8) 0.1s:10s	Resistive: 26A 250VAC Inductive: 33A 250VAC (cos ϕ =0.8) 0.1s:10s	Resistive: 26A 250VAC Inductive: 31A 250VAC (cos ϕ =0.8) 0.1s:10s	Resistive: 26A 250VAC
Max. switching voltage	277VAC			
Max. switching current	31A	33A	31A	26A
Max. switching power	7750VA	8250VA	7750VA	7202VA
Mechanical endurance	1×10^6 OPS	1×10^5 ops	1×10^5 ops	1×10^5 OPS
Electrical endurance	HT type: 3 x 10 ⁵ OPS (26A 250VAC Resistive 75°C 1.5s on 1.5s off)	HT type: 3 x 10 ⁵ OPS (26A 250VAC Resistive 75°C 1.5s on 1.5s off)	HT type: 3 x 10 ⁵ OPS (26A 250VAC Resistive 75°C 1.5s on 1.5s off)	HT type: 3 x 10 ⁵ OPS (26A 250VAC Resistive 75°C Room temp. 1.5s on 1.5s off)

Notes: 1)The data shown above are initial values.

COIL

Coil power	Approx. 1.4W			
Holding voltage	35% to 120%Un (at 23°C) 45% to 80%Un (at 85°C)			

Notes: 1)The coil holding voltage is the voltage of coil after being applied rated voltage for 100ms

2)The relay coil does not allow applied more than maximum of holding voltage values for a long time (Eg: 120% Un at 23°C; 80% Un at 85°C), prevent overheating burned.

COIL DATA

at 23°C

Nominal Voltage VDC	Pick-up Voltage VDC max. ¹⁾	Drop-out Voltage VDC min. ¹⁾	Max. Voltage VDC * ²⁾	Coil Resistance Ω
9	6.3	0.9	10.8	58 x (1±10%)
12	8.4	1.2	14.4	103 x (1±10%)
18	12.6	1.8	21.6	230 x (1±10%)
24	16.8	2.4	28.8	410 x (1±10%)

Notes: 1)The data shown above are initial values.

2)Maximum voltage refers to the maximum voltage which relay coil could endure in a short period of time.



HONGFA RELAY

ISO9001、ISO/TS16949、ISO14001、OHSAS18001、IECQ QC 080000 CERTIFIED

2019 Rev. 1.00

CHARACTERISTICS

Insulation resistance	1000MΩ (at 500VDC)
Dielectric strength	Between coil & contacts 4500VAC 1min Between open contacts 2500VAC 1min
Surge voltage (between coil & contacts)	10kV (1.2/50μs)
Operate time (at rated. volt.)	20ms max.
Release time (at rated. volt.)	10ms max.
Temperature rise (at rated. volt.)	95K max. (Contact load current 31A, rated voltage excitation, at 60°C) 70K max. (Contact load current 31A, 80% of rated voltage excitation, at 85°C)
Shock resistance	Functional 196m/s ² Destructive 980m/s ²
Vibration resistance	10Hz to 55Hz 1.5mm DA -40°C to 85°C
Ambient temperature	(Apply holding voltage to coil, which is 45% to 80% of that of rated voltage)
Humidity	5% to 85% RH
Termination	PCB
Unit weight	Approx. 21g
Construction	Flux proofed

Notes: The data shown above are initial values.

SAFETY APPROVAL RATINGS

UL/CUL	AgSnO ₂	26A 277VAC at 75°C
		22A 277VAC at 85°C
VDE	AgSnO ₂	26A 277VAC at 75°C
		22A 277VAC at 85°C
		31A 250VAC cos ϕ = 0.8 0.1s:10s
		33A 250VAC cos ϕ = 0.8 0.1s:10s (477)

Notes: 1) All values unspecified are at room temperature.

2) Only typical loads are listed above. Other load specifications can be available upon request.

ORDERING INFORMATION

	HF161F-W /	12	-H	T	(XXX)
Type					
Coil voltage	9, 12, 18, 24VDC				
Contact arrangement	H: 1 Form A				
Contact material	T: AgSnO ₂				
Special code ³⁾	XXX: Customer special requirement			Nil: Standard	

Notes: 1) Water cleaning or surface process is not suggested after the flux-proofed relays are assembled on PCB.

2) Flux-proofed relays can not be used in the environment with pollutants like H₂S, SO₂, NO₂, dust, etc.


3) The customer special requirement express as special code after evaluating by Hongfa. e.g. (414) stands for product with coil terminal of 1.4X0.4; e.g. (477) stands for Contact gap: 1.8mm.(456) stands for Contact gap: 2.0mm.(704)stands for Contact gap: 2.3mm.

OUTLINE DIMENSIONS, WIRING DIAGRAM AND PC BOARD LAYOUT


Unit: mm

Outline Dimensions

Standard type



(414) special code version




Annex 4

Pictures of the unit


Enclosure - Front View for AF6K-SL, AF6K-SLP and AF6K-SL-0




Enclosure - Rear for AF6K-SL and AF6K-SLP




Enclosure - Rear for AF6K-SL-0




Enclosure - Side View (Left) for AF6K-SL, AF6K-SLP and AF6K-SL-0




Enclosure - Side View (Right) for AF6K-SL, AF6K-SLP and AF6K-SL-0




Enclosure - Top View for AF6K-SL, AF6K-SLP and AF6K-SL-0




Enclosure - Bottom View for AF6K-SL and AF6K-SLP




Enclosure - Bottom View for AF6K-SL-0



Internal view of inverter for AF6K-SL and AF6K-SLP




Internal view of inverter for AF6K-SL-0



Enclosure - Front View for AF6K-ASL and AF6K-ASL-0



Enclosure - Rear for AF6K-ASL and AF6K-ASL-0



Enclosure - Side View (Left) for AF6K-ASL and AF6K-ASL-0




Enclosure - Side View (Right) for AF6K-ASL and AF6K-ASL-0




Enclosure - Top View for AF6K-ASL and AF6K-ASL-0



Enclosure - Bottom View for AF6K-ASL and AF6K-ASL-0



Internal view of inverter for AF6K-ASL



Internal view of inverter for AF6K-ASL-0



--- End of test report---