NSPIRE-V INSPECTION REPORT

Harrow County Housing Authority - Project-Based Voucher Program

(Simplified model - not an official HUD form)

Project	Bellmont Terrace, 77 Tinderbox Court, Wexmoor, OH 45000
HAP contract	HCHA-PBV-24-0007
Inspection type	Biennial (sample of contract units)
Inspection date	08/20/2026
Units inspected	2A, 2B, 2C, 3B, 3D
Inspector	T. Okonedo-Marsh, NSPIRE-V Inspector

Deficiencies

Unit	Location	Deficiency	Severity	Correct by	Corrected
2A	-	-	-	-	-
2B	Bedroom 2	Egress - window blocked by fixed security bar	Life-Threatening	08/21/2026	08/22/2026
2C	Kitchen	Cabinet door missing	Moderate	09/19/2026	09/05/2026
3B	Hall	Smoke alarm missing battery	Life-Threatening	08/21/2026	08/20/2026
3D	-	-	-	-	-

Life-Threatening deficiencies must be corrected within 24 hours of the inspection; all other deficiencies within 30 days.

REINSPECTION

Reinspection date	09/18/2026
Units	2B, 2C, 3B
Result	PASS - all cited deficiencies verified corrected

No abatement applied. Correction dates are as reported by the owner and verified on site.