Element Materials Technology Wednesbury
Unit 3 Wednesbury One,
Black Country New Road,
Wednesbury,
WS10 7NZ.
United Kingdom

T : +44 (0) 121 506 7500
E : info@element.com
W: www.element.com

SUMMARY OF RESULTS: WIL 552590

Design and Supply

13 Plant Industrial Estate, Merthyr Tydfil, CF48 2SR

This document confirms that the following simulations have been carried out on an outwards opening, single steel doorset and an outwards opening, double steel doorset to BS EN ISO 10077-1:2017 requirements.

The following results were achieved:

BS EN ISO 10077-1:2017 Summary of tests	Result
Outwards opening, single steel doorset	**1.3**
Outwards opening, double steel doorset	**1.3**
Inwards opening, single steel doorset	**1.3**
Inwards opening, double steel doorset	**1.3**

This summary accompanies and must be used only in conjunction with Test Report number WIL 552590

Summary prepared by
T.Maybery*
Trainee Test Engineer

Approved by
C. Bryan*
Door & Window Laboratory Manager

UKAS TESTING
0621

* For and on behalf of Element Materials Technology Wednesbury

Testing carried out by Element Materials Technology
At Unit 3 Wednesbury One, Black Country New Road, Wednesbury. WS10 7NZ

Date issued: 11/11/25