

# GCC Technology

14 Patton dr  
Bloomfield NJ 07003  
7187176579 | gcchvacr@gmail.com | gcchvacr.com

## HVAC Service Order Invoice

Ticket #: 20260120-0014    Date: 2026-01-20    Time: 20:43:14

### CONTACT INFORMATION

Customer: Park It  
Location: 160-162 West 124th Street, New York, NY 10001  
Phone: —  
Email: gary@parkitNY.com

### UNIT INFORMATION

Unit: RTU-2  
Make: York    Model: 12344  
Serial #: 455555x  
Mode: Fault    Health: 85% (Excellent)  
Fault Code: None

### DESCRIPTION OF WORK (AUTO-GENERATED)

Primary Issue: None  
Snapshot:  
Supply: 43.7 F    Return: 44.4 F    ΔT: 0.0 F  
Discharge: 105.3 PSI    Suction: 39.6 PSI  
Superheat: 23.1 F    Subcool: 4.1 F  
Amps: 39.7 A    V1/V2/V3: 243.9/245.4/243.5  
  
Top Alerts:  
[WARNING] UNUSUAL\_PRESSURE\_RATIO: Pressure ratio 2.7 - Outside no  
[WARNING] PHASE\_1\_OVERLOAD: Phase 1 overload: 243.9A  
[WARNING] PHASE\_2\_OVERLOAD: Phase 2 overload: 245.4A  
[WARNING] PHASE\_3\_OVERLOAD: Phase 3 overload: 243.5A

### MATERIALS & SERVICES (TECH TO FILL)

### LABOR DESCRIPTION (TECH TO FILL)

### TERMS

Customer authorizes work to be performed. Service and parts may be billed per agreement.

Customer Signature: \_\_\_\_\_    Date: \_\_\_\_\_